



NSAI
Standards

Irish Standard Recommendation
S.R. CLC/TS 50576:2016

Electric cables - Extended application of test results for reaction to fire

S.R. CLC/TS 50576:2016

Incorporating amendments/corrigenda/National Annexes issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard — national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation — recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

This document replaces/revises/consolidates the NSAI adoption of the document(s) indicated on the CEN/CENELEC cover/Foreword and the following National document(s):

NOTE: The date of any NSAI previous adoption may not match the date of its original CEN/CENELEC document.

This document is based on:

CLC/TS 50576:2016

Published:

2016-12-23

This document was published under the authority of the NSAI and comes into effect on:

2017-01-16

ICS number:

13.220.40

29.060.20

NOTE: If blank see CEN/CENELEC cover page

NSAI
1 Swift Square,
Northwood, Santry
Dublin 9

T +353 1 807 3800
F +353 1 807 3838
E standards@nsai.ie
W NSAI.ie

Sales:
T +353 1 857 6730
F +353 1 857 6729
W standards.ie

Údarás um Chaighdeáin Náisiúnta na hÉireann

National Foreword

S.R. CLC/TS 50576:2016 is the adopted Irish version of the European Document CLC/TS 50576:2016, Electric cables - Extended application of test results for reaction to fire

This document does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with this document does not of itself confer immunity from legal obligations.

In line with international standards practice the decimal point is shown as a comma (,) throughout this document.

This page is intentionally left blank

TECHNICAL SPECIFICATION
SPÉCIFICATION TECHNIQUE
TECHNISCHE SPEZIFIKATION

CLC/TS 50576

December 2016

ICS 13.220.40; 29.060.20

Supersedes CLC/TS 50576:2014

English Version

**Electric cables - Extended application of test results for reaction
to fire**

Câbles électriques - Application étendue des résultats
d'essai

Kabel und Leitungen - Erweiterte Anwendung von
Prüfergebnissen

This Technical Specification was approved by CENELEC on 2016-10-10.

CENELEC members are required to announce the existence of this TS in the same way as for an EN and to make the TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents	Page
European foreword.....	4
Introduction.....	5
1 Scope.....	6
2 Normative references.....	6
3 Terms and definitions	7
4 Extended application of test results (EXAP)	9
4.1 Product families for EXAP	9
4.1.1 General	9
4.1.2 Product families for power cables.....	9
4.1.3 Product families for communication cable.....	9
4.1.4 Product families for optical fibre cables.....	10
4.2 Specific and general EXAP.....	10
5 Specific EXAP with safety margin for power cables	10
5.1 Rules for specific EXAP for EN 50399 test	10
5.2 Extension to cables larger than the tested range	13
6 General EXAP for power cables	14
6.1 Rules for general EXAP for EN 50399 test.....	14
6.2 Example of use of general EXAP (FIGRA) where $m = 1$	16
6.3 Example of use of general EXAP (TSP) where $m = 1$	17
6.4 Example of use of general EXAP (TSP) where m is less than 1	18
7 Specific EXAP with safety margin for optical fibre cables	19
7.1 Rules for specific EXAP for EN 50399 test	19
8 EXAP rule for EN 50399 test for flaming droplets/particles for power, control and communication (copper or optical fibre) cables	20
9 EXAP rule for EN 60332-1-2 test for classes B _{ca} , C _{ca} , and D _{ca} for power, control and communication (copper or optical fibre) cables.....	20
10 EXAP rule for EN 60332-1-2 test for class E _{ca} for power, control and communication (copper or optical fibre) cables.....	21
11 EXAP rule for EN 61034-2 test for classes s1a and s1b for power, control and communication (copper or optical fibre) cables	22
Annex A (informative) Flow chart and checklist for specific EXAP for power cables	23
A.1 Basic EXAP procedure flow chart	23
A.2 Checklist for specific EXAP	24
Annex B (normative) Rounding of numbers.....	25
Annex C (informative) Background information on EN 60332-1-2 and EN 61034-2 testing	26
C.1 Background information regarding EN 60332-1-2 testing	26
C.2 Background information regarding EN 61034-2 testing.....	26
Bibliography.....	28

Tables

Table 1 — Safety margins v_{sm} for power cables	11
Table 2 — Allowed range of cable diameters and cable parameters for using safety margins as specified in Table 1	12
Table 3 — Allowed ranges of d_{max} for EXAP applied for larger cables	13
Table 4 — Safety margins v_{sm} for optical fibre cables	20
Table C.1 — Time for flame application	26
Table C.2 — Number of test pieces for EN 61034–2	27
Table C.3 — Evaluation of EN 61034–2 tests on product families	27

Figures

Figure 1 — Assessment of v_{class} for the classification parameter TSP (theoretical example)	13
Figure 2 — FIGRA results for cable family	17
Figure 3 — TSP results for cable family	18
Figure 4 — TSP results for cable family	19
Figure A.1 — Flow chart of the EXAP procedure	23

CLC/TS 50576:2016 (E)

European foreword

This document (CLC/TS 50576:2016) has been prepared by CLC/TC 20 "Electric cables".

The following date is proposed:

- latest date by which the existence of (doa) [2017-04-10]
this document has to be announced
at national level

This document supersedes CLC/TS 50576:2014.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

This document is meant to be used in conjunction with EN 50575 in order to evaluate the reaction to fire performance of power, control and communication cables.

NOTE For the purposes of this Technical Specification, the term 'electric cables' also covers optical fibre cables.

Introduction

The original project “CEMAC – CE marking of cables” was carried out over a three year period. It brought together cable manufacturers, research and testing laboratories, and research establishments in creating the technical background and developing rules and procedures for extended application of test results (EXAP). More than 200 tests to EN 50399 on more than 100 cables were carried out as part of the project. The final report [1] was published in 2010 and the EXAP rules and procedures developed by the CEMAC project have been used as the basis for this Technical Specification.

A specific EXAP procedure and rules based on the use of safety margins and a cable parameter derived from the extensive CEMAC tests was developed for the most common generic types of power cables used in the European market.

A general EXAP procedure and rules based upon a statistical treatment of the actual test results obtained from a cable family was also developed for any power cables. However, the use of this general procedure and rules will generally require more tests to be carried out than the use of the specific procedure and rules.

Since the CEMAC project report was completed in 2010, the project has been extended to further investigate the performance of optical fibre cables and rules and procedures developed for extended application of test results for these products. An additional report [2] was published in 2015 and the EXAP rules and procedures developed by the further CEMAC project work have been used as the basis for the 2016 revision of this Technical Specification.

General guidance on direct and extended application may be found in CEN/TS 15117 [3].

CLC/TS 50576:2016 (E)

1 Scope

This Technical Specification gives the procedure and rules for extended application of results of tests carried out according to the test methods described in EN 50399, EN 60332-1-2 and EN 61034-2.

The EXAP rules described apply to EN 50399 test results used for classification in classes B_{2ca}, C_{ca} and D_{ca}, additional smoke production classes s1, s2 and s3 and flaming droplets/particles, to EN 60332-1-2 test results used for classification in classes B_{2ca}, C_{ca}, D_{ca} and E_{ca} and to EN 61034-2 test results used for classification in classes s1a and s1b.

Cables of diameter 5,0 mm and less should be tested as bundles according to EN 50399. Bundled cables are not included in the EXAP rules applying to EN 50399 test results.

The rules apply to circular and non-circular cables provided that they fall within the scope of the relevant test method.

A specific EXAP rule has been developed for the most common generic power cable families and optical fibre cables. A general EXAP rule has been developed for any power cable families. The general EXAP rule is not applicable to communication or optical fibre cables.

NOTE 1 Multicore power cables with more than 5 cores are sometimes referred to as control cables with a rated voltage but for the purposes of this Technical Specification are considered as power cables.

The general EXAP rule may be applied in the case of hybrid cables provided that the conditions of 6.1 are fulfilled.

The use of the specific EXAP rule gives benefit in the lower number of cables to be tested for a range of cable constructions (product family).

An EXAP is only possible when cables belong to a defined family as defined in this Technical Specification.

NOTE 2 No EXAP procedure and rules have been developed in respect of the results of tests carried out according to the test method described in EN 60754-2. As the parameters (pH and conductivity) for each cable in a family are determined based upon calculation using material test results, this is considered as a matter of direct application. Material test results taken from any one sample of finished cable from a family are sufficient to calculate the parameters for each cable in the family.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50399, *Common test methods for cables under fire conditions - Heat release and smoke production measurement on cables during flame spread test - Test apparatus, procedures, results*

EN 60332-1-2, *Tests on electric and optical fibre cables under fire conditions - Part 1-2: Test for vertical flame propagation for a single insulated wire or cable - Procedure for 1 kW pre-mixed flame (IEC 60332-1-2)*

EN 61034-2, *Measurement of smoke density of cables burning under defined conditions - Part 2: Test procedure and requirements (IEC 61034-2)*

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-