

Irish Standard Recommendation S.R. HD 629-1-S3:2019

Test requirements for accessories for use on power cables of rated voltage from 3,6/6(7,2) kV up to 20,8/36(42) kV - Part 1: Accessories for cables with extruded insulation

© CENELEC 2019 No copying without NSAI permission except as permitted by copyright law.

S.R. HD 629-1-S3:2019

Incorporating amendments/corrigenda/National Annexes issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation — recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

This document replaces/revises/consolidates the NSAI adoption of the document(s) indicated on the CEN/CENELEC cover/Foreword and the following National document(s):

NOTE: The date of any NSAI previous adoption may not match the date of its original CEN/CENELEC document.

This document is based on: HD 629-1-S3:2019 *Published:* 2019-03-22

This document was published ICS number: under the authority of the NSAI and comes into effect on: 29.060.20 2019-04-09 NOTE: If blank see CEN/CENELEC cover page NSAI T +353 1 807 3800 Sales: 1 Swift Square, F +353 1 807 3838 T+35318576730 Northwood, Santry F +353 1 857 6729 E standards@nsai.ie Dublin 9 W NSAI.ie W standards.ie

Údarás um Chaighdeáin Náisiúnta na hÉireann

National Foreword

S.R. HD 629-1-S3:2019 is the adopted Irish version of the European Document HD 629-1-S3:2019, Test requirements for accessories for use on power cables of rated voltage from 3,6/6(7,2) kV up to 20,8/36(42) kV - Part 1: Accessories for cables with extruded insulation

This document does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

For relationships with other publications refer to the NSAI web store.

Compliance with this document does not of itself confer immunity from legal obligations.

In line with international standards practice the decimal point is shown as a comma (,) throughout this document.

This is a free page sample. Access the full version online.

This page is intentionally left blank

HARMONIZATION DOCUMENT DOCUMENT D'HARMONISATION

HD 629-1-S3

HARMONISIERUNGSDOKUMENT

March 2019

ICS 29.060.20

Supersedes HD 629.1 S2:2006

English Version

Test requirements for accessories for use on power cables of rated voltage from 3,6/6(7,2) kV up to 20,8/36(42) kV - Part 1: Accessories for cables with extruded insulation

Prescriptions relatives aux essais des accessoires des câbles d'énergie pour des tensions assignées de 3,6/6(7,2) kV à 20,8/36(42) kV - Partie 1: Accessoires pour câbles à isolation extrudée Prüfanforderungen für Kabelgarnituren für Starkstromkabel mit einer Nennspannung von 3,6/6(7,2) kV bis 20,8/36(42) kV - Teil 1: Garnituren für Kabel mit extrudierter Kunststoffisolierung

This Harmonization Document was approved by CENELEC on 2019-02-06. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for implementation of this Harmonization Document at national level.

Up-to-date lists and bibliographical references concerning such national implementations may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This Harmonization Document exists in three official versions (English, French, German).

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization Comité Européen de Normalisation Electrotechnique Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2019 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

HD 629.1 S3:2019 (E)

Contents

Page

1	Scope						
•	1 1	General	5				
	1.2	Type of accessories	5				
	1.3	Rated voltage	5				
	1.4	Current	5				
2	Norm	ative references	6				
3	Term	Terms and definitions					
4	Com	ponents	9				
	4.1	Connectors	9				
	4.2	Materials	9				
5	Test assemblies						
	5.1	Identification	9				
	5.2	Cable conductor cross-section	9				
	5.3	Assembly1	11				
	5.4	Terminations1	11				
	5.5	Terminal boxes 1	11				
	5.6	Joints and stop ends 1	11				
	5.7	Separable connectors 1	11				
	5.8	Test arrangements and number of samples1	12				
6	Extent of compliance		12				
	6.1	General1	12				
	6.2	Non range taking terminations, joints and stop ends 1	12				
	6.3	Range taking terminations, joints and stop ends 1	13				
	6.4	Terminations 1	13				
	6.5	Separable connectors 1	14				
	6.6	Connectors	14				
	6.7	Cable constructions	15				
	6.8	Three-core to single core accessory 1	15				
7	Test	sequences1	6				
	7.1	General1	16				
	7.2	Dynamic short circuit performance 1	16				
8	Test	results 1	16				
	8.1	General1	16				
	8.2	Test reports 1	16				
	8.3	Failures1	17				
9	Visua	al examination1	17				
Anr	Annex A (normative) Identification of test cable						
Annex B (normative) Identification of Connector							
Annex C (normative) Visual examination							
Annex D (informative) Examples for cross section selection							
Bibliography							

Tables

Table 1 — Compliance and qualification scheme for non range taking terminations, joints and stop ends	. 10
Table 2 — Compliance and qualification scheme for range taking terminations, joints, and stop ends	. 10
Table 3 — Test cable conductor cross-sections for separable connectors	12
Table 4 — Extension of compliance and qualification scheme for non range taking terminations, joints and stop ends	. 13
Table 5 — Extension of compliance and qualification scheme for range taking terminations, joints, and stop ends	, 13
Table 6 — Compliance requirements of connectors for joints and terminations	. 14
Table 7 – Compliance requirements of lugs for separable connectors	15
Table 8 – Cable insulation compliance	15
Table 9 — Extension of compliance from a three-core accessory to a single-core accessory of the same design	y 15
Table 10 — Indoor terminations for extruded insulation cables (including shrouded terminations)	. 18
Table 11 — Outdoor terminations for extruded insulation cables	19
Table 12 — Straight joints, branch joints and loop joints for extruded insulation cables	20
Table 13 — Stop ends for extruded insulation cables	21
Table 14 — Screened separable connectors for extruded insulation cables	22
Table 15 — Unscreened separable connectors (excluding shrouded terminations) for extruded insulation cables	. 24
Table 16 – Additional tests for compliance extension to other conductor connectors (1)	25
Table 17 – Additional tests for smallest cable cross section compliance (1)	26
Table 18 — Additional tests for separable connector compliance extension to largest cable cross section ⁽¹⁾	. 27
Table 19 — Summary of test voltages	28
Table D.1 — Example for Outdoor Terminations	40
Table D.2 — Example for Joints	41
Table D.3 — Example for Outdoor Terminations	42
Table D.4 — Example for Joints	43

Figures

Figure 1 — Test arrangements for non range taking terminations	. 29
Figure 2 — Test arrangements for range taking terminations	. 30
Figure 3 — Test arrangements for non range taking joints, loop joints and branch-joints	. 31
Figure 4 — Test arrangements for range taking joints, loop joints and branch-joints	. 32
Figure 5 — Test arrangements for non range taking stop ends	. 33
Figure 6 — Test arrangements for range taking stop ends	. 34
Figure 7 — Test arrangements for screened separable connectors	. 35
Figure 8 — Test arrangements for unscreened separable connectors	. 36

HD 629.1 S3:2019 (E)

European foreword

This document (HD 629.1 S3:2019) has been prepared by CLC/TC 20, "Electric cables".

The following dates are fixed:

•	latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement	(dop)	2020-02-06
•	latest date by which the national standards conflicting with this document have to be withdrawn	(dow)	2022-02-06

This document supersedes HD 629.1 S2:2006 and its amendment A1:2008.

This Harmonization Document has been written as part of a series of standards to satisfy the Public Procurement Directive, and is complementary to HD 620, which covers extruded insulation power cables from 3,6/6(7,2) kV to 20,8/36(42) kV, inclusive.

This standard defines the requirements, which may be called up for joints, stop ends, separable connectors, indoor and outdoor terminations when used with extruded insulation power cables covered by HD 620. The equivalent requirements for paper-insulated power cables are given in HD 629.2.

The test methods for these accessories are given in EN 61442:2005.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

4

1 Scope

1.1 General

This document specifies performance requirements for type tests for cable accessories for use on extruded insulation power cables as specified in HD 620 or other relevant cable standards.

Once type test for an accessory is successfully completed, it is not necessary to repeat the test, unless changes are made in the materials, design or manufacturing process, which might affect the performance characteristics.

Possible extra thermo-mechanical forces due to high current loads from renewable sources of power generation are not covered by these tests (under consideration).

Accessories for special applications such as submarine cables, ship cables or hazardous situations (explosive environments, fire resistant cables or seismic conditions) are not included.

Test methods are included in EN 61442:2005.

NOTE 1: This European Standard does not invalidate existing approvals of products achieved on the basis of national standards and specifications and/or the demonstration of satisfactory service performance. However, products approved according to such national standards or specifications cannot directly claim approval to this European standard.

NOTE 2: It may be possible, subject to agreement between supplier and purchaser, and/or the relevant conformity assessment body, to demonstrate that conformity to the earlier standard can be used to claim conformity to this European Standard, provided an assessment is made of any additional type testing that may need to be carried out. Any such additional testing that is part of a sequence of testing cannot be done separately.

1.2 Type of accessories

The accessories covered by this standard are listed below:

- a) indoor and outdoor terminations of all designs, including terminal boxes;
- b) straight-joints, branch-joints, stop ends and loop joints of all designs, suitable for use underground, indoors or outdoors;

NOTE 1 Tests specific for UV and outdoor weather resistance are not included.

c) screened or unscreened plug-in type or bolted-type separable connectors, capable of interfacing with bushing profiles as specified in EN 50180 and EN 50181.

NOTE 2 Joints connecting extruded insulation cables (HD 620) to paper insulated cables (HD 621) are not included. The requirements for these accessories are dealt with in HD 629.2.

1.3 Rated voltage

The rated voltages $U_0/U(U_m)$ of the accessories covered by this standard are 3,6/6(7,2) - 3,8/6,6(7,2) - 6/10(12) - 6,35/11(12) - 8,7/15(17,5) - 12/20(24) - 12,7/22(24) - 18/30(36) - 19/33(36) - 20,8/36(42) kV where:

 U_0 is the rated power-frequency voltage between conductor and earth or metallic screen, for which the cable accessory is designed;

U is the rated power-frequency voltage between conductors for which the cable accessory is designed;

 $U_{\rm m}$ is the maximum value of the 'highest system voltage' for which the cable accessory is designed.

1.4 Current

The continuous current rating of a termination or joint for extruded insulation power cables is in accordance with the appropriate cable specified in HD 620 or other relevant cable standards and is suitable for operation at the rated current and under short circuit fault conditions at the temperatures stated therein.

The current rating of a separable connector is governed by the current rating of the mating bushing (see EN 50180 and EN 50181).



This is a free preview. Purchase the entire publication at the link below:

Product Page

S Looking for additional Standards? Visit Intertek Inform Infostore

> Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation