



NSAI
Standards

Irish Standard
I.S. EN 12504-1:2019

Testing concrete in structures - Part 1: Cored specimens - Taking, examining and testing in compression

I.S. EN 12504-1:2019

Incorporating amendments/corrigenda/National Annexes issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard — national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation — recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

This document replaces/revises/consolidates the NSAI adoption of the document(s) indicated on the CEN/CENELEC cover/Foreword and the following National document(s):

NOTE: The date of any NSAI previous adoption may not match the date of its original CEN/CENELEC document.

This document is based on:

EN 12504-1:2019

Published:

2019-06-26

This document was published under the authority of the NSAI and comes into effect on:

2019-07-26

ICS number:

91.100.30

NOTE: If blank see CEN/CENELEC cover page

NSAI
1 Swift Square,
Northwood, Santry
Dublin 9

T +353 1 807 3800
F +353 1 807 3838
E standards@nsai.ie
W NSAI.ie

Sales:
T +353 1 857 6730
F +353 1 857 6729
W standards.ie

Údarás um Chaighdeáin Náisiúnta na hÉireann

National Foreword

I.S. EN 12504-1:2019 is the adopted Irish version of the European Document EN 12504-1:2019, Testing concrete in structures - Part 1: Cored specimens - Taking, examining and testing in compression

This document does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

For relationships with other publications refer to the NSAI web store.

Compliance with this document does not of itself confer immunity from legal obligations.

In line with international standards practice the decimal point is shown as a comma (,) throughout this document.

This page is intentionally left blank

EUROPEAN STANDARD

EN 12504-1

NORME EUROPÉENNE

EUROPÄISCHE NORM

June 2019

ICS 91.100.30

Supersedes EN 12504-1:2009

English Version

Testing concrete in structures - Part 1: Cored specimens - Taking, examining and testing in compression

Essais pour béton dans les structures - Partie 1 :
Carottes - Prélèvement, examen et essais en
compression

Prüfung von Beton in Bauwerken - Teil 1:
Bohrkernproben - Herstellung, Untersuchung und
Prüfung der Druckfestigkeit

This European Standard was approved by CEN on 29 April 2019.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN 12504-1:2019 (E)

Contents	Page
European foreword.....	3
1 Scope	4
2 Normative references	4
3 Terms and definitions	4
4 Principle	4
5 Apparatus.....	4
6 Taking cores.....	5
6.1 General.....	5
6.2 Location	5
6.3 Drilling.....	5
6.4 Length of cores	5
6.5 Marking and identification	5
7 Examination	6
7.1 Visual inspection	6
7.2 Measurements.....	6
8 Preparation of cores.....	6
8.1 General.....	6
8.2 Length/diameter ratios	7
8.3 Tolerances	7
9 Compression test.....	7
9.1 Storage	7
9.2 Testing.....	7
10 Expression of results.....	8
11 Test report.....	8
12 Precision.....	8
Annex A The effect of aggregate size and core diameter on core specimen strength	9
Bibliography	10

European foreword

This document (EN 12504-1:2019) has been prepared by Technical Committee CEN/TC 104 “Concrete and related products”, the secretariat of which is held by SN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by December 2019, and conflicting national standards shall be withdrawn at the latest by December 2019.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 12504-1:2009.

It is recognized good practice to include measurement of density prior to the determination of compressive strength, as a check on compaction of the concrete.

In drafting the standard consideration has been given to the results of the research programme, part funded by the EC under the Measurement and Testing Programme, contract MAT1-CT94-0043.

The standard includes simple guidance on the process of taking cores, but does not consider a sampling plan. It also provides procedures for visual examination and compressive strength testing, but not the interpretation of the results.

This standard is one of a series on testing concrete.

EN 12504, *Testing concrete in structures*, consists of the following parts:

- *Part 1: Cored specimens – Taking, examining and testing in compression;*
- *Part 2: Non-destructive testing – Determination of rebound number;*
- *Part 3: Determination of pull-out force;*
- *Part 4: Determination of ultrasonic pulse velocity.*

This edition includes the following significant technical changes with respect to EN 12504-1:2009:

- a) editorial revisions;
- b) measurement of core dimensions;
- c) core samples to be tested in an *in situ* or wet conditions;
- d) procedures for preparation of specimens prior to testing.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

EN 12504-1:2019 (E)

1 Scope

This document specifies a method for taking cores from hardened concrete, their examination, preparation for testing and determination of compressive strength.

This document does not give guidance on the decision to drill cores or on the locations for drilling.

This document does not provide procedures for interpreting the core strength results.

For the assessment of in situ compressive strength in structures and precast concrete components, EN 13791 may be used.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 12390-1, *Testing hardened concrete — Part 1: Shape, dimensions and other requirements for specimens and moulds*

EN 12390-3:2019, *Testing hardened concrete — Part 3: Compressive strength of test specimens*

EN 12390-4, *Testing hardened concrete — Part 4: Compressive strength — Specification for testing machines*

3 Terms and definitions

No terms and definitions are listed in this document.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

4 Principle

Cores extracted using a core drill are carefully examined, prepared by grinding or capping and tested in compression using standard procedures.

5 Apparatus

5.1 Core drill, equipment capable of extracting cores from the hardened concrete to the dimensions set out in 6.4 to the tolerances set out in 8.3.

5.2 Compression testing machine, conforming to EN 12390-4 and related to the size of specimens and their expected failure load.

NOTE Concrete compression testing machines conforming to EN 12390-4 may need to be adapted to test cores (see the Foreword of EN 12390-4).

5.3 Balance or scale, capable of determining the mass of the core, as tested, to a maximum permissible error of 0,1 % of the mass.

5.4 Callipers and/or rules, capable of measuring the dimensions of the core and the steel reinforcement to a maximum permissible error of 1 %.

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-