



NSAI
Standards

Irish Standard
I.S. EN 15182-4:2019

Portable equipment for projecting extinguishing agents supplied by firefighting pumps - Hand-held branchpipes for fire service use - Part 4: High pressure branchpipes PN 40

I.S. EN 15182-4:2019

Incorporating amendments/corrigenda/National Annexes issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard — national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation — recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

This document replaces/revises/consolidates the NSAI adoption of the document(s) indicated on the CEN/CENELEC cover/Foreword and the following National document(s):

NOTE: The date of any NSAI previous adoption may not match the date of its original CEN/CENELEC document.

This document is based on:

EN 15182-4:2019

Published:

2019-08-14

This document was published under the authority of the NSAI and comes into effect on:

2019-09-01

ICS number:

13.220.10

NOTE: If blank see CEN/CENELEC cover page

NSAI
1 Swift Square,
Northwood, Santry
Dublin 9

T +353 1 807 3800
F +353 1 807 3838
E standards@nsai.ie
W NSAI.ie

Sales:
T +353 1 857 6730
F +353 1 857 6729
W standards.ie

Údarás um Chaighdeáin Náisiúnta na hÉireann

National Foreword

I.S. EN 15182-4:2019 is the adopted Irish version of the European Document EN 15182-4:2019, Portable equipment for projecting extinguishing agents supplied by firefighting pumps - Hand-held branchpipes for fire service use - Part 4: High pressure branchpipes PN 40

This document does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

For relationships with other publications refer to the NSAI web store.

Compliance with this document does not of itself confer immunity from legal obligations.

In line with international standards practice the decimal point is shown as a comma (,) throughout this document.

This page is intentionally left blank

EUROPEAN STANDARD

EN 15182-4

NORME EUROPÉENNE

EUROPÄISCHE NORM

August 2019

ICS 13.220.10

Supersedes EN 15182-4:2007+A1:2009

English Version

Portable equipment for projecting extinguishing agents
supplied by firefighting pumps - Hand-held branchpipes
for fire service use - Part 4: High pressure branchpipes PN
40

Équipement portable de projection d'agents
d'extinction alimenté par des pompes à usage incendie
- Lances à main destinées aux services d'incendie et de
secours - Partie 4 : Lances haute pression PN 40

Tragbare Geräte zum Ausbringen von Löschmitteln, die
mit Feuerlöschpumpen gefördert werden - Strahlrohre
für die Brandbekämpfung - Teil 4:
Hochdruckstrahlrohre PN 40

This European Standard was approved by CEN on 10 June 2019.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN 15182-4:2019 (E)

Contents		Page
European foreword		3
1	Scope	4
2	Normative references	4
3	Terms and definitions	4
4	Requirements and verification	5
4.1	General	5
4.2	Mechanical characteristics	5
4.2.1	Dimensions and mass	5
4.2.2	Operating and handling elements	6
4.2.3	Flow adjustment positions	7
4.2.4	Jet spray angles and adjustment positions	7
4.3	Hydraulic characteristics	10
4.3.1	General	10
4.3.2	Flow rates	10
4.3.3	Effective throw	11
4.3.4	Pressure control test for type 4 branchpipes	12
4.4	Leak-tightness	12
4.5	Hydrostatic behaviour	13

European foreword

This document (EN 15182-4:2019) has been prepared by Technical Committee CEN/TC 192 “Fire and rescue service equipment”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by February 2020, and conflicting national standards shall be withdrawn at the latest by February 2020.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 15182-4:2007+A1:2009.

Compared to EN 15182-4:2007+A1:2009 the following changes have been made:

- new maximum flowrate: 250 l/min;
- the definitions have been updated;
- each verification has been placed under the corresponding requirement;
- a test to measure the forces needed to move the rotating elements which have detents (4.2.2) has been added;
- the requirements for flowrates (4.3.2) have been updated;
- the verifications for leak-tightness (4.4) and hydrostatic behaviour (4.5) have been updated;
- improvement of the wording/editorial changes.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

EN 15182-4:2019 (E)

1 Scope

In addition to the requirements given in EN 15182-1:2019, this document applies to hand-held high pressure branchpipes (nozzles) with a nominal pressure of 40 bar (4,0 MPa) PN 40, with a maximum flow rate up to 250 l/min at a reference pressure of 6 bar (0,6 MPa). It deals with:

- safety requirements;
- performance requirements;
- test methods.

This document applies to branchpipes as defined in Annex A of EN 15182-1:2019.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 15182-1:2019, *Portable equipment for projecting extinguishing agents supplied by firefighting pumps — Hand-held branchpipes for fire service use — Part 1: Common requirements*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 15182-1:2019 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1 high pressure branchpipe
branchpipe including a shut-off device and an adjustable pattern with a nominal pressure (maximum operating pressure) of 40 bar

Note 1 to entry: Branchpipe is defined in 3.1 of EN 15182-1:2019.

3.1.1 high pressure branchpipe - type 1
high pressure branchpipe with adjustable pattern at variable flow

Note 1 to entry: Changing pattern changes the flow at one given pressure.

3.1.2 high pressure branchpipe - type 2
high pressure branchpipe with adjustable pattern at fixed flow

Note 1 to entry: Changing pattern does not change the flow at one given pressure.

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-