

Irish Standard I.S. EN 15004-6:2020

Fixed firefighting systems - Gas extinguishing systems - Part 6: Physical properties and system design of gas extinguishing systems for HFC 23 extinguishant (ISO 14520-10:2019, modified)

 $\ensuremath{\mathbb S}$ CEN 2020 $\hfill No copying without NSAI permission except as permitted by copyright law.$

I.S. EN 15004-6:2020

Incorporating amendments/corrigenda/National Annexes issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation — recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

This document replaces/revises/consolidates the NSAI adoption of the document(s) indicated on the CEN/CENELEC cover/Foreword and the following National document(s):

NOTE: The date of any NSAI previous adoption may not match the date of its original CEN/CENELEC document.

This document is based on: EN 15004-6:2020 *Published:* 2020-10-07

This document was published under the authority of the NSAI and comes into effect on:

2020-10-26

ICS number:

13.220.20

NOTE: If blank see CEN/CENELEC cover page

NSAI	T +353 1 807 3800	Sales:
1 Swift Square,	F +353 1 807 3838	T +353 1 857 6730
Northwood, Santry	E standards@nsai.ie	F +353 1 857 6729
Dublin 9	W NSAI.ie	W standards.ie

Údarás um Chaighdeáin Náisiúnta na hÉireann

National Foreword

I.S. EN 15004-6:2020 is the adopted Irish version of the European Document EN 15004-6:2020, Fixed firefighting systems - Gas extinguishing systems - Part 6: Physical properties and system design of gas extinguishing systems for HFC 23 extinguishant (ISO 14520-10:2019, modified)

This document does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

For relationships with other publications refer to the NSAI web store.

Compliance with this document does not of itself confer immunity from legal obligations.

In line with international standards practice the decimal point is shown as a comma (,) throughout this document.

This is a free page sample. Access the full version online.

This page is intentionally left blank

This is a free page sample. Access the full version online. I.S. EN 15004-6:2020

EUROPEAN STANDARD NORME EUROPÉENNE

EN 15004-6

EUROPÄISCHE NORM

October 2020

ICS 13.220.20

Supersedes EN 15004-6:2008

English Version

Fixed firefighting systems - Gas extinguishing systems -Part 6: Physical properties and system design of gas extinguishing systems for HFC 23 extinguishant (ISO 14520-10:2019, modified)

Installations fixes de lutte contre l'incendie -Installations d'extinction à gaz - Partie 6 : Propriétés physiques et conception des systèmes pour agent extincteur HFC 23 (ISO 14520-10:2019, modifiée) Ortsfeste Brandbekämpfungsanlagen - Löschanlagen mit gasförmigen Löschmitteln - Teil 6: Physikalische Eigenschaften und Anlagenauslegung für Feuerlöschmittel HFC 23 (ISO 14520-10:2019, modifiziert)

This European Standard was approved by CEN on 17 August 2020.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

Page

European foreword		
1	Scope	5
2	Normative references	5
3	Terms and definitions	5
4	Characteristics and uses	. 5
4.1	General	. 5
4.2	Use of HFC 23 systems	6
5	Safety of personnel	9
6	System design	10
6.1	Fill density	0
6.2	Superpressurization	0
6.3	Extinguishant quantity	1
6.4	Other fill density and superpressurization levels 1	3
7	Environmental properties 1	4

European foreword

This document (EN 15004-6:2020) has been prepared by Technical Committee CEN/TC 191 "Fixed firefighting systems", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2021, and conflicting national standards shall be withdrawn at the latest by April 2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 15004-6:2008.

The main changes in EN 15004-6:2020 compared to EN 15004-6:2008 are the following:

- European foreword: Part 3 was removed from the list;
- Foreword of ISO 14520-10 was removed;
- Scope: Nominal pressure level 70 bar was added;
- 6.1, Fill density: 70 bar storage container was added;
- 6.2, Superpressurization option 70 bar was added;
- 6.3, Temperature/pressure graph for HFC 23 superpressurized to 70 bar at 20 °C was added;
- 6.4, Other fill density and superpressurization levels: new sub-clause added;
- Clause 7, Environmental properties: new clause added.

The text of the International Standard ISO 14520-10:2019 from Technical Committee ISO/TC 21 "Equipment for fire protection and firefighting" of the International Organization for Standardization (ISO) has been taken over as a European Standard by Technical Committee CEN/TC 191 "Fixed firefighting systems", the secretariat of which is held by BSI, with common modifications which are indicated by a straight line in the margin of the text.

EN 15004 will consist of the following parts, under the general title *Fixed firefighting systems* — *Gas extinguishing systems:*

- Part 1: *Design, installation and maintenance;*
- Part 2: Physical properties and system design of gas extinguishing systems for FK-5-1-12 extinguishant;
- Part 4: Physical properties and system design of gas extinguishing systems for HFC 125 extinguishant;
- Part 5: Physical properties and system design of gas extinguishing systems for HFC 227ea extinguishant;
- Part 6: *Physical properties and system design of gas extinguishing systems for HFC 23 extinguishant;*

This is a free page sample. Access the full version online. I.S. EN 15004-6:2020

- Part 7: Physical properties and system design of gas extinguishing systems for IG-01 extinguishant;
- Part 8: Physical properties and system design of gas extinguishing systems for IG-100 extinguishant;
- Part 9: Physical properties and system design of gas extinguishing systems for IG-55 extinguishant;
- Part 10: *Physical properties and system design of gas extinguishing systems for IG-541.*

The International Standards ISO 14520-2 and ISO 14520-11, which dealt with $CF_{3}I$ and HFC 236fa extinguishants, respectively, have not been implemented by CEN, as $CF_{3}I$ is only valid for local application and HFC 236fa extinguishant is only applicable for portable fire extinguishers and local application, respectively, which is not covered by the scope.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

This document contains specific requirements for gaseous fire-extinguishing systems, with respect to the HFC 23 extinguishant. It includes details of physical properties, specification, usage and safety aspects and is applicable to systems operating at a nominal pressure of 41 bar without nitrogen superpressurization and 70 bar superpressurized with nitrogen.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 15004-1:2019, Fixed firefighting systems — Gas extinguishing systems — Part 1: Design, installation and maintenance

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 15004-1 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <u>http://www.iso.org/obp</u>
- IEC Electropedia: available at <u>http://www.electropedia.org/</u>

4 Characteristics and uses

4.1 General

Extinguishant HFC 23 shall comply with the specification shown in Table 1.

HFC 23 is a colourless, almost odourless, electrically non-conductive gas with a density approximately 2,4 times that of air.

The physical properties are shown in Table 2.

HFC 23 extinguishes fires mainly by physical means, but by some chemical means.

Property	Requirement
Purity	99,6 % (mol/mol), min.
Acidity	3 × 10 ⁻⁶ by mass, max.
Water content	10 × 10⁻⁶ by mass, max.
Non-volatile residue	0,01 % by mass, max.
Suspended matter or sediment	None visible

Table 1 — Specification for HFC 23



This is a free preview. Purchase the entire publication at the link below:

Product Page

S Looking for additional Standards? Visit Intertek Inform Infostore

> Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation