



NSAI
Standards

Irish Standard Recommendation
S.R. CLC/TS 50600-2-10:2021

Information technology - Data centre facilities and infrastructures - Part 2-10: Earthquake risk and impact analysis

S.R. CLC/TS 50600-2-10:2021

Incorporating amendments/corrigenda/National Annexes issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard — national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation — recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

This document replaces/revises/consolidates the NSAI adoption of the document(s) indicated on the CEN/CENELEC cover/Foreword and the following National document(s):

NOTE: The date of any NSAI previous adoption may not match the date of its original CEN/CENELEC document.

This document is based on:

CLC/TS 50600-2-10:2021

Published:

2021-03-12

*This document was published
under the authority of the NSAI
and comes into effect on:*

2021-03-30

ICS number:

NOTE: If blank see CEN/CENELEC cover page

NSAI
1 Swift Square,
Northwood, Santry
Dublin 9

T +353 1 807 3800
F +353 1 807 3838
E standards@nsai.ie
W NSAI.ie

Sales:
T +353 1 857 6730
F +353 1 857 6729
W standards.ie

Údarás um Chaighdeáin Náisiúnta na hÉireann

National Foreword

S.R. CLC/TS 50600-2-10:2021 is the adopted Irish version of the European Document CLC/TS 50600-2-10:2021, Information technology - Data centre facilities and infrastructures - Part 2-10: Earthquake risk and impact analysis

This document does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

For relationships with other publications refer to the NSAI web store.

Compliance with this document does not of itself confer immunity from legal obligations.

In line with international standards practice the decimal point is shown as a comma (,) throughout this document.

This page is intentionally left blank

TECHNICAL SPECIFICATION
SPÉCIFICATION TECHNIQUE
TECHNISCHE SPEZIFIKATION

CLC/TS 50600-2-10

March 2021

ICS 35.110; 35.020; 35.160

English Version

**Information technology - Data centre facilities and infrastructures
- Part 2-10: Earthquake risk and impact analysis**

Technologie de l'information - Installation et infrastructures
de centres de traitement de données - Partie 2-10 : Risque
sismique et analyse d'impact

Informationstechnik - Einrichtungen und Infrastrukturen von
Rechenzentren - Teil 2-10: Analyse des Risikos und der
Auswirkung von Erdbeben

This Technical Specification was approved by CENELEC on 2021-01-25.

CENELEC members are required to announce the existence of this TS in the same way as for an EN and to make the TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	4
Introduction.....	5
1 Scope.....	8
2 Normative references.....	8
3 Terms, definitions and abbreviations	8
3.1 Terms and definitions	8
3.2 Abbreviations	9
4 Availability Class of EN 50600-1.....	9
5 Overview of risk associated with seismic activity	10
5.1 Direct risk of seismic motion.....	10
5.1.1 Ground motion	10
5.1.2 Long-period ground motion	10
5.1.3 Ground liquefaction.....	10
5.2 Indirect risk initiated by seismic motion.....	10
5.2.1 Fire and toxic or damaging effluent	10
5.2.2 Explosion.....	10
5.2.3 Flooding.....	10
5.2.4 Utilities	10
5.2.5 Access.....	11
5.2.6 Transport.....	11
5.2.7 Security systems.....	12
6 Seismic activity risk assessment	12
6.1 General.....	12
6.2 Ground motion	12
6.3 Ground stability.....	13
6.4 Evaluation by Probable Maximum Loss (PML).....	14
6.4.1 General	14
6.4.2 Advantages and disadvantages	15
7 Seismic activity risk mitigation.....	15
7.1 Direct risk of seismic motion.....	15
7.1.1 General	15
7.1.2 Structural mitigation using isolation base techniques	15
7.1.3 Localized mitigation	18
7.1.4 Roofs and ceiling supports	19
7.2 Indirect risk initiated by seismic motion.....	20
7.2.1 Fire and toxic or damaging effluent	20
7.2.2 Explosion.....	21
7.2.3 Flooding.....	21
7.2.4 Utilities	21
7.2.5 Access.....	22
7.2.6 Transport.....	22
8 Disaster planning and recovery	22

Bibliography	23
--------------------	----

Tables

Table 1 — PGA and Seismic Intensity Scales	12
Table 2 — PGA and typical damage	12
Table 3 — P_L value and risk of liquefaction	14
Table 4 — Example of evaluation criteria of PML	14

Figures

Figure 1 — Schematic relationship between the EN 50600 series of documents	6
Figure 2 — The effect of soil liquefaction	14
Figure 3 — Structure with an isolation base	16
Figure 4 — Oil damper	16
Figure 5 — Lead damper	16
Figure 6 — Steel damper	17
Figure 7 — Laminated rubber isolator	17
Figure 8 — Laminated rubber isolator with lead plug	17
Figure 9 — Sliding bearing	18
Figure 10 — Rack isolator	18
Figure 11 — Equipment suspended from roof/ceiling slab	19
Figure 12 — Example of duct or cable management systems suspended from roof/ceiling slab	20
Figure 13 — Anti-drop measures of lightning equipment for suspended ceiling systems	20

CLC/TS 50600-2-10:2021 (E)

European foreword

This document (CLC/TS 50600-2-10:2021) has been prepared by CLC/TC 215 “Electrotechnical aspects of telecommunication equipment”.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

This document is based on the text of ISO/IEC TR 22237-30:—¹.

Regarding the structure of the EN 50600 series, see the Introduction.

¹ Under preparation. Stage at time of publication: ISO/IEC DTS 22237 30:2020.

Introduction

The unrestricted access to internet-based information demanded by the information society has led to an exponential growth of both internet traffic and the volume of stored/retrieved data. Data centres are housing and supporting the information technology and network telecommunications equipment for data processing, data storage and data transport. They are required both by network operators (delivering those services to customer premises) and by enterprises within those customer premises.

Data centres usually provide modular, scalable and flexible facilities and infrastructures to easily accommodate the rapidly changing requirements of the market. In addition, energy consumption of data centres has become critical both from an environmental point of view (reduction of environmental footprint) and with respect to economic considerations (cost of energy) for the data centre operator.

The implementation of data centres varies in terms of:

- a) purpose (enterprise, co-location, co-hosting, or network operator facilities);
- b) security level;
- c) physical size;
- d) accommodation (mobile, temporary and permanent constructions).

The needs of data centres also vary in terms of availability of service, the provision of security and the objectives for energy efficiency. These needs and objectives influence the design of data centres in terms of building construction, power distribution, environmental control and physical security as well as the operation of the data centre. Effective management and operational information is crucial for monitoring achievement of the defined needs and objectives.

This series specifies requirements and recommendations to support the various parties involved in the design, planning, procurement, integration, installation, operation and maintenance of facilities and infrastructures within data centres. These parties include:

- 1) owners, facility managers, ICT managers, project managers, main contractors;
- 2) architects, consultants, building designers and builders, system and installation designers;
- 3) facility and infrastructure integrators, suppliers of equipment;
- 4) installers, maintainers.

At the time of publication of this document, the EN 50600 series will comprise the following standards and documents:

EN 50600-1, *Information technology — Data centre facilities and infrastructures — Part 1: General concepts*

EN 50600-2-1, *Information technology — Data centre facilities and infrastructures — Part 2-1: Building construction*

CLC/TS 50600-2-10, *Information technology — Data centre facilities and infrastructures — Part 2-10: Earthquake risk and impact analysis*

EN 50600-2-2, *Information technology — Data centre facilities and infrastructures — Part 2-2: Power supply and distribution*

EN 50600-2-3, *Information technology — Data centre facilities and infrastructures — Part 2-3: Environmental control*

EN 50600-2-4, *Information technology — Data centre facilities and infrastructures — Part 2-4: Telecommunications cabling infrastructure*

CLC/TS 50600-2-10:2021 (E)

EN 50600-2-5, *Information technology — Data centre facilities and infrastructures — Part 2-5: Security systems*

EN 50600-3-1, *Information technology — Data centre facilities and infrastructures — Part 3-1: Management and operational information*

EN 50600-4-1, *Information technology — Data centre facilities and infrastructures — Part 4-1: Overview of and general requirements for key performance indicators*

EN 50600-4-2, *Information technology — Data centre facilities and infrastructures — Part 4-2: Power Usage Effectiveness*

EN 50600-4-3, *Information technology — Data centre facilities and infrastructures — Part 4-3: Renewable Energy Factor*

EN 50600-4-6, *Information technology — Data centre facilities and infrastructures — Part 4-6: Energy Reuse Factor*

EN 50600-4-7, *Information technology — Data centre facilities and infrastructures — Part 4-7: Cooling Efficiency Ratio*

CLC/TR 50600-99-1, *Information technology — Data centre facilities and infrastructures — Part 99-1: Recommended practices for energy management*

CLC/TR 50600-99-2, *Information technology — Data centre facilities and infrastructures — Part 99-2: Recommended practices for environmental sustainability*

CLC/TR 50600-99-3, *Information technology — Data centre facilities and infrastructures — Part 99-3: Guidance to the application of EN 50600 series.*

The inter-relationship of the documents within the EN 50600 series is shown in Figure 1.




Figure 1 — Schematic relationship between the EN 50600 series of documents

EN 50600-2-X documents specify requirements and recommendations for particular facilities and infrastructures to support the relevant classification for “availability”, “physical security” and “energy efficiency enablement” selected from EN 50600-1.

EN 50600-3-X documents specify requirements and recommendations for data centre operations, processes and management.

EN 50600-4-X documents specify requirements and recommendations for key performance indicators (KPIs) used to assess and improve the resource usage efficiency and effectiveness, respectively, of a data centre.

CLC/TS 50600-5-X documents provide a maturity model addressing the facilities, infrastructures and the information and communication technology equipment of the data centre.

Determination of the risk and scale of seismic activity should be included as part of the overall risk assessment approach according to EN 50600-1.

In addition, EN 50600-2-1 requires a geographical risk analysis which includes seismic activity and requires mitigation actions to be undertaken as necessary but does not identify the specific actions to be applied. EN 50600-2-5 addresses external environmental events but does not explicitly list earthquakes or seismic activity within that group of events (other than general vibration) or indicate the specific measures required.

As a result, this document, CLC/TS 50600-2-10, provides requirements and recommendations for the type of risk assessment to be employed concerning seismic activity and earthquakes in relation to data centres.

CLC/TS 50600-2-10:2021 (E)

1 Scope

This document provides requirements and recommendations for the type of risk assessment to be employed concerning seismic activity and earthquakes in relation to data centres. In addition, it describes design concepts that can be employed as mitigation actions within the construction, and other elements of design, of data centres.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50600 (series), *Information technology — Data centre facilities and infrastructures*

3 Terms, definitions and abbreviations

3.1 Terms and definitions

For the purposes of this document, the terms and definitions in the EN 50600 series and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1.1

aseismic performance

resistance to seismic activity of a specified scale

3.1.2

base isolation building

structure that absorbs the energy of earthquakes by installing a base isolation layer composed of isolators and dampers between the ground and the building

3.1.3

information and communication technology equipment

ICT equipment

information technology (IT) and network telecommunications (NT) equipment providing data storage, processing and transport services

Note 1 to entry: Representing the “critical load” of the data centre.

[SOURCE: CLC/TR 50600-99-1:2020, 3.1.16]

3.1.4

passive damper

structure that absorbs the energy of earthquakes with dampers, etc., by installing energy absorption members such as dampers in main structures

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-