



NSAI
Standards

Irish Standard
I.S. EN 12543-2:2021

Non-destructive testing - Characteristics of focal spots in industrial X-ray systems for use in non-destructive testing - Part 2: Pinhole camera radiographic method

I.S. EN 12543-2:2021

Incorporating amendments/corrigenda/National Annexes issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard — national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation — recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

This document replaces/revises/consolidates the NSAI adoption of the document(s) indicated on the CEN/CENELEC cover/Foreword and the following National document(s):

NOTE: The date of any NSAI previous adoption may not match the date of its original CEN/CENELEC document.

This document is based on:

EN 12543-2:2021

Published:

2021-04-14

This document was published under the authority of the NSAI and comes into effect on:

2021-05-06

ICS number:

19.100

NOTE: If blank see CEN/CENELEC cover page

NSAI
1 Swift Square,
Northwood, Santry
Dublin 9

T +353 1 807 3800
F +353 1 807 3838
E standards@nsai.ie
W NSAI.ie

Sales:
T +353 1 857 6730
F +353 1 857 6729
W standards.ie

Údarás um Chaighdeáin Náisiúnta na hÉireann

National Foreword

I.S. EN 12543-2:2021 is the adopted Irish version of the European Document EN 12543-2:2021, Non-destructive testing - Characteristics of focal spots in industrial X-ray systems for use in non-destructive testing - Part 2: Pinhole camera radiographic method

This document does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

For relationships with other publications refer to the NSAI web store.

Compliance with this document does not of itself confer immunity from legal obligations.

In line with international standards practice the decimal point is shown as a comma (,) throughout this document.

This page is intentionally left blank

EUROPEAN STANDARD

EN 12543-2

NORME EUROPÉENNE

EUROPÄISCHE NORM

April 2021

ICS 19.100

Supersedes EN 12543-2:2008

English Version

Non-destructive testing - Characteristics of focal spots in industrial X-ray systems for use in non-destructive testing - Part 2: Pinhole camera radiographic method

Essais non destructifs - Caractéristiques des foyers émissifs des tubes radiogènes industriels utilisés dans les essais non destructifs - Partie 2 : Méthode radiographique par sténopé

Zerstörungsfreie Prüfung - Charakterisierung von Brennflecken in Industrie-Röntgenanlagen für die zerstörungsfreie Prüfung - Teil 2: Radiographisches Lochkamera-Verfahren

This European Standard was approved by CEN on 1 March 2021.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents		Page
European foreword		3
Introduction		4
1	Scope	5
2	Normative references	5
3	Terms and definitions	5
4	Test equipment	6
4.1	Essential characteristics of the pinhole	6
4.2	Alignment and position of the pinhole camera	7
4.3	Position of the radiographic image detector	8
4.4	Requirements on the radiographic image detector	9
4.5	Image processing equipment for digital images	10
4.6	Loading factors	10
5	Measurement and determination of the focal spot size	10
5.1	Measurement procedure	10
5.2	Measurement with digital technique (preferred method)	12
5.3	Evaluation with digital technique using Integrated Line Profiles (ILP)	12
5.4	Measurement of effective focal spot size visually using film radiographs	15
6	Classification and result of focal spot size measurement	15
Annex A (normative) Values for the classification of X-ray tube focal spot sizes		17
Bibliography		19

European foreword

This document (EN 12543-2:2021) has been prepared by Technical Committee CEN/TC 138 “Non-destructive testing”, the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2021, and conflicting national standards shall be withdrawn at the latest by October 2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 12543-2:2008.

The main changes compared to the previous edition are as follows:

- The document has been technically and editorially revised;
- The scope of application was extended up to 1000 kV for digital detectors;
- Table 1 has been extended to include pin holes of 10 micron diameter;
- In Annex A, Focal Spot Classes have been introduced for simple X-ray tube classification;
- Chapter 5 introduces a new measurement procedure “Integrated Line Profile”;
- Table A.1 and Table A2 provide a new classification and result of focal spot measurement.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

EN 12543-2:2021 (E)

Introduction

In order to cover the large range of effective focal spot sizes, different methods are described in EN 12543-1, EN 12543-2, EN 12543-3, EN 12543-4 and EN 12543-5.

The pinhole method (EN 12543-2) is intended for effective focal spot sizes above 0,1 mm and mainly used for sealed standard and mini focus tubes.

The edge method of EN 12543-4 is intended for field applications when the users have to observe the effective focal spot on a regular basis and the pinhole method is non-practical.

The edge measurement method of EN 12543-5 is intended for measurement of effective focal spot sizes between 5 μm and 300 μm and mainly for the use with μ -Focus tubes (up to 100 μm) and mini focus tubes with spot sizes of 100 μm to 300 μm .

In the overlapping ranges, the different standard parts provide comparable values within $\pm 20\%$ tolerance.

ASTM E1165 describes the same pinhole procedure.

1 Scope

This document specifies a method for the measurement of effective focal spot dimensions above 0,1 mm of X-ray systems up to and including 1000 kV tube voltage by means of the pinhole camera method with digital evaluation. The tube voltage applied for this measurement is restricted to 200 kV for visual film evaluation and may be selected higher than 200 kV if digital detectors are used.

The imaging quality and the resolution of X-ray images depend highly on the characteristics of the effective focal spot, in particular the size and the two dimensional intensity distribution as seen from the detector plane. This method compared to the others in the EN 12543 series allows to obtain an image of the focal spot and to see the state of it (e.g. cratering of the anode).

This test method provides instructions for determining the effective size (dimensions) of standard (macro focal spots) and mini focal spots of industrial X-ray tubes. This determination is based on the measurement of an image of a focal spot that has been radiographically recorded with a "pinhole" technique and evaluated with a digital method.

For the characterization of commercial X-ray tube types (i.e. for advertising or trade) it is advised that the specific FS (Focal spot) values of Annex A are used.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN ISO 19232-5, *Non-destructive testing - Image quality of radiographs - Part 5: Determination of the image unsharpness and basic spatial resolution value using duplex wire-type image quality indicators (ISO 19232-5)*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1

actual focal spot

X-ray emitting area of the anode as viewed from a position perpendicular to the anode surface

Note 1 to entry: The actual focal spot is also called thermal focal spot in other literature.

Note 2 to entry: See Figure 3, Key 7.

3.2

effective focal spot

X-rays emitting area of the anode as viewed from the image plane of the detector

Note 1 to entry: The effective focal spot is also called optical focal spot in other literature.

Note 2 to entry: See Figure 3, Key 4.

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-