

AS/NZS 3008.1.2:1998

Australian/New Zealand Standard™

**Electrical installations—
Selection of cables**

**Part 1.2: Cables for alternating
voltages up to and including
0.6/1 kV—Typical New Zealand
installation conditions**

AS/NZS 3008.1.2:1998

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL/1, Wiring Rules. It was approved on behalf of the Council of Standards Australia on 11 February 1998 and on behalf of the Council of Standards New Zealand on 12 February 1998. It was published on 5 May 1998.

The following interests are represented on Committee EL/1:

The Association of Consulting Engineers, Australia
Australian Building Codes Board
Australian Electrical and Electronic Manufacturers Association
Canterbury Manufacturers Association, New Zealand
Communications Electrical Plumbing Union, Australia
DAS Interiors Australia
Electrical Contractors Association, Qld
Electrical Contractors Association of New Zealand
Electricity Supply Association of Australia
Institute of Electrical Inspectors, Australia
Institution of Engineers, Australia
Insurance Council of Australia
Ministry of Commerce, New Zealand
National Electrical Contractors Association of Australia
Regulatory authorities (electrical), Australia
Telstra Corporation, Australia

Review of Standards. To keep abreast of progress in industry, Joint Australian/New Zealand Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Joint Standards and related publications will be found in the Standards Australia and Standards New Zealand Catalogue of Publications; this information is supplemented each month by the magazines 'The Australian Standard' and 'Standards New Zealand', which subscribing members receive, and which give details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Joint Standards, addressed to the head office of either Standards Australia or Standards New Zealand, are welcomed. Notification of any inaccuracy or ambiguity found in a Joint Australian/New Zealand Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

AS/NZS 3008.1.2:1998

Australian/New Zealand Standard™

**Electrical installations—
Selection of cables**

**Part 1.2: Cables for alternating
voltages up to and including
0.6/1 kV—Typical New Zealand
installation conditions**

First published as AS/NZS 3008.1.2:1998.

Published jointly by:

Standards Australia
1 The Crescent,
Homebush NSW 2140 Australia

Standards New Zealand
Level 10, Radio New Zealand House,
155 The Terrace,
Wellington 6001 New Zealand

ISBN 0 7337 1902 3

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL/1, Wiring Rules, to supersede AS 3008.1—1989, *Electrical installations—Selection of cables*, Part 1: *Cables for alternating voltages up to and including 0.6/1 kV*.

This Standard (Part 1.2) is applicable to New Zealand installation conditions where the nominal ambient air and soil temperatures are 30°C and 15°C, respectively. Part 1.1 is applicable to Australian installation conditions where the nominal air and soil temperatures are 40°C and 25°C, respectively. Each Part is a complete Standard and requires no reference to the other.

Part 2 will deal with cables for use with alternating voltages over 1 kV.

The objective of the Standard is to specify current-carrying capacity, voltage drop and short-circuit temperature rise of cables, to provide a method of selection for those types of electric cables and methods of installation which are in common use at working voltages up to and including 0.6/1 kV at 50 Hz a.c.

This Standard differs from the 1989 edition as follows:

- (a) Cables with a conductor operating temperature of 110°C have been added.
- (b) Aluminium sheathed MIMS cables have been deleted, tables for copper sheathed MIMS cables have been revised and their sheath operating temperature has been changed to 100°C.
- (c) Paper insulated cables have been deleted.
- (d) Voltage drop tables for tinned copper conductors have been deleted.
- (e) References have been added for aerial bundled cables.
- (f) Tables apply to New Zealand installation conditions.
- (g) Tables have been recalculated to IEC 287, *Electric cables—Calculation of the current rating* (all Parts), based on conductor, insulation and sheath dimensions in the relevant Australian/New Zealand Standards and New Zealand ambient temperatures, except as detailed in Clause 3.1.2. The current ratings for insulated aerial cables are generally based on IEC 287 and on methods proposed by Dr V.T. Morgan of the CSIRO. The work carried out by Dr V.T. Morgan was sponsored by ESAA and AEEMA.

In the preparation of this Standard, reference was made to IEC 287 and acknowledgment is made of the assistance received from that source.

Statements expressed in mandatory terms in notes to tables and figures are deemed to be requirements of this Standard.

The term 'informative' has been used in this Standard to define the application of the appendix to which it applies. An 'informative' appendix is only for information and guidance.

CONTENTS

	<i>Page</i>
FOREWORD	8
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE AND APPLICATION	9
1.2 ALTERNATIVE SPECIFICATIONS	9
1.3 REFERENCED AND RELATED DOCUMENTS	10
1.4 DEFINITIONS	11
SECTION 2 CABLE SELECTION PROCEDURE	
2.1 GENERAL	12
2.2 SELECTION PROCESS	12
2.3 DETERMINATION OF MINIMUM CABLE SIZE BASED ON CURRENT-CARRYING CAPACITY CONSIDERATIONS	12
2.4 DETERMINATION OF MINIMUM CABLE SIZE BASED ON VOLTAGE DROP CONSIDERATIONS	13
2.5 DETERMINATION OF MINIMUM CABLE SIZE BASED ON THE SHORT-CIRCUIT TEMPERATURE CONSIDERATIONS	14
SECTION 3 CURRENT-CARRYING CAPACITY	
3.1 RATINGS	15
3.2 TYPES OF CONDUCTORS	15
3.3 TYPES OF CABLE	16
3.4 INSTALLATION CONDITIONS	18
3.5 EXTERNAL INFLUENCES ON CABLES	21
SECTION 4 VOLTAGE DROP	
4.1 GENERAL	64
4.2 DETERMINATION OF VOLTAGE DROP FROM MILLIVOLTS PER AMPERE METRE	64
4.3 DETERMINATION OF VOLTAGE DROP FROM CIRCUIT IMPEDANCE	65
4.4 DETERMINATION OF VOLTAGE DROP FROM CABLE OPERATING TEMPERATURE	66
4.5 DETERMINATION OF VOLTAGE DROP FROM LOAD POWER FACTOR	67
4.6 DETERMINATION OF VOLTAGE DROP IN UNBALANCED MULTIPHASE CIRCUITS	68
SECTION 5 SHORT-CIRCUIT PERFORMANCE	
5.1 GENERAL	88
5.2 FACTORS GOVERNING THE APPLICATION OF THE TEMPERATURE LIMITS	88
5.3 CALCULATION OF PERMISSIBLE SHORT-CIRCUIT CURRENTS	89
5.4 INFLUENCE OF METHOD OF INSTALLATION	89
5.5 MAXIMUM PERMISSIBLE SHORT-CIRCUIT TEMPERATURES	90

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-