

AS/NZS 2293.2:2019

AS/NZS 2293.2:2019

Australian/New Zealand Standard™

Emergency lighting and exit signs for buildings

Part 2: Routine service and maintenance



AS/NZS 2293.2:2019

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee LG-007, Emergency Lighting In Buildings. It was approved on behalf of the Council of Standards Australia on 25 March 2019 and by the New Zealand Standards Approval Board on 30 January 2019.
This Standard was published on 9 April 2019.

The following are represented on Committee LG-007:

Australasian Fire and Emergency Service Authorities Council
Australian Industry Group
Business New Zealand
Engineers Australia
Fire Protection Association Australia
IES: The Lighting Society
Lighting Council Australia
Lighting Council New Zealand
National Electrical and Communications Association
Property Council of Australia
Queensland University of Technology
University of Sydney
WorkSafe New Zealand

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Site at www.standards.org.au or Standards New Zealand web site at www.standards.govt.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of Standards Australia or the New Zealand Standards Executive at the address shown on the back cover.

This Standard was issued in draft form for comment as DR AS/NZS 2293.2:2018.

AS/NZS 2293.2:2019

Australian/New Zealand Standard™

Emergency lighting and exit signs for buildings

Part 2: Routine service and maintenance

Originated in Australia as AS 2293.2—1979.
Originated in New Zealand as part of NZS 6742:1971.
Previous edition AS/NZS 2293.2:1995.
Fourth edition 2019.

COPYRIGHT

© Standards Australia Limited

© The Crown in right of New Zealand, administered by the New Zealand Standards Executive

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

ISBN 978 1 76072 421 4

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee LG-007, Emergency Lighting for Buildings, to supersede AS/NZS 2293.2:1995, *Emergency escape lighting and exit signs for buildings, Part 2: Inspection and maintenance*.

The objective of this Standard is to establish the performance criteria for the routine service and maintenance of emergency lighting and exit sign systems, such that they continue to safeguard occupants until the next scheduled activity from injury by having adequate emergency lighting and identification of exits, and provide direction to exits in accordance with the approved design.

The changes in this edition are primarily a consequence of alterations made in AS/NZS 2293.1:2018 and AS/NZS 2293.3:2018.

The following changes of significance have been introduced:

- (a) The layout has been aligned with AS 1851, *Routine service of fire protection systems and equipment*. A series of tables and figures has been introduced to simplify application, and reduce duplication and complexity.
- (b) Introduction of—
 - (i) baseline data against which maintenance and ongoing system performance requirements are measured;
 - (ii) concept of routine service, including preventative maintenance;
 - (iii) procedures for intervals greater than 12 months;
 - (iv) concepts of critical, non-critical defect and non-conformance along with requirements for reporting;
 - (v) light source life (LSL) assessment for LED luminaires and exit signs; and
 - (vi) additional information and guidance in Appendices C, D, E, F and G.
- (c) Update references and requirements to align with most recent International and Australian Standards.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

This Standard includes a commentary on some of the clauses. The commentary directly follows the relevant clause, is designated by ‘C’ preceding the clause number and is printed in italics in a box. The commentary is for information and guidance and does not form part of the Standard.

CONTENTS

	Page
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE.....	4
1.2 APPLICATION	4
1.3 NORMATIVE REFERENCES	4
1.4 DEFINITIONS.....	5
SECTION 2 GENERAL REQUIREMENTS	
2.1 ROUTINE SERVICE AND MAINTENANCE OF THE INSTALLATION	7
2.2 BASELINE DATA OF THE INSTALLATION.....	7
2.3 SERVICE PRECAUTIONS.....	7
2.4 SYSTEM RETROFIT.....	8
2.5 FREQUENCY AND TOLERANCES OF ROUTINE SERVICE INTERVALS	8
2.6 RECORDS AND REPORTING.....	10
2.7 ROUTINE SERVICE AND MAINTENANCE RECORDS	10
2.8 CRITICAL DEFECTS	11
2.9 RELATIONSHIPS AND THIS STANDARD.....	12
SECTION 3 INSPECTION, SURVEY, TEST, SERVICE AND MAINTENANCE PROCEDURES	
3.1 GENERAL.....	14
3.2 REQUIRED PROCEDURES	14
3.3 SELF-CONTAINED EMERGENCY LUMINAIRE AND EXIT SIGN SYSTEMS ..	14
3.4 CENTRAL BATTERY EMERGENCY LUMINAIRE AND EXIT SIGN SYSTEMS	15
3.5 LED LUMINAIRES AND EXIT SIGNS.....	15
APPENDICES	
A ROUTINE SERVICE INTERVAL REQUIREMENTS AND SCHEDULES.....	18
B INFORMATION TO FACILITATE THE MAINTENANCE OF BATTERIES AND BATTERY CHARGERS.....	26
C CLEANING OF EMERGENCY LUMINAIRES AND EXIT SIGNS.....	27
D YEARLY CONDITION REPORT.....	28
E SERVICE CONCEPTS FOR POWERED SIGNS	29
F GUIDANCE ON COMPUTER SYSTEM MAINTENANCE	30
G DISPOSAL AND RECYCLING.....	31
BIBLIOGRAPHY	32

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-