# Australian Standard<sup>™</sup>

## Instrument transformers

Part 1: Current transformers (IEC 60044-1:1996, MOD)



This Australian Standard was prepared by Committee EL-013, Measurement and Protection Transformers. It was approved on behalf of the Council of Standards Australia on 13 December 2002 and published on 3 February 2003.

The following are represented on Committee EL-013:

Australian Electrical and Electronic Manufacturers Association

CSIRO

CIGRE AP12

Electricity Supply Association of Australia

University of South Australia

#### Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Australia web site at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Australian Standard*, has a full listing of revisions and amendments published each month.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.com.au, or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

This Standard was issued in draft form for comment as DR 01084.

AS 60044.1-2003

# Australian Standard<sup>™</sup>

## Instrument transformers

# Part 1: Current transformers (IEC 60044-1:1996, MOD)

Originated as part of AS C45—1928. Previous edition AS 1243—1982. AS 1243—1982 revised and re-designated in part as AS 60044.1—2003.

### COPYRIGHT

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd GPO Box 5420, Sydney, NSW 2001, Australia ISBN 0 7337 5020 6 ii

## PREFACE

This Standard was prepared by the Standards Australia Committee EL-013, Measurement and Protection Transformers to supersede AS 1675—1986 one year after publication. During this period it is anticipated that regulatory authorities will approve current transformers to either standard.

The objective of this Standard is to provide users and manufacturers of current transformers with definitions of terms, safety requirements, methods of specifying performance and methods of test.

This Standard is Part One of a series covering instrument transformers. The series consists of the following Standards:

AS

60044 Instrument transformers

60044.1 Part 1: Current transformers (this Standard)

60044.2 Part 2: Single-phase inductive voltage transformers

This Standard is an adoption with national modifications of IEC 60044-1:1996, *Instrument transformers*, Part 1: *Current Transformers* (including Amendment 1: 2000).

Variations to IEC 60044-1:1996 are indicated at the appropriate places throughout this standard. Strikethrough (example) identifies IEC text, tables and figures which, for the purposes of this Australian Standard, are deleted. Where text, tables or figures are added, each is set in its proper place and identified by shading (example). Added figures are not themselves shaded, but are identified by a shaded border.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text 'this standard' should read 'this Australian Standard'.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

The terms 'normative' and 'informative' are used to define the application of the annex to which they apply. A normative annex is an integral part of a standard, whereas an informative annex is only for information and guidance.

Attention is drawn to the following differences between this Standard and AS 1675–1986.

- (a) This Standard has a new thermal class for windings in oil and hermetically sealed that allows 65 K temperature rise. See Table 2, *Limits of temperature rise of the windings*.
- (b) This Standard has highest voltages for equipment of 170 kV and 245 kV in place of 245 kV in AS 1675—1986. See Table 3, *Rated insulation levels for transformer primary windings*.
- (c) This Standard introduces reduced levels of permissible partial discharges across the complete range of system earthing types and voltages, with increases in prestress voltage level (from the current 1.3 times the nominal voltage of the system  $U_n$  level to the induced voltage withstand test level) and in testing voltage level (from 1.1  $U_m$  to 1.3  $U_m$ ). See Clause 5.1.2.2, *Partial discharges* and Clause 8.2.2.2, *Partial discharge test procedure*.
- (d) This Standard allows a maximum permissible voltage across secondary winding of up to 4.5 kV for all cores and up to 10 kV for PX class (the PL class of AS 1675—1986). See Clause 5.1.5, *Inter-turn insulation requirements*.

iii

- (e) This Standard introduces requirements for minimum insulator creepage distance and arcing/creepage ratio for various pollution levels. See Clause 5.1.6, *Requirements for the external insulation*.
- (f) This Standard requires repeated dielectric testing to be performed at 80% of the initial power frequency voltage (and not 75% as in AS 1675—1986). See Clause 6.2.
- (g) This Standard covers measurement of dielectric dissipation factor as a special test, and not as a routine test as does AS 1675–1986. See Clause 6.3, *Special tests*.
- (h) This Standard tests radio interference voltage with a prestress voltage of 1.5 Um/ $\sqrt{3}$ , and a limit of 300 pC or 2500  $\mu$ V at 1.1 Um/ $\sqrt{3}$ . This test is also required for voltages 123 kV and upwards (and not from 245 kV as in AS 1675—1986). See Clause 7.5, *Radio interference voltage measurement*.
- (i) This Standard includes requirements for measurement of partial discharges different to those in AS 1675—1986 (which calls up AS 2532 which has been withdrawn). See Clause 8.2.2, *Partial discharge measurement*.
- (j) This Standard introduces new special tests of chopped impulse on primary winding and mechanical testing of primary terminals. See Clause 9.1, *Chopped impulse test on primary winding* and Clause 5.2, *Mechanical requirements*.
- (k) Special Metering Classes are introduced in this Standard as classes 0.2S and 0.5S for the secondary current 5 A only, with a current range from 1-120% (that can be extended to 150% and 200%). AS 1675—1986 has classes 0.1ME, 0.2ME and 0.5ME for secondary currents 1 A and 5 A, but the current range is 2.5-125/150/200%. See Clause 11.2, *Limits of current error and phase displacement for measuring current transformers*.
- This Standard allows a higher error margin for errors measured at 5-20% of rated current than does AS 1675—1986, but better accuracy can be achieved by selecting a different class for such needs. See Clause 11.2, *Limits of current error and phase displacement for measuring current transformers*.
- (m) This Standard requires a maximum current of 120% for accuracy testing of metering CTs instead of the 125% required in AS 1675—1986. See Clause 11.2, *Limits of current error and phase displacement for measuring current transformers*.
- (n) This Standard allows protection classes 5P and 10P to have accuracies of 1% and 3% respectively. See Clause 12.3, *Limits of errors for protective current transformers*.
- (o) Tests for accuracy are done at 1.0 power factor in AS 1675—1986. This Standard requires tests for accuracy to be done at 0.8 power factor or at 1.0 power factor with the results converted to equivalent results at 0.8 power factor. See Clause 12.3, *Limits of errors for protective current transformers*.
- (p) AS 1675—1986 covered class PS which is not covered in this Standard. However, class PR (air gaps) of this Standard deals with requirements of this type. See Clause 13, Additional requirements for class PR protective current transformers.
- (q) This Standard includes a class PX which covers all requirements of class PL in AS 1675—1986. See Clause 14, Additional requirements for class PX protective current transformers.
- (r) This Standard does not have requirements for thermal stability testing.
- (s) This Standard has no requirements for variation of error margins during accuracy testing of metering cores.



This is a free preview. Purchase the entire publication at the link below:

**Product Page** 

S Looking for additional Standards? Visit Intertek Inform Infostore

> Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation