

Australian Standard™

**Instrument transformers—**

**Part 2: Single-phase inductive voltage  
transformers  
(IEC 60044-2:1997, MOD)**

This Australian Standard was prepared by Committee EL-013, Measurement and Protection Transformers. It was approved on behalf of the Council of Standards Australia on 13 December 2002 and published on 3 February 2003.

---

The following are represented on Committee EL-013:

Australian Electrical and Electronic Manufacturers Association  
CSIRO  
CIGRE AP12  
Electricity Supply Association of Australia  
University of South Australia

---

#### **Keeping Standards up-to-date**

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Australia web site at [www.standards.com.au](http://www.standards.com.au) and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Australian Standard*, has a full listing of revisions and amendments published each month.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at [mail@standards.com.au](mailto:mail@standards.com.au), or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

---

**Australian Standard™**

**Instrument transformers—**

**Part 2: Single-phase inductive voltage  
transformers  
(IEC 60044-2:1997, MOD)**

Originated as part of AS C45—1928.  
Previous edition AS 1243—1982.  
AS 1243—1982 revised and re-designated in part as  
AS 60044.2—2003.

**COPYRIGHT**

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd  
GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 5019 2

## PREFACE

This Standard was prepared by the Standards Australia Committee EL-013, Measurement and Protection Transformers to partially supersede AS 1243—1982 for single phase inductive transformers one year after publication. During this period, it is anticipated that regulatory authorities will approve current transformers to either Standard. AS 1243—1982 will continue to apply to capacitor voltage transformers and three-phase voltage transformers only.

The objective of this Standard is to provide users and manufacturers of voltage transformers with definitions of terms, safety requirements, methods of specifying performance and methods of test.

This Standard is Part Two of a series covering instrument transformers. This series consists of the following Standards:

AS

60044 Instrument transformers

60044.1 Part 1: Current transformers

60044.2 Part 2: Single-phase inductive voltage transformers (this Standard)

This Standard has been reproduced from IEC 60044-2:1997, *Instrument transformers—Part 1: Voltage Transformers* (including Amendment 1: 2000). Some minor variations have been made for Australian conditions.

Variations to IEC 60044-2 (including Amendment 1:2000) are indicated at the appropriate places throughout this Standard. Strikethrough (~~example~~) identifies IEC tables, figures and passages of text which, for the purpose of this Standard, are deleted. Where tables, figures and passages of text are added, each is set in its proper place and identified by shading (example). Added figures are not themselves shaded but are identified by a shaded border.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text ‘this standard’ should read ‘this Australian Standard’.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

In January 1997, the IEC commenced numbering its Standards from 60 000 by adding 60 000 to the number of each existing Standard. Publications printed earlier than 1997 will continue to carry the old series of numbers.

Attention is drawn to the following differences between this Standard and AS 1243—1982:

- (a) This Standard introduces temperature rise testing of voltage transformers with voltage factors of 1.5 for 30 s, 1.9 for 30 s and 1.9 for 8 h starting after the voltage transformers have reached equilibrium at  $1.2 U_n$ . See Clause 5.4, *Limits of temperature rise*.
- (b) This Standard has a new thermal class for windings in oil and hermetically sealed that allows 65 K temperature rise (see Table 3, *Limits of temperature rise of windings*).
- (c) This Standard introduces requirements and tests for winding withstand capability. See Clause 6.1, *Insulation requirements*.
- (d) This Standard has highest voltages for equipment of 170 kV and 245 kV in place of 245 kV in AS 1243—1982. See Clause 6.1.1, *Rated insulation levels for primary windings*.
- (e) This Standard introduces reduced levels of permissible partial discharges across the complete range of system earthing types and voltages, with increases in prestress voltage level (from the current  $1.3 U_n$  level to the induced voltage withstand test level) and in testing voltage level (from  $1.1 U_m$  to  $1.3 U_m$ ). See Clause 6.1.2.3, *Partial discharges* and Clause 9.2.4, *Partial discharge measurement*.

- (f) This Standard introduces requirements for minimum insulator creepage distance and arcing/creepage ratio for four various pollution levels. See Clause 6.1.5, *Requirements for the external insulation*.
- (g) This Standard requires repeated dielectric testing to be performed at 80% of the initial power frequency voltage (and not 75% as in AS 1243—1982). See Clause 7.2.
- (h) This Standard covers measurement of dielectric dissipation factor as a special test, and not as a routine test as does AS 1243—1982. See Clause 7.3, *Special tests*.
- (i) This Standard requires testing of radio interference voltage with a prestress voltage of  $1.5 U_m/\sqrt{3}$ , and a limit of 300 pC or 2500  $\mu\text{V}$  at  $1.1 U_m/\sqrt{3}$ . This test is also required for voltages 123 kV and upwards (and not from 245 kV as in AS 1243—1982). See Clause 8.5, *Radio interference voltage measurement*.
- (j) This Standard includes requirements for measurement of partial discharges that are stricter than those in AS 1243—1982 (which calls up AS 2532 which has been withdrawn). See Clause 9.2.4, *Partial discharge measurement*.
- (k) This Standard introduces new special tests of chopped impulse on primary winding and mechanical testing of primary terminals. See Clause 10.1, *Chopped impulse test on primary winding* and Clause 10.3, *Mechanical tests*.
- (l) This Standard requires that testing for accuracy be done at a primary voltage of 0.8 to 1.2  $U_n$  and a power factor of 0.8 lagging. AS 1243—1982 requires that testing for accuracy be done at a primary voltage of 0.9 to 1.1  $U_n$  and a power factor of 1. See Clause 12.2, *Limits of voltage error and phase displacement for measuring voltage transformers*.
- (m) This Standard has Classes 3P and 6P and does not have the Classes 1P, 2P and 5P of AS 1243—1982. See Clause 13.1.1, *Standard accuracy classes for protective voltage transformers*.
- (n) This Standard does not include requirements for voltage transformers for laboratory use (Class L in AS 1243). The committee considered that this class is no longer required.

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

- 
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
  - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-