

AS/NZS 3439.5:2009
IEC 60439-5, Ed. 2.0 (2006)

AS/NZS 3439.5:2009

Australian/New Zealand Standard™

Low-voltage switchgear and controlgear assemblies

Part 5: Particular requirements for assemblies for power distribution in public networks



AS/NZS 3439.5:2009

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-006, Industrial Switchgear and Controlgear. It was approved on behalf of the Council of Standards Australia on 13 August 2009 and on behalf of the Council of Standards New Zealand on 16 October 2009.
This Standard was published on 11 November 2009.

The following are represented on Committee EL-006:

Australasian Railway Association
Australian Chamber of Commerce and Industry
Australian Electrical and Electronic Manufacturers Association
Bureau of Steel Manufacturers of Australia
Engineers Australia
National Electrical Switchboard Manufacturers Association
Testing Interests (Australia)

Additional Interests:

Subcommittee EL-006-08

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR 07161.

AS/NZS 3439.5:2009

Australian/New Zealand Standard™

Low-voltage switchgear and controlgear assemblies

Part 5: Particular requirements for assemblies for power distribution in public networks

Originated at AS/NZS 3439.5:2001.
Second edition 2009.

COPYRIGHT

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia, GPO Box 476, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 9300 2

PREFACE

This Standard was prepared by the Standards Australia/Standards New Zealand Committee EL-006, Industrial Switchgear and Controlgear to supersede AS/NZS 3439.5:2001 on publication.

The objective of this Standard is to specify requirements for cable distribution cabinets in public places, accessed by skilled persons.

This Standard is identical with, and has been reproduced from IEC 60439-5, Ed. 2.0 (2006), *Low-voltage switchgear and controlgear assemblies – Part 5: Particular requirements for assemblies for power distribution in public networks*.

This publication should be read in conjunction with AS/NZS 3439.1. The numbering of its clauses and subclauses correspond with the latter. The clauses of this Standard supplement, modify or replace clauses in AS/NZS 3439.1.

Where there is no corresponding clause or subclause in this Standard the clause or subclause of AS/NZS 3439.1 applies without modification.

Clauses, subclauses, figures and tables that are additional to those in Part 1 are numbered starting from 101.

This Standard is Part 5 of the following series:

AS/NZS 3439	Low-voltage switchgear and controlgear assemblies
AS/NZS 3439.1	Part 1: Type-tested and partially type-tested assemblies
AS 3439.2	Part 2: Particular requirements for busbar trunking systems (busways)
AS 3439.3	Part 3: Particular requirements for low-voltage switchgear and controlgear assemblies intended to be installed in places where unskilled persons have access for their use—Distribution boards
AS 3439.4	Part 4: Particular requirements for assemblies for construction sites (ACS)
AS/NZS 3439.5	Part 5: Particular requirements for assemblies for power distribution in public networks (this Standard)

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text 'IEC 60439-5' should read 'AS/NZS 3439.5' and 'IEC 60439-1' should read 'AS/NZS 3439.1'.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

The terms 'normative' and 'informative' are used to define the application of the annex to which they apply. A normative annex is an integral part of a standard, whereas an informative annex is only for information and guidance.

CONTENTS

	<i>Page</i>
1 General.....	1
1.1 Scope and object	1
1.2 Normative references.....	1
2 Definitions.....	2
3 Classification of ASSEMBLIES	4
4 Electrical characteristics of ASSEMBLIES	5
5 Information to be given regarding the ASSEMBLY	5
5.1 Nameplates.....	5
5.2 Markings.....	5
6 Service conditions.....	5
7 Design and construction.....	6
8 Test specifications	9
Annex A (normative) Minimum and maximum cross-section of copper and aluminium conductors, suitable for connection	25

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-