

Australian Standard™

Gate valves for waterworks purposes

Part 2: Resilient seated

This Australian Standard was prepared by Committee WS-022, Valves for Water Supply Purposes. It was approved on behalf of the Council of Standards Australia on 21 August 2002 and published on 6 September 2002.

The following are represented on Committee WS-022:

Association of Consulting Engineers Australia
AusPoly
Australian Chamber of Commerce and Industry
Australian Industry Group
Australian Valve Manufacturers Association
Business New Zealand
Certification Bodies (Australia)
Department of Contract and Management Services WA
Local Government New Zealand
Master Plumbers Australia
New Zealand Metal Casting Industry Association
New Zealand Water and Waste Association
Society of Mechanical Engineers of Australasia
Water Industry Alliance
Water Services Association of Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Australia web site at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Australian Standard*, has a full listing of revisions and amendments published each month.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.com.au, or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

This Standard was issued in draft form for comment as DR 02079.

AS 2638.2—2002

Australian Standard™

Gate valves for waterworks purposes

Part 2: Resilient seated

Originated as AS 2638—1983.
Previous edition AS 2638.2—1999.
Second edition 2002.

COPYRIGHT

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd
GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 4790 6

PREFACE

This Standard was prepared by the Australian members of the Joint Standards Australia/Standards New Zealand Committee WS-022, Valves for Water Supply Purposes, to supersede AS 2638.2—1999, *Gate valves for waterworks purposes—Resilient seated*. After consultation with stakeholders in both countries, Standards Australia and Standards New Zealand decided to develop this Standard as an Australian Standard rather than an Australian/New Zealand Standard.

The objective of the this Standard is to specify requirements for Class 16 metal-bodied resilient-seated gate valves for waterworks purposes.

This revision includes the following changes:

- (a) Incorporation of gate valves intended for above ground use in both non-rising and rising spindle designs.
- (b) Inclusion of DN 350, DN 400 and DN 700 sizes.
- (c) Changes to spindle seal retainer requirements.
- (d) Inclusion of a type test for adhesion of rubber to the gate.
- (e) Inclusion of a type test for strength of spindle caps and spindle extensions.
- (g) Revision of test duration. (For product certification purposes for a product that has been certified to AS/NZS 2638.2—1999, it is not required to repeat corresponding type tests within this Standard, except in the case of a design change.)
- (h) Adoption of water industry standard maximum operating temperature of 40°C for water supply.
- (i) Specifying scaling factors to be applied when testing to AS/NZS 4020.

Attention is drawn to the proposed publication of SAI/SNZ Rul PL/2, Rulings to the Joint Australia/New Zealand Standard, Gate valves for waterworks purposes. Where rulings of public significance are issued, they will be available from Standards Australia through a subscription service. When rulings are included in an amendment or revision, the specific ruling will be withdrawn at the time of publication of the amendment. Enquiries should be directed to Standards Australia.

Statements expressed in mandatory terms in notes to tables and figures are deemed to be requirements of this Standard.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

Support and contribution is acknowledged from the Water Services Association of Australia (WSAA).

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE.....	4
1.2 REFERENCED DOCUMENTS.....	4
1.3 DEFINITIONS.....	4
1.4 DESIGNATION OF SIZE	6
1.5 ALLOWABLE PRESSURES	6
SECTION 2 MATERIALS AND COMPONENTS	
2.1 MATERIALS.....	7
2.2 DEZINCIFICATION-RESISTANT MATERIALS.....	7
2.3 CONTAMINATION OF WATER	7
2.4 O-RINGS (ELASTOMERIC TOROIDAL SEALING RINGS)	7
SECTION 3 DESIGN	
3.1 GENERAL.....	9
3.2 DIMENSIONS.....	9
3.3 END CONNECTIONS	9
3.4 GATE	9
3.5 COMPONENT JOINTING.....	10
3.6 WATERWAY.....	10
3.7 SPINDLE.....	10
3.8 OPERATION.....	11
3.9 LIFTING DEVICES	11
3.10 SUPPORT FEET	11
SECTION 4 COATINGS	
4.1 GENERAL.....	16
4.2 DESIGN.....	16
SECTION 5 TESTING	
5.1 TYPE TESTS.....	17
5.2 PRODUCTION TESTS	20
SECTION 6 GEARBOXES	
6.1 DESIGN.....	22
6.2 COATINGS	22
6.3 MARKINGS	22
SECTION 7 MARKING AND PACKAGING	
7.1 BODY MARKINGS	23
7.2 VALVE KEY AND SPINDLE EXTENSION MARKINGS.....	23
7.3 DIRECTION OF CLOSURE FOR HANDWHEELS AND CAPS.....	23
7.4 PACKAGING.....	23
APPENDICES	
A MEANS FOR DEMONSTRATING COMPLIANCE WITH THIS STANDARD	24
B PURCHASING GUIDELINES.....	28
C REFERENCED DOCUMENTS.....	31
D ALTERNATIVE MATERIAL REQUIREMENTS.....	33
E GUIDELINES FOR GEARBOX SELECTION AND APPLICATION.....	34

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-