

AS/NZS IEC 60947.7.1:2015
IEC 60947-7-1, Ed. 3.0 (2009)

AS/NZS IEC 60947.7.1:2015

Australian/New Zealand Standard™

Low-voltage switchgear and controlgear

**Part 7.1: Ancillary equipment—Terminal
blocks for copper conductors**



AS/NZS IEC 60947.7.1:2015

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-006, Industrial Switchgear and Controlgear. It was approved on behalf of the Council of Standards Australia on 27 May 2015 and on behalf of the Council of Standards New Zealand on 29 May 2015. This Standard was published on 29 June 2015.

The following are represented on Committee EL-006:

Association of Accredited Certification Bodies
Ausgrid
Australian Chamber of Commerce and Industry
Australian Industry Group
Bureau of Steel Manufacturers of Australia
Business New Zealand
Electrical Contractors Association of New Zealand
Engineers Australia
National Electrical and Communications Association
National Electrical Switchboard Manufacturers Association
Rail Industry Safety and Standards Board (RISSB)

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR AS/NZS IEC 60947.7.1:2015.

AS/NZS IEC 60947.7.1:2015

Australian/New Zealand Standard™

Low-voltage switchgear and controlgear

Part 7.1: Ancillary equipment—Terminal blocks for copper conductors

Originated as AS 3947.7.1—1996.
Revised and redesignated as AS/NZS IEC 60947.7.1:2015.

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140.

ISBN 978 1 76035 083 3

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-006, Industrial Switchgear and Controlgear, to supersede AS 60947.7.1—2004.

The objective of this Standard is to specify requirements for terminal blocks with screw-type or screwless-type clamping units primarily intended for industrial or similar use and to be fixed to a support to provide electrical and mechanical connection between copper conductors. It applies to terminal blocks intended to connect round copper conductors, with or without special preparation, having a cross-section between 0.2 mm² and 300 mm² (AWG 24/600 kcmil), intended to be used in circuits of a rated voltage not exceeding 1,000 V a.c. up to 1,000 Hz or 1,500 V d.c.

This Standard is identical with, and has been reproduced from, IEC 60947-7-1, Ed. 3.0 (2009), *Low-voltage switchgear and controlgear, Part 7.1: Ancillary equipment—Terminal blocks for copper conductors*.

This Standard shall be read in conjunction with IEC 60947-1. The provisions of the general rules dealt with in IEC 60947-1 are applicable to this Standard, where specifically called for. Clauses and subclauses, tables, figures and annexes thus applicable are identified by reference to IEC 60947-1, e.g. 1.2 of IEC 60947-1, Table 4 of IEC 60947-1 or Annex A of IEC 60947-1.

As this Standard is reproduced from an International Standard, the following applies:

- (a) In the source text ‘this part of IEC 60947’ should read ‘this Australian/New Zealand Standard’.
- (b) A full point substitutes for a comma when referring to a decimal marker.

References to International Standards should be replaced by references to Australian or Australian/New Zealand Standards, as follows:

<i>Reference to International Standard</i>		<i>Australian/New Zealand Standard</i>	
IEC		AS/NZS	
60695	Fire hazard testing	60695	Fire hazard testing
60695-11-5	Part 11-5: Test flames— Needle-flame test method— Apparatus, confirmatory test arrangement and guidance	60695.11.10	Part 11.5: Test flames— Needle-flame test method— Apparatus, confirmatory test arrangement and guidance

Only normative references that have been adopted as Australian or Australian/New Zealand Standards have been listed.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the annexes to which they apply. A ‘normative’ annex is an integral part of a Standard, whereas an ‘informative’ annex is only for information and guidance.

CONTENTS

1	General	6
1.1	Scope.....	6
1.2	Normative references	6
2	Definitions	7
3	Classification.....	7
4	Characteristics	7
4.1	Summary of characteristics	7
4.2	Type of terminal block	7
4.3	Rated and limiting values	8
4.3.1	Rated voltages	8
4.3.2	Short-time withstand current.....	8
4.3.3	Standard cross-sections	8
4.3.4	Rated cross-section.....	8
4.3.5	Rated connecting capacity.....	9
5	Product information	9
5.1	Marking.....	9
5.2	Additional information.....	9
6	Normal service, mounting and transport conditions.....	10
7	Constructional and performance requirements.....	10
7.1	Constructional requirements.....	10
7.1.1	Clamping units.....	10
7.1.2	Mounting	10
7.1.3	Clearances and creepage distances	10
7.1.4	Terminal identification and marking	10
7.1.5	Resistance to abnormal heat and fire.....	11
7.1.6	Rated cross-section and rated connecting capacity	11
7.2	Performance requirements	11
7.2.1	Temperature-rise	11
7.2.2	Dielectric properties.....	11
7.2.3	Short-time withstand current.....	11
7.2.4	Voltage drop.....	12
7.2.5	Electrical performance after ageing (for screwless-type terminal blocks only)	12
7.3	Electromagnetic compatibility (EMC)	12
8	Tests.....	12
8.1	Kinds of test	12
8.2	General	12
8.3	Verification of mechanical characteristics	13
8.3.1	General	13
8.3.2	Attachment of the terminal block on its support.....	13
8.3.3	Mechanical properties of clamping units	14
8.4	Verification of electrical characteristics.....	15
8.4.1	General	15
8.4.2	Verification of clearances and creepage distances	16
8.4.3	Dielectric tests.....	16

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-