AS 2200-1978

Australian Standard®

Design charts for water supply and sewerage

The following scientific, industrial and governmental organizations and departments were officially represented on the committee entrusted with the preparation of this standard:

City Councils Commission of Public Health, Victoria Confederation of Australian Industry Consulting Engineers Department of Construction Department of Local Government, Qld Department of Public Works, N.S.W. Institute of Plumbing Australia Institution of Engineers, Australia Master Plumbers and Sanitary Engineers Association Royal Australian Institute of Architects SAA Plastics Standards Board University of New South Wales Victorian Railways Water Supply, Sewerage and Drainage Authorities

This standard, prepared by the Water Supply Sewerage and Drainage Standards Board, was approved on behalf of the Council of the Standards Association of Australia on 14 July 1978, and was published on 1 September 1978.

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

AS 2200-1978

Australian Standard®

Design charts for water supply and sewerage

First published	1978
Reprinted	1982

PUBLISHED BY STANDARDS AUSTRALIA (STANDARDS ASSOCIATION OF AUSTRALIA) 1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 1535 X

PREFACE

This standard was prepared by the Water Supply Sewerage and Drainage Standards Board following discussion between representatives of the Metric Conversion Board and of the Standards Association of Australia.

The Department of Construction gathered, coordinated and edited material submitted by major water supply and sewerage authorities in Australia and prepared all committee drafts leading up to publication of this standard.

The Association acknowledges with gratitude the work done by the Department of Construction and by the many Australian authorities which provided material for consideration and inclusion in this standard.

CONTENTS

		Page
FOREWORD		3
CHARTS FO	or Hydraulic Design of Pipes	
Chart Chart	1 — Colebrook-White Formula $k = 0.003 \text{ mm}$	4
Chart	$3 - \text{Colebrook-White Formula} = 0.000 \text{ mm}$ $\dots \dots \dots$	6
Chart Chart	4 — Colebrook-White Formula— $k = 0.03$ mm	7 8
Chart	6 — Colebrook-White Formula— $k = 0.15$ mm	9
Chart	7 — Colebrook-White Formula— $k = 0.30 \text{ mm}$	10
Chart	8 — Colebrook-White Formula— $k = 0.60 \text{ mm}$	11
Chart	9 — Colebrook-White Formula $-k = 1.50$ mm	12
Chart	10 - Colebrook-White Formula = 6.00 mm	15
Chart	11 = Corebrook-white Formula = 0.00 mm = 100 mm to 100 mm	15
Chart	13 — Hazen and Williams Formula— $C = 120$; $D = 10$ mm to 100 mm	16
Chart	14 — Hazen and Williams Formula— $C = 140$; $D = 10$ mm to 100 mm	17
Chart	15 — Hazen and Williams Formula— $C = 50$ to 160; $D = 50$ mm to 500 mm	18
Chart	16 — Hazen and Williams Formula— $C = 50$ to 160; $D = 300$ mm to 2500 mm	19
Chart	17 — Manning Formula— $D = 60 \text{ mm}$ to 2000 mm	20
Chart Chart	 18 — Proportional Velocity and Discharge in Part-full Circular Sections 19 — Guide to Resistance Coefficients of Valves and Fittings 	21 22
TABLE 1.	Guide to Roughness Coefficients for Pipes Concentrically Jointed and Clean \ldots	23
APPENDICE	S	

А	Examples—Colebrook-White Charts	23
В	Resistance Coefficient Chart	24

© Copyright - STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

STANDARDS ASSOCIATION OF AUSTRALIA

Australian Standard DESIGN CHARTS FOR WATER SUPPLY AND SEWERAGE

FOREWORD

The pipe-flow charts in this standard are based on the Manning formula, the Hazen and Williams formula, or the Colebrook-White formula. These three formulas were chosen as they represent those most commonly used for pipeline design in Australia. Designers will need to make their own choice as to which formula they wish to adopt.

The three formulas are as follows:

(a) Manning:

$$V = \frac{1}{n} R^{0.67} S^{0.5}$$

- (b) *Hazen and Williams:* $V = 0.849 C R^{0.63} S^{0.54}$
- (c) *Colebrook-White:*

$$V = -\sqrt{32gRS \log \left[\frac{k}{14.8R} + \frac{1.255v}{R\sqrt{32gRS}}\right]}$$

where

- n = Manning roughness coefficient
- C = Hazen and Williams roughness coefficient
- k =Colebrook-White roughness coefficient, in metres
- V = velocity
- R = hydraulic radius, in metres
- S = slope, in metres per metre
- g = gravitational acceleration, in metres per second squared
- v = kinematic viscosity of water, in square metres per second.

It is intended that the charts will give designers a reasonably accurate basis for design of pipe systems. However, it must be realized that the formulas on which they are based may have limitations on the range of velocities, diameters and roughness coefficients to be used. They may be inaccurate where the parameters used are outside the conditions upon which the formulas were originally based. A guide to roughness coefficients for various pipe materials is given in Table 1.

Some hydraulic text books report that the Hazen and Williams formula may not be entirely suitable for diameters less than 50 mm or velocities greater than 3 m/s. It is also stated that the formula is not entirely accurate for values of C substantially less than 100.

The Manning formula applies to about the same flow range as the Hazen and Williams formula. It may be more useful than the Hazen and Williams formula in cases where the value of C is well below 100. However, its use is now diminishing in favour of the more reliable Hazen and Williams and Colebrook-White formulas.

The most recent formula to be devised is that by Colebrook-White which has only lately been presented in graphical form. It is regarded by many hydraulicians throughout the world as the most accurate basis for hydraulic design. It has had ample experimentation confirmation over wide conditions of flow.

The Colebrook-White charts have been drawn for a water temperature of 20°C. Although the temperature of water and sewage varies between seasons and also between localities, 20°C is considered to be a suitable mean value for Australian conditions. A temperature correction table has not been included because the increase or decrease in discharge due to temperature variations is small. In fact an increase or decrease in temperature of 10°C will vary the discharge by only about 3 percent.

Diameters given on the various charts represent internal diameters of pipes. Designers should therefore ensure that, when using the charts, actual internal diameters are applied, and not the 'nominal size' from the various Australian standards for pipes.

Examples in the use of the Colebrook-White formula charts are given in Appendix A, and an example in the use of Chart 19, Guide to Resistance Coefficients of Valves and Fittings for Fluid Flows, is given in Appendix B. For some other charts, an example is given below the chart.



This is a free preview. Purchase the entire publication at the link below:

Product Page

S Looking for additional Standards? Visit Intertek Inform Infostore

> Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation