

Australian/New Zealand Standard™

Electric cables—Polymeric insulated

Part 1: For working voltages up to and including 0.6/1 (1.2) kV

AS/NZS 5000.1:2003

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-003, Electric Wires and Cables. It was approved on behalf of the Council of Standards Australia on 19 September 2003 and on behalf of the Council of Standards New Zealand on 30 September 2003. It was published on 28 November 2003.

The following are represented on Committee EL-003:

Australasian Railway Association
Australian Electrical and Electronic Manufacturers Association
Australian Industry Group
Canterbury Manufacturers Association, New Zealand
Department of Defence (Australia)
Department of Mineral Resources N.S.W.
Electrical Contractors Association of New Zealand
Electrical Regulatory Authorities Council
Electricity Supply Association of Australia
Institution of Engineers Australia
Ministry of Economic Development (New Zealand)
National Electrical and Communications Association

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Australia web site at www.standards.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia International or Standards New Zealand at the address shown on the back cover.

Australian/New Zealand Standard™

Electric cables—Polymeric insulated

Part 1: For working voltages up to and including 0.6/1 (1.2) kV

Originated in Australia as part of AS C50—1928 and AS C178—1966.
Originated in New Zealand as NZS/AS 3198—1990.
Previous editions AS 3178—1991 and AS/NZS 5000.1:1999.
AS 3178—1991 and AS/NZS 5000.1:1999 jointly revised, amalgamated and redesignated AS/NZS 5000.1:2003.

COPYRIGHT

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 5571 2

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-003, Electric Wires and Cables to supersede AS/NZS 5000.1:1999 and AS 3178—1991, *Approval and test specification—Electric cables—Silicone rubber insulated— For working voltages up to and including 0.6/1 kV*.

The objective of this Standard is to provide manufacturers and suppliers with construction details, dimensions and tests for cables and flexible cables insulated with thermoplastic, elastomer or XLPE materials intended for use in electrical installations at working voltages up to and including 0.6/1 (1.2) kV.

This Standard differs from the 1999 edition as follows:

- (a) X-90UV and R-S-150 have been included in the list of insulation materials.
- (b) TPE-75 and TP-90 have been deleted from the list of insulation materials.
- (c) Only PVC materials have been specified for insulation of aerial cables or fixed cables used in outdoor applications.
- (d) Bedding, separation layer, armour, metallic sheath, non-metallic braid and further protection have been designated as optional processes.
- (e) The Clause covering bedding requirements has been rewritten to improve clarity.
- (f) A mandatory non-metallic sheath has been specified for cables with polyolefin insulation.
- (g) Polyolefin materials have been deleted from the list of non-metallic sheath materials.
- (h) The specification for reduced thickness sheaths over armour has been deleted.
- (i) A specification has been provided for the thickness of non-metallic sheath where the sheath consists of two layers of material.
- (j) An optional non-metallic braid has been included.
- (k) The type of cables or cable components on which the spark test and high voltage test for five minutes is carried out, has been amended.

In the preparation of this Standard, consideration was given to IEC 60502-1, *Power cables with extruded insulation and their accessories for rated voltages from 1 kV ($U_m = 1,2$ kV) up to 30 kV ($U_m = 36$ kV)*, Part 1: *Cables for rated voltages of 1 kV ($U_m = 1,2$ kV) and 3 kV ($U_m = 3,6$ kV)* and acknowledgment is made of the assistance received from that source.

The nominal cross-sectional areas of the conductors specified in this Standard are based on the values recommended in IEC 60228, *Conductors of insulated cables*.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the appendix to which they apply. A 'normative' appendix is an integral part of a Standard, whereas an 'informative' appendix is only for information and guidance.

Statements expressed in mandatory terms in notes to tables are deemed to be requirements of this Standard.

CONTENTS

	<i>Page</i>
1 SCOPE.....	4
2 REFERENCED DOCUMENTS.....	4
3 DEFINITIONS.....	5
4 VOLTAGE DESIGNATION	6
5 CONDUCTORS.....	6
6 INSULATION.....	7
7 ASSEMBLY OF CORES.....	9
8 BEDDING (OPTIONAL).....	10
9 METALLIC LAYERS (OPTIONAL)	11
10 SEPARATION LAYER (OPTIONAL).....	11
11 ARMOUR (OPTIONAL).....	12
12 METALLIC SHEATH (OPTIONAL).....	13
13 NON-METALLIC SHEATH (OPTIONAL).....	13
14 NON-METALLIC BRAID (OPTIONAL).....	15
15 FURTHER PROTECTION (OPTIONAL)	16
16 MARKING.....	16
17 TESTS.....	17
APPENDICES	
A PURCHASING GUIDELINES.....	20
B THE FICTITIOUS CALCULATION METHOD FOR THE DETERMINATION OF THE DIMENSIONS OF PROTECTIVE COVERINGS.....	21

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-