

Technical Report

Electromagnetic compatibility (EMC)

Part 1.4: General—Historical rationale for the limitation of power-frequency conducted harmonic current emissions from equipment, in the frequency range up to 2 kHz



TR IEC 61000.1.4:2012

This Joint Australian/New Zealand Technical Report was prepared by Joint Technical Committee EL-034, Power Quality. It was approved on behalf of the Council of Standards Australia on 7 December 2011 and on behalf of the Council of Standards New Zealand on 20 December 2011.

This Technical Report was published on 31 January 2012.

The following are represented on Committee EL-034:

Australian Chamber of Commerce and Industry
Australian Industry Group
Australian Information Industry Association
Bureau of Steel Manufacturers of Australia
Consumer Electronics Suppliers Association
Consumers Federation of Australia
Electrical Regulatory Authorities Council
Electricity Engineers Association (New Zealand)
Energy Networks Association
Engineers Australia
Lighting Council of Australia
Ministry of Economic Development (New Zealand)
National Measurement Institute
New Zealand Coordinating Committee on Power & Telecommunication Systems
New Zealand Electric Fence Energiser Manufacturers Standards WG
Telstra Corporation
University of Canterbury New Zealand
University of Wollongong

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

Technical Report

Electromagnetic compatibility (EMC)

Part 1.4: General—Historical rationale for the limitation of power-frequency conducted harmonic current emissions from equipment, in the frequency range up to 2 kHz

First published as TR IEC 61000.1.4:2012.

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140

ISBN 978 1 74342 016 4

PREFACE

This Technical Report was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-034, Power Quality.

The objective of this Technical Report is to provide the users of electromagnetic emissions Standards with a rationale for the limitation of power-frequency conducted harmonic current emissions from equipment for frequencies up to 2 kHz on the public electricity supply, in the editions up to and including the second edition of AS/NZS 61000.3.2:2003*, and in the first edition of AS/NZS 61000.3.12:2006.

This Technical Report is identical with, and has been reproduced from IEC/TR 61000-1-4, Ed.1.0 (2005). The IEC processes related to development and approval of a Technical Report are subject to a more moderate level of transparency and consensus than the processes related to developing and approving a normative Standard.

As this Technical Report is reproduced from an International Technical Report, the following applies:

- (a) Its number appears on the cover and title page while the International Technical Report number appears only on the cover.
- (b) A full point substitutes for a comma when referring to a decimal marker.

References to International Standards should be replaced by references to Australian or Australian/New Zealand Standards, as follows:

<i>Reference to International Standard</i>		<i>Australian/New Zealand Standard</i>	
IEC		AS/NZS	
61000	Electromagnetic compatibility (EMC)	61000	Electromagnetic compatibility (EMC)
61000-2-2	Part 2-2: Environment—Compatibility levels for low-frequency conducted disturbances and signalling in public low-voltage power supply systems	61000.2.2	Part 2.2: Environment—Compatibility levels for low-frequency conducted disturbances and signalling in public low-voltage power supply systems
61000-3-2	Part 3-2: Limits—Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)	61000.3.2	Part 3.2: Limits—Limits for harmonic current emissions (equipment input current less than or equal to 16 A per phase) (IEC 61000-3-2 Ed.3.0 (2005) MOD)
61000-3-3	Part 3-3: Limits—Limitation of voltage fluctuations and flicker in public low-voltage supply systems for equipment with rated current ≤ 16 A per phase	61000.3.3	Part 3.3: Limits—Limitation of voltage fluctuations and flicker in public low-voltage supply systems for equipment with rated current ≤ 16 A per phase (IEC 61000-3-3, Ed.1.2 (2005) MOD)

* AS/NZS 61000.3.2:2003 has been superseded by AS/NZS 61000.3.2:2007, which is a modified adoption of IEC 61000-3-2:2005 (Ed.3.0).

3

IEC		AS/NZS	
61000-3-4	Part 3-4: Limits—Limitation of emission of harmonic currents in low-voltage power supply systems for equipment with rated current greater than 16 A	61000.3.4	Part 3.4: Limits—Limitation of emission of harmonic currents in low-voltage power supply systems for equipment with rated current greater than 75 A
61000-3-6	Part 3-6: Limits—Section 6: Assessment of emission limits for distorting loads in MV and HV power systems	61000.3.6	Part 3.6: Limits—Assessment of emission limits for distorting loads in MV and HV power systems
61000-3-11	Part 3-11: Limits—Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems—Equipment with rated current ≤ 75 A and subject to conditional connection	61000.3.11	Limits—Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply system—Equipment with rated current ≤ 75 A and subject to conditional connection
61000-3-12	Part 3-12: Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current > 16 A and ≤ 75 A per phase	61000.3.12	Limits—Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current > 16 A and ≤ 75 A per phase
61000-4-13	Part 4-13: Testing and measurement techniques—Harmonics and interharmonics including mains signalling at a.c. power port, low frequency immunity tests	61000.4.13	Part 4.13: Testing and measurement techniques—Harmonics and interharmonics including mains signalling at a.c. power port, low frequency immunity tests

The term ‘informative’ has been used in this Technical Report to define the application of the annex to which it applies. An ‘informative’ annex is only for information and guidance.

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-