

Australian/New Zealand Standard™

**PVC-U pipes and fittings for drain, waste
and vent application**

AS/NZS 1260:2002

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee PL-021, PVC, ABS and Polyamide Pipe Systems. It was approved on behalf of the Council of Standards Australia on 25 June 2002 and on behalf of the Council of Standards New Zealand on 20 June 2002. It was published on 1 August 2002.

The following are represented on Committee PL-021:

Australian Gas Association
Australian Nuclear Science and Technology Organisation
CSIRO Building, Construction and Engineering
Certification Bodies (Australia)
Institution of Engineers Australia
Local Government New Zealand
Master Plumbers Australia
Master Plumbers, Gasfitters and Drainlayers New Zealand
New Zealand Water and Waste Association
PVC Pipelines Industry Association of Australasia Limited
Plastics Institute of New Zealand
Plastics and Chemicals Industries Association Incorporated
Water Services Association of Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Australia web site at www.standards.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia International or Standards New Zealand at the address shown on the back cover.

AS/NZS 1260:2002

Australian/New Zealand Standard™

PVC-U pipes and fittings for drain, waste and vent application

Originated in Australia as part of AS K138—1963 and AS A160—1969.
Originated in New Zealand in part as NZS 7641:1978, NZS 7642:1971 and NZS 7649:1988.
Previous edition AS/NZS 1260:1999.
Third edition 2002.

COPYRIGHT

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 4700 0

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee PL-021, PVC, ABS and Polyamide Pipe Systems, to supersede AS/NZS 1260:1999.

This Standard covers PVC-U pipes and fittings for sewerage applications, for soil, waste and vent applications and drain applications in both Australia and New Zealand.

The objective of this Standard is to outline minimum requirements for the manufacture and performance of PVC-U pipes and fittings for non-pressure drain, waste and vent (DWV) applications for use by manufacturers, specifiers and purchasers of such products.

The test criteria specified apply to pipes and fittings at the time of manufacture and should not be used to assess the results from tests on pipes or fittings that have been in service.

For pipes of nominal diameter up to and including 80 mm, the pipes are specified solely in terms of the materials used and dimensions. There is no pipe stiffness requirement regardless of pipe type, as the stiffness of pipes in this size range is considerably higher than the minimum values used for larger pipes. By continuing to specify in terms of dimensions, the Standard ensures that existing installation practices, for example the spacing between supports on near horizontal runs, can continue to be used. Most pipes installed above ground are in this size range.

Pipes of nominal size of 100 mm and above are specified in terms of minimum stiffness. Sufficient dimensional information is provided to ensure compatible joints and resistance to abrasion.

Pipes are specified in terms of stiffness classes measured in a standard test. The classes are not exactly the same as the earlier classification scheme (Class SH and Class SEH) but are similar.

Class SN4 and Class SN6 are considered to be suitable for plumbing and domestic use.

Class SN8 and Class SN10 are suitable for general municipal drainage, deeper burial and similar applications where higher pipe stiffness is required to minimize deflection of the installed pipes due to the load imposed by the back fill or surcharge or to poor installation practice.

Stiffness class, SN16, has been included in response to a request from New Zealand users who previously specified Class SEH-C for applications where heavy loads, for example traffic loads, acted on buried pipes. Australian Standards for sewer and drainage pipes have not included a pipe of similar stiffness in the past and Australian manufacturers may not have DWV pipes of this class generally available.

This revision provides for injection moulded-fittings of diameters greater than DN150 with parallel solvent-welded sockets. These fittings are predominantly imported fittings and have no specific requirements for colour or titanium dioxide to provide UV protection. Additional marking requirements have been specified for these fittings to highlight the parallel sockets, the need for gap-filling solvent cements and UV protection when used outdoors.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the appendix to which they apply. A 'normative' appendix is an integral part of a Standard, whereas an 'informative' appendix is only for information and guidance.

Statements expressed in mandatory terms in notes to tables are deemed to be requirements of this Standard.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE.....	5
1.2 REFERENCED DOCUMENTS.....	5
1.3 DEFINITIONS.....	6
1.4 RING BENDING STIFFNESS	7
1.5 NOTATION.....	8
1.6 CLASSIFICATION	8
SECTION 2 GENERAL REQUIREMENTS	
2.1 GENERAL.....	10
2.2 COMPOSITION	10
2.3 COLOUR.....	10
2.4 FREEDOM FROM DEFECTS	10
2.5 REQUIREMENTS FOR ELASTOMERIC SEALS	11
2.6 SOLVENT CEMENTS.....	11
2.7 PACKAGING, STORAGE AND TRANSPORTATION	11
SECTION 3 PERFORMANCE REQUIREMENTS	
3.1 GENERAL.....	12
3.2 TESTS ON PIPES.....	12
3.3 TESTS ON MOULDED AND FABRICATED FITTINGS	13
3.4 TESTS ON ELASTOMERIC SEAL JOINTS	14
3.5 ADDITIONAL TESTS ON PIPE AND FITTINGS CONTAINING RECYCLED PVC-U	14
SECTION 4 PIPES	
4.1 GENERAL.....	15
4.2 DIAMETER AND WALL THICKNESS	15
4.3 LENGTH	15
4.4 PIPE SPIGOT ENDS	15
4.5 SOCKETS FORMED ON PIPE ENDS.....	15
4.6 MARKING	19
4.7 WITNESS MARK	20
SECTION 5 MOULDED FITTINGS	
5.1 GENERAL.....	21
5.2 DIMENSIONS OF MOULDED FITTINGS	21
5.3 WALL THICKNESS	23
5.4 GEOMETRY OF FITTINGS	24
5.5 THREADED END CONNECTIONS.....	26
5.6 TEST OPENINGS	26
5.7 INSPECTION OPENINGS.....	27
5.8 GRATINGS	29
5.9 BOLTED TRAP SCREWS	29
5.10 OVERFLOW RELIEF GRATINGS	29
5.11 MARKING	30

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-