

AS/NZS 1429.2:1998

Australian/New Zealand Standard[®]

**Electric cables—Polymeric
insulated**

**Part 2: For working voltages above
19/33 (36) kV up to and including
76/132 (145) kV**

AS/NZS 1429.2:1998

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL/3, Electric Wires and Cables. It was approved on behalf of the Council of Standards Australia on 17 November 1997 and on behalf of the Council of Standards New Zealand on 17 November 1997. It was published on 5 February 1998.

The following interests are represented on Committee EL/3:

Australasian Railways Association
Australian Electrical and Electronic Manufacturers Association
Department of Defence, Australia
Electrical regulatory authorities
Electricity Supply Association of Australia
Institution of Engineers, Australia
Ministry of Commerce, New Zealand
New Zealand Electrical Contractors Association
New Zealand Electrical and Electronic Manufacturers Federation
Office of Energy, N.S.W.
Testing interests

Review of Standards. To keep abreast of progress in industry, Joint Australian/New Zealand Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Joint Standards and related publications will be found in the Standards Australia and Standards New Zealand Catalogue of Publications; this information is supplemented each month by the magazines 'The Australian Standard' and 'Standards New Zealand', which subscribing members receive, and which give details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Joint Standards, addressed to the head office of either Standards Australia or Standards New Zealand, are welcomed. Notification of any inaccuracy or ambiguity found in a Joint Australian/New Zealand Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

AS/NZS 1429.2:1998

Australian/New Zealand Standard[®]

**Electric cables—Polymeric
insulated**

**Part 2: For working voltages above
19/33 (36) kV up to and including
76/132 (145) kV**

First published as AS/NZS 1429.2:1998.

PUBLISHED JOINTLY BY:

STANDARDS AUSTRALIA
1 The Crescent,
Homebush NSW 2140 Australia

STANDARDS NEW ZEALAND
Level 10, Radio New Zealand House,
155 The Terrace,
Wellington 6001 New Zealand

ISBN 0 7337 1722 5

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL/3, Electric Wires and Cables, to complement AS 1429.1—1993, *Electric cables—Polymeric insulated, Part 1: For working voltages 1.9/3.3(3.6) kV up to and including 19/33(36) kV*.

The objective of this Standard is to specify requirements for single-core cross-linked polyethylene insulated cables for fixed installations operating at voltages above 19/33(36) kV up to and including 76/132(145) kV.

In the preparation of this Standard, consideration was given to the following publications and acknowledgment is made of the assistance received:

IEC

- 229 Tests on cable oversheaths which have a special protective function and are applied by extrusion
- 502 Extruded solid dielectric insulated power cables for rated voltages from 1 kV up to 30 kV
- 840 Tests for power cables with extruded insulation for rated voltages above 30 kV ($U_m = 36$ kV) up to 150 kV ($U_m = 170$ kV)
- 811 Common test methods for insulating and sheathing materials of electric cables (all parts)

AEIC

- CS7 Specifications for crosslinked polyethylene insulated shielded power cables rated 69 through 138 kV

The nominal cross-sectional areas of the conductors specified herein are identical with the values specified in AS 1125, *Conductors in insulated electric cables and flexible cords*. Additional conductor sizes referenced are specified in IEC 228, *Conductors of insulated cables*. The dimensions for non-metallic sheath thicknesses are based on the values recommended in IEC 502. Certain tests and criteria in this Standard are more stringent than those in IEC 840.

One type of insulation compound is specified in this Standard, namely insulation comprising cross-linked polyethylene (XLPE).

Although the Standard provides tables of insulation thicknesses and the necessary information to establish precisely the dimensions of the cable protective coverings, no cable dimension tables are provided owing to the variety of cable constructions that could affect such dimensions.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the appendix to which they apply. A 'normative' appendix is an integral part of a Standard, whereas an 'informative' appendix is only for information and guidance.

Statements expressed in mandatory terms in notes to tables and figures are deemed to be requirements of this Standard.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	5
1.2 REFERENCED DOCUMENTS	5
1.3 DEFINITIONS	5
SECTION 2 CONSTRUCTION	
2.1 GENERAL	7
2.2 OPERATING VOLTAGES	8
2.3 MAXIMUM CONDUCTOR TEMPERATURE	8
2.4 CONDUCTORS	8
2.5 CONDUCTOR SCREEN	8
2.6 INSULATION	9
2.7 EXTRUDED INSULATION SCREEN	9
2.8 WATER BLOCKING	10
2.9 MOISTURE BARRIER	10
2.10 METAL SHEATH	10
2.11 METALLIC SCREEN	10
2.12 BINDERS AND BARRIER TAPES	11
2.13 NON-METALLIC SHEATH	11
2.14 PROTECTION FROM INSECT ATTACK (OPTIONAL)	12
2.15 CABLE IDENTIFICATION	12
2.16 METRE MARKING ON CABLE (OPTIONAL)	12
2.17 PREPARATION FOR DELIVERY	12
2.18 MARKING OF DRUMS	12
SECTION 3 TESTS	
3.1 GENERAL	13
3.2 CHECK ON INSULATION THICKNESS OF CABLE FOR ELECTRICAL TYPE TESTS	13
3.3 SELECTION OF SAMPLES	13
3.4 CABLE CHARACTERISTICS	13
3.5 PARTIAL DISCHARGE TEST	18
3.6 HIGH VOLTAGE TEST FOR 30 MIN	18
3.7 PARTIAL DISCHARGE TEST AFTER BENDING	18
3.8 MEASUREMENT OF DDF ($\tan \delta$) AT AMBIENT TEMPERATURE	19
3.9 MEASUREMENT OF DDF ($\tan \delta$) AT OPERATING TEMPERATURE	19
3.10 PARTIAL DISCHARGE TEST AFTER HEAT CYCLING	19
3.11 IMPULSE TEST FOLLOWED BY A HIGH VOLTAGE TEST	19
3.12 RE-QUALIFICATION TESTS	20

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-