

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Amendment No. 1
to
AS/NZS 2638.1:2011
Gate valves for waterworks purposes
Part 1: Metal seated

REVISED TEXT

The 2011 edition of AS/NZS 2638.1 is amended as follows; the amendments should be inserted in the appropriate places.

SUMMARY: This Amendment applies to the Preface, Clauses 1.2, 1.3, 1.4.3, 1.4.13, 1.4.22, 1.4.25, 1.4.28, 1.4.29, 1.4.30 (new), 1.4.31 (new), 1.4.32 (new), 1.6, 2.1, 2.2, 2.4, 3.7.3, 3.7.4, 3.7.5, 4.1 and 4.2, Table 2.1 and Appendices A, B and C.

Published on 17 August 2017.

Approved for publication in New Zealand by the New Zealand Standards Approval Board on 5 July 2017.

AMDT
No. 1
AUG
2017

Preface

Second paragraph, *delete* both instances of the word ‘Class’ and *replace* with ‘PN’.

AMDT
No. 1
AUG
2017

Clause 1.2

Delete text and *replace* with the following:

Means for demonstrating conformity with this Standard shall be in accordance with Appendix A.

AMDT
No. 1
AUG
2017

Clause 1.3

1 *Delete* entry ‘AS 4087 Metallic flanges for waterworks purposes’.

2 *Add* the following new entry after AS/NZS 4020:

4087 Metallic flanges for water works purposes

3 *Add* the following new entry after AS/NZS 4158:

AS ISO/IEC

17025 General requirements for the competence of testing and calibration laboratories

4 *Add* the following new entry after ASTM A276-10:

A743 Standard Specification for Castings, Iron-Chromium, Iron-Chromium-Nickel, Corrosion Resistant, for General Application

AMDT
No. 1
AUG
2017

Clause 1.4.3

Delete title and definition.

AMDT
No. 1
AUG
2017

Clause 1.4.13

Delete title and definition.

AMDT
No. 1
AUG
2017

Clause 1.4.22

Delete text and *replace* with the following:

Schedule of products of the same type, nominal diameter and wall thickness with identical dimensional characteristics manufactured from the same material. The production batch is defined by the manufacturer.

AMDT
No. 1
AUG
2017

Clause 1.4.25

Delete title and definition, including Note.

AMDT
No. 1
AUG
2017

Clause 1.4.28

Delete title and definition.

AMDT
No. 1
AUG
2017

Clause 1.4.29

Delete title and definition.

AMDT
No. 1
AUG
2017

Clause 1.4.30 (new)

After Clause 1.4.29, *add* the following new definition:

1.4.30 Production test

A test performed by the manufacturer on a batch of components, which has to be satisfactorily completed before the batch can be released.

AMDT
No. 1
AUG
2017

Clause 1.4.31 (new)

Add the following new definition:

1.4.31 Seal retainer housing

Component that houses the spindle seal retainer to ensure it is accurately fixed in position.

AMDT
No. 1
AUG
2017

Clause 1.4.32 (new)

Add the following new definition:

1.4.32 Spindle seal retainer

Component that is in direct contact with the spindle seals to ensure they are retained.

AMDT
No. 1
AUG
2017

Clause 1.6

Delete text ‘postion’ and *replace* with ‘position’.

AMDT
No. 1
AUG
2017

Clause 2.1

Delete text and *replace* with the following:

Table 2.1 lists the basic material requirements for the manufacture of valve components. Alternative materials are allowable, provided they are equivalent in performance and corrosion resistance. Acceptable alternative materials are listed in Appendix C.

NOTE: For further information on material equivalence, refer to the Water Services Association of Australia (WSAA).

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-