



NSAI
Standards

Irish Standard Recommendation
S.R. CEN/TR 16886:2016

Guidance on the application of statistical methods for determining the properties of masonry products

S.R. CEN/TR 16886:2016

Incorporating amendments/corrigenda/National Annexes issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard — national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation — recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

This document replaces/revises/consolidates the NSAI adoption of the document(s) indicated on the CEN/CENELEC cover/Foreword and the following National document(s):

NOTE: The date of any NSAI previous adoption may not match the date of its original CEN/CENELEC document.

This document is based on:

CEN/TR 16886:2016

Published:

2016-11-23

This document was published under the authority of the NSAI and comes into effect on:

2016-12-12

ICS number:

03.120.30

91.100.25

NOTE: If blank see CEN/CENELEC cover page

NSAI
1 Swift Square,
Northwood, Santry
Dublin 9

T +353 1 807 3800
F +353 1 807 3838
E standards@nsai.ie
W NSAI.ie

Sales:
T +353 1 857 6730
F +353 1 857 6729
W standards.ie

Údarás um Chaighdeáin Náisiúnta na hÉireann

National Foreword

S.R. CEN/TR 16886:2016 is the adopted Irish version of the European Document CEN/TR 16886:2016, Guidance on the application of statistical methods for determining the properties of masonry products

This document does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with this document does not of itself confer immunity from legal obligations.

In line with international standards practice the decimal point is shown as a comma (,) throughout this document.

This page is intentionally left blank

TECHNICAL REPORT

CEN/TR 16886

RAPPORT TECHNIQUE

TECHNISCHER BERICHT

November 2016

ICS 03.120.30; 91.100.25

English Version

Guidance on the application of statistical methods for determining the properties of masonry products

Guide pour l'application de méthodes statistiques pour
la détermination des propriétés des éléments de
maçonnerie

Leitfaden für die Anwendung statistischer Methoden
zur Bestimmung der Eigenschaften von Mauerwerk
Produkten

This Technical Report was approved by CEN on 24 August 2015. It has been drawn up by the Technical Committee CEN/TC 125.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents	Page
European Foreword	3
Introduction	4
1 Scope	5
2 Normative references	5
3 Terms, definitions and symbols	5
3.1 Terms and definitions	5
3.2 Symbols	8
4 General	9
5 Statistical evaluation	10
5.1 Factory production control	10
5.2 Finished product testing	10
5.2.1 General	10
5.2.2 Inspection lot	11
5.2.3 Spot sampling and sample sizes	11
5.2.4 Production types	12
5.2.5 Control method A: Batch control	12
5.2.6 Control method B: 'Rolling' inspection	13
5.2.7 Evaluation of test results	15
5.2.8 How to come from unknown to known standard deviation?	18
5.2.9 Conformity	18
5.2.10 Simple and conservative approach	19
5.2.11 Non-conforming products	19
5.2.12 Guidance	19
6 Product type determination	22
Annex A (informative) Normal distribution (Laplace-Gauss distribution)	23
Annex B (informative) Tables for acceptance coefficient k_n depending on the used fractile p and confidence level γ (taken from ISO 16269-6:2005)	24
Annex C (informative) Examples of statistical evaluation	40
C.1 Example 1	40
C.2 Example 2	42
C.3 Example 3	43
C.4 Example 4	45
C.5 Example 5	47
Annex D (informative) Normality test of SHAPIRO – WILK	50
D.1 General	50
D.2 Normality test of SHAPIRO-WILK	50
Bibliography	54

European Foreword

This document (CEN/TR 16886:2016) has been prepared by Technical Committee CEN/TC 125 “Masonry”, the secretariat of which is held by BSI.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

CEN/TR 16886:2016 (E)

Introduction

This document is informative for the guidance of manufacturers and Notified Bodies (NBs), who want to use statistical methods for the evaluation of conformity and Factory Production Control of masonry products. Its use is optional. Other statistical methods and non-statistical methods may be used.

Quality control of building materials and components is an indispensable part of an overall concept of structural reliability. As quality control is generally a time-consuming and expensive task, various operational techniques and activities have been developed to fulfil safety requirements in buildings. Properly employed statistical methods are one way to provide efficient, economic and effective means of quality control.

Background: “The terms and definitions in EN 1990 (*Eurocode: Basis of structural design*) are derived from ISO 2394 (*General principles on reliability for structures*). For the design of structures, EN 1996-1-1 (*Eurocode 6: Design of masonry structures — Part 1-1: General rules for reinforced and unreinforced masonry structures*) is intended to be used together with EN 1990. ISO 12491 (*Statistical methods for quality control of building materials and components*) gives general principles for the application of statistical methods for the quality control of building materials and components, in compliance with the safety and serviceability requirements of ISO 2394. ISO 12491 is applicable to all buildings and other civil engineering works, existing or under construction, whatever nature or combination of materials used, e.g. concrete, steel, wood, bricks. The EN 771 series specifies that one method of satisfying the conformity criterion laid down in these product standards is to use the approach given in ISO 12491.”

This Technical Report gives guidance on how a statistical evaluation can be put into practice based on the background of ISO 12491.

A simplified method is also given based on information obtained from practice about the possible distribution in production for specific product characteristics.

The method may also be used for the evaluation of different properties at the different stages of the factory production control (FPC) with the aim to minimize testing costs for the manufacturer and to ensure that the requirements are fulfilled.

Detailed examples are given in Annex C. For other more sophisticated techniques and specific problems, other international standards can be applied.

The initial draft of this document was prepared by the joint working group CEN/TC 125/TG 5 and the Sector Group 10 of Notified Bodies under the Construction Products Directive. The CEN/TR is a tool available for manufacturers and Notified Bodies.

It is laid down in the hEN's of masonry products that the manufacturer should demonstrate compliance for his product with the requirements of the harmonized product standards.

The purpose of this Technical Report is to put statistical evaluation into practice. Detailed examples are given in the annexes.

1 Scope

In the masonry unit standards and in national legislation, some properties need to be declared based on a certain fractile and confidence level. To demonstrate compliance with that a statistical tool can be used.

The purpose of this Technical Report is to exemplify how a statistical tool can be used in practice. This document should not contradict nor extend the scope of the work and role of a Notified Body, nor impose additional burdens on the manufacturer, beyond those laid down in the Construction Products Regulation and the product standards.

Mechanical and other properties of building materials and components are in the report described by random variables with a certain type of probability distribution. The popular normal distribution (Laplace-Gauss distribution) is given in Annex A. Normal distribution may be used to approximate many actual symmetrical distributions. When a remarkable asymmetry is observed, then another type of distribution reflecting this asymmetry should be considered, leading to a more complex method to demonstrate compliance with the product standard. More information on the normality test of Shapiro-Wilk is given in Annex D.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1990, *Eurocode - Basis of structural design*

EN 1996 (all parts), *Eurocode 6 — Design of masonry structures*

3 Terms, definitions and symbols

For the purposes of this document, the following terms, definitions and symbols apply.

3.1 Terms and definitions

3.1.1

unit

defined quantity of building material, component or element that can be individually considered and separately tested

3.1.2

population

totality of units under consideration

3.1.3

variable

X

variable which can take any of the values of a specified set of values and with which is associated a probability distribution

3.1.4

probability distribution

function which gives the probability that a variable X takes any given value (in the case of a discrete variable) or belongs to a given set of values (in the case of a continuous variable)

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-