

Australian/New Zealand Standard™

Power transformers

Part 5: Ability to withstand short circuit (IEC 60076-5, Ed. 3.0 (2006) MOD)



AS/NZS 60076.5:2012

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-008, Power Transformers. It was approved on behalf of the Council of Standards Australia on 22 March 2012 and on behalf of the Council of Standards New Zealand on 29 March 2012.

This Standard was published on 16 April 2012.

The following are represented on Committee EL-008:

Australian Railway Association
Australian Chamber of Commerce and Industry
Australian Industry Group
Australian Greenhouse Office, Department of the Environmental and Heritage
Australian Institute of Petroleum
Department of Climate Change and Energy Efficiency
Electricity Engineers Association, New Zealand
Energy Efficiency and Conservation Authority of New Zealand
Energy Networks Association
EE-Oz Training Standards
Engineers Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR AS/NZS 60076.5.

Australian/New Zealand Standard™

Power transformers

Part 5: Ability to withstand short circuit (IEC 60076-5, Ed. 3.0 (2006) MOD)

Originated in Australia as AS C61—1931.
Previous edition AS 2375.5—1982.
Jointly revised and redesignated as AS/NZS 60076.5:2012.

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-008, Power Transformers to supersede AS 2374.5—1982, *Power transformers, Part 5: Ability to withstand short-circuit*.

The objective of this Standard is to provide designers, manufacturers, test laboratories and purchasers with methods of assessing the ability of a power transformer to sustain external short circuits.

This Standard contains different test methods to those in AS 2374.5—1982.

This Standard is an adoption with national modifications and has been reproduced from IEC 60076-5, Ed.3.0 (2006), *Power transformers—Part 5: Ability to withstand short circuit* and has been varied as indicated in Appendix ZZ to take account of Australian and New Zealand conditions.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number appears on the cover and title page while the International Standard number appears only on the cover.
- (b) In the source text ‘this part of IEC 60076’ should read ‘this Australian/New Zealand Standard’.
- (c) A full point substitutes for a comma when referring to a decimal marker.

The term ‘informative’ has been used in this Standard to define the application of the appendix to which it applies. An ‘informative’ appendix is only for information and guidance.

References to International Standards should be replaced by references to Australian or Australian/New Zealand Standards, as follows:

<i>Reference to International Standard</i>	<i>Australian/New Zealand Standard</i>
IEC	AS
60076 Power transformers	60076 Power transformers
60076-1 Part 1: General	60076.1 Part 1: General
	AS/NZS
60076-3 Part 3: Insulation levels, dielectric tests and external clearances in air	60076.3 Part 3: Insulation levels, dielectric tests and external clearances in air (IEC 60076-3, Ed 2 (2000) MOD)
60076-8 Part 8: Application guide	—
	AS
60076-11 Part 11: Dry-type transformers	60076.11 Part 11: Dry-type transformers

CONTENTS

1	Scope.....	5
2	Normative references	5
3	Requirements with regard to ability to withstand short circuit.....	5
3.1	General	5
3.2	Overcurrent conditions	6
4	Demonstration of ability to withstand short circuit	9
4.1	Thermal ability to withstand short circuit.....	9
4.2	Ability to withstand the dynamic effects of short circuit	12
	Annex A (informative) Theoretical evaluation of the ability to withstand the dynamic effects of short circuit	21
	Annex B (informative) Definition of similar transformer.....	36
	Figure 1 – Star/delta connected transformer	15
	Figure 2 – Star/star auto-transformer	16
	Table 1 – Recognized minimum values of short-circuit impedance for transformers with two separate windings	7
	Table 2 – Short-circuit apparent power of the system.....	7
	Table 3 – Maximum permissible values of the average temperature of each winding after short circuit.....	11
	Table 4 – Values for factor $k \times \sqrt{2}$	13
	Table A.1 – Comparison of forces and stresses in core-type transformers	31
	Table A.2 – Comparison of forces and stresses in shell-type transformers	33
	Table A.3 — Values for factor K_3	35
	Table A.4 — Values for factor K_4	35

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-