

Australian Standard™

**Components for the protection of
openings in fire-resistant walls**

Part 1: Fire-resistant doorsets



This Australian Standard was prepared by Committee FP-019, Passive Fire Protection. It was approved on behalf of the Council of Standards Australia on 7 July 2005.

This Standard was published on 9 September 2005.

The following are represented on Committee FP-019:

Architectural Hardware Industry Association
Australasian Fire Authorities Council
Australian Building Codes Board
Australian Chamber of Commerce and Industry
Australian Industry Group
Building Research Association of New Zealand
CSIRO Manufacturing and Infrastructure Technology
Fire Protection Association Australia
Fire Protection Association New Zealand

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia, GPO Box 476, Sydney, NSW 2001.

This Standard was issued in draft form for comment as DR 04098.

AS 1905.1—2005

Australian Standard™

Components for the protection of openings in fire-resistant walls

Part 1: Fire-resistant doorsets

First published in Australia as AS CA57.1—1972.
Revised and redesignated AS 1905.1—1976.
Fourth edition 1990.
First published in New Zealand as part of NZS 1188:1954.
Revised and redesignated in part as NZS 4232.1:1988.
AS 1905.1—1990 and NZS 4232.1:1988, jointly revised, amalgamated
and designated AS/NZS 1905.1:1997.
AS/NZS 1905.1:1997 revised and redesignated as AS 1905.1—2005.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 476, Sydney, NSW 2001, Australia
ISBN 0 7337 6846 6

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee FP-019, Passive Fire Protection, to supersede AS/NZS 1905.1:1997.

After consultation with stakeholders in both countries, Standards Australia and Standards New Zealand decided to develop this Standard as an Australian Standard rather than an Australian/New Zealand Standard.

The objective of this Standard is to provide manufacturers, suppliers and installers with minimum requirements for the construction and installation of fire-resistant doorsets designed to protect the openings in walls and elements of construction that are required to resist the passage of fire.

Committee FP-019 is currently developing an additional option for testing door hardware and non-essential door seals, proposing that door hardware be assessed for use on generic types fire-resistant doorsets without the need for reference to proprietary types of doorsets. These changes will allow door hardware approvals to be gained independently of the doorset manufacturer, to facilitate a more cost effective and efficient method of assessment. It is anticipated that these changes will be introduced as an amendment within a year of publication of this Standard.

Requirements for standard configurations and permissible variations that do not require assessment have been moved from this Standard to AS 1530.4, *Methods for fire tests on building materials, components and structures*, Part 4: *Fire resistance test of elements of construction*, in line with the ISO 834, *Fire resistance tests—Elements of building construction* Standards. As such, the Standard is to be used in conjunction with the appropriate clauses of AS 1530.4.

The opportunity has also been taken to further refine this Standard, reduce ambiguity and provide clearer advice.

This Standard will be referenced in the Building Code of Australia (BCA) by way of BCA 2006 to be published by 1 May 2006, thereby superseding AS/NZS 1905.1:1997.

The requirements for maintenance of fire-resistant doorsets are covered in a separate Standard designated for that purpose, although reference is made in Section 6 of this Standard to maintenance record systems.

Statements expressed in mandatory terms in notes to tables and figures are deemed to be requirements of this Standard.

This Standard references documents in clauses of both a normative and informative nature. Normative referenced documents, are listed in Clause 1.3 and informative referenced documents are listed in the bibliography.

The term ‘informative’ has been used in this Standard to define the application of the appendix to which it applies. An ‘informative’ appendix is only for information and guidance.

This Standard incorporates a Commentary on some clauses. The Commentary directly follows the relevant clause, is designated by ‘C’ preceding the clause number and is printed in italics in a panel. The Commentary is for information only and does not need to be followed for compliance with the Standard.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	4
1.2 APPLICATION	4
1.3 NORMATIVE REFERENCED DOCUMENTS	5
1.4 DEFINITIONS	5
SECTION 2 DESIGN REQUIREMENTS	
2.1 GENERAL	12
2.2 SIDE-HUNG DOORS, INCLUDING DOUBLE-ACTING DOORSETS	13
2.3 SLIDING DOORSETS	14
SECTION 3 DETERMINATION OF FIRE RESISTANCE.....	16
SECTION 4 VARIATIONS FROM THE TESTED SPECIMEN	
4.1 GENERAL	17
4.2 VARIATIONS PERMITTED SUBJECT TO A FORMAL OPINION.....	17
SECTION 5 INSTALLATION	
5.1 GENERAL	21
5.2 DOORSILLS	21
5.3 FIXING OF DOORFRAMES	21
5.4 ALLOWABLE VARIATIONS FOR FIXING OF DOORFRAMES.....	21
5.5 CLEARANCES	22
5.6 HARDWARE	23
5.7 FINAL CHECK	24
SECTION 6 MARKING AND OTHER DOCUMENTATION	
6.1 MARKING OF FIRE-RESISTANT DOORSETS	27
6.2 MARKING OF LATCHSETS AND CLOSERS	28
6.3 EVIDENCE	29
APPENDICES	
A PHYSICAL TESTING OF FIRE-RESISTANT DOORSETS.....	31
B INFORMATION TO BE SUPPLIED WITH ENQUIRIES AND ORDERS	34
C SUPPLEMENTARY NOTES ON THE SELECTION OF DOOR CLOSERS FOR FIRE-RESISTANT DOORSETS.....	37
D METHODS FOR FIXING FIRE-RESISTANT DOORFRAMES TO EXISTING WALLS OF CONCRETE OR MASONRY	38
E FIRE DOOR CERTIFICATE AND SCHEDULE OF EVIDENCE OF COMPLIANCE	42
BIBLIOGRAPHY	44

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-