



NSAI
Standards

Irish Standard
I.S. EN 17432:2021

Packaged refrigerating units for walk-in cold rooms - Classification, performance and energy consumption testing

I.S. EN 17432:2021

Incorporating amendments/corrigenda/National Annexes issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard — national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation — recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

This document replaces/revises/consolidates the NSAI adoption of the document(s) indicated on the CEN/CENELEC cover/Foreword and the following National document(s):

NOTE: The date of any NSAI previous adoption may not match the date of its original CEN/CENELEC document.

This document is based on:

EN 17432:2021

Published:

2021-09-29

*This document was published
under the authority of the NSAI
and comes into effect on:*

2021-10-18

ICS number:

27.200

NOTE: If blank see CEN/CENELEC cover page

NSAI
1 Swift Square,
Northwood, Santry
Dublin 9

T +353 1 807 3800
F +353 1 807 3838
E standards@nsai.ie
W NSAI.ie

Sales:
T +353 1 857 6730
F +353 1 857 6729
W standards.ie

Údarás um Chaighdeáin Náisiúnta na hÉireann

National Foreword

I.S. EN 17432:2021 is the adopted Irish version of the European Document EN 17432:2021, Packaged refrigerating units for walk-in cold rooms - Classification, performance and energy consumption testing

This document does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

For relationships with other publications refer to the NSAI web store.

Compliance with this document does not of itself confer immunity from legal obligations.

In line with international standards practice the decimal point is shown as a comma (,) throughout this document.

This page is intentionally left blank

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 17432

September 2021

ICS 27.200

English Version

**Packaged refrigerating units for walk-in cold rooms -
Classification, performance and energy consumption
testing**

Groupe frigorifiques prêts à monter pour chambres
froides - Classification, performance et essai de
consommation d'énergie

Kälteaggregate für begehbare Kühlräume -
Klassifikation, Prüfung der Leistung und des
Energieverbrauchs

This European Standard was approved by CEN on 21 June 2021.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

Page

European foreword.....	3
Introduction	4
1 Scope	5
2 Normative references.....	5
3 Terms and definitions	5
4 Symbols and abbreviated terms	7
5 Classification.....	8
6 Test conditions.....	9
6.1 General.....	9
6.2 Testing conditions	9
6.3 Measurement uncertainty	10
7 Test setup.....	11
7.1 General.....	11
7.2 Calorimeter room.....	11
7.3 Arrangement of test and measurement equipment.....	11
7.4 Installation and preparation of a test unit.....	12
7.5 Measurement criteria.....	12
7.6 Calibration test of the calorimeter room.....	13
8 Performance testing.....	14
8.1 General.....	14
8.2 Steady-state conditions.....	14
8.3 Cooling capacity tests	15
8.3.1 Steady-state conditions.....	15
8.3.2 Data acquisition.....	15
8.3.3 Heat recovery capacity.....	15
8.4 Calculation of the cooling capacity	15
8.5 Measuring of electric power consumption	15
8.6 Calculation of EER	16
9 Test results.....	16
10 Test report.....	17
10.1 General information.....	17
10.2 Additional information	18
11 Information on the type plate.....	18
Annex A (informative) Examples for the test setup	19
A.1 General.....	19
A.2 Examples	19
Bibliography.....	22

European foreword

This document (EN 17432:2021) has been prepared by Technical Committee CEN/TC 44 “Commercial and Professional Refrigerating Appliances and Systems, Performance and Energy Consumption”, the secretariat of which is held by UNI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by March 2022, and conflicting national standards shall be withdrawn at the latest by March 2022.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a Standardization Request given to CEN by the European Commission and the European Free Trade Association.

Any feedback and questions on this document should be directed to the users’ national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

EN 17432:2021 (E)

Introduction

This document was developed in order to provide a suitable method of performance testing of packaged refrigerating units for stationary cold room applications.

This is the first edition of this document. It includes testing only in so-called “dry conditions”. That means, the evaporator does not show any ice formation during the test. Although it is well-known, that such conditions do not represent the typical situation in the practical use of the packaged refrigerating units, this edition of the document focusses on the description of a test procedure providing reliable test results, which can be used to compare the performance of different models/types of packaged refrigerating unit.

In order to keep the test procedure in this document practically oriented, tests under so-called “wet conditions” as well as taking defrost periods into account will be a future Work Item of the responsible working group. The aim is to integrate such tests in a later revision of this document.

This document reflects the current market situation which shows that only refrigerating units without integrated pump for the heat transfer medium on the exterior heat exchanger are offered.

1 Scope

This document specifies classification criteria, test conditions and test procedures for performance testing of packaged refrigerating units for stationary cold room applications. This includes ductless units for cold storage applications at medium temperatures (MT) and low temperatures (LT) in either compact or split designs, fitted with electrically driven compressors, which work according to the vapour compression cycle.

2 Normative references

There are no normative references in this document.

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1

packaged refrigerating unit

functional unit incorporating a complete factory-made refrigerating system, mounted in a suitable frame and/or enclosure, that is fabricated and transported complete, or in two or more sections and in which no refrigerant-containing parts are connected on site other than by isolation valves, such as companion valves, and by interconnecting piping as defined by the manufacturer

Note 1 to entry: A packaged refrigerating unit incorporates at least one refrigerant circuit, and can incorporate one or more heat transfer circuits.

Note 2 to entry: The terms “factory-made” and “refrigerating system” are defined in EN 378-1.

3.2

compact unit

packaged refrigerating unit, that has been assembled, filled ready for use, and is installed without the need for connecting any refrigerant-containing parts

3.3

split unit

packaged refrigerating unit, comprising one unit providing cooling to the cold room and one unit used for condensing the refrigerant

3.4

factory made

manufactured at a dedicated production location under control of a recognized quality system

Note 1 to entry: Assembling in this context means manufacturing.

[SOURCE: EN 378-1:2016, 3.8.5, modified — The present Note 1 to entry was added.]

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-