AS 2374.3.1—1992 IEC 76-3-1:1987

Australian Standard®

Power transformers

Part 3.1: Insulation levels and dielectric test—External clearances in air

This Australian Standard was prepared by Committee EL/8, Power Transformers. It was approved on behalf of the Council of Standards Australia on 3 June 1992 and published on 14 September 1992.

The following interests are represented on Committee EL/8:

Australian Electrical and Electronic Manufacturers Association Confederation of Australian Industry
Electrical testing laboratories
Electricity Supply Association of Australia
Electricity Supply Engineers Association of New South Wales
Institute of Technology, S.A.
Institution of Engineers, Australia
Railways of Australia Committee

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 91194.



This is a free preview. Purchase the entire publication at the link below

Product Page

- Dooking for additional Standards? Visit Intertek Inform Infostore
- Dearn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation