

AS 3147—1992

Australian Standard[®]

**Approval and test specification—
Electric cables—Thermoplastic
insulated—For working voltages
up to and including 0.6/1 kV**

This Australian Standard was prepared by Committee EL/3, Electric Wires and Cables. It was approved on behalf of the Council of Standards Australia on 15 October 1992 and published on 21 December 1992.

The following interests are represented on Committee EL/3:

Australian Electrical and Electronic Manufacturers Association
Department of Defence
Electrical Contractors Associations of Australia
Electrical regulatory authorities
Electrical Supply Association of Australia
Office of Energy, New South Wales
Railways of Australia Committee
Testing interests.

Review of Australian Standards. *To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.*

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 91252.

AS 3147—1992

Australian Standard[®]

**Approval and test specification—
Electric cables—Thermoplastic
insulated—For working voltages
up to and including 0.6/1 kV**

First published as part of AS C147—1950.
Second edition 1955.
Third edition 1967.
Fourth edition 1969.
AS C189 first published 1971.
Fifth edition AS C147—1972.
AS C189—1971 and part of AS C147—1972 revised,
amalgamated and redesignated AS 3147—1974.
AS C189—1971 withdrawn 1976.
AS C147—1972 withdrawn 1976.
Second edition AS 3147—1976.
Third edition 1981.
Fourth edition 1988.
Fifth edition 1992.
Incorporating:
Amdt 1—1993
Amdt 2—1995
Amdt 3—1996

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 7909 9

PREFACE

This Standard was prepared by the Standards Australia Committee on Electric Wires and Cables to supersede AS 3147—1988, *Approval and test specification—Electric cables—Thermoplastic insulated for working voltages up to and including 0.6/1 kV*.

The Standard applies to cables and flexible cables insulated with thermoplastic materials (including PVC) intended for use in electrical installations at working voltages up to and including 0.6/1 kV.

This Standard differs from the 1988 edition as follows:

- (a) The V-105 insulation in Table 1, while having retained the criteria, has now been redesignated as V-90 HT (i.e. a higher temperature endurance version of V-90) insulation and permits conductor operating temperature up to a maximum of 105°C for limited periods (see Clause 5).

Accordingly, the V-105 insulated cables in Tables 8 and 16 have been similarly redesignated as V-90 HT insulated and are now shown in Tables 7 and 15.

- (b) Average thickness of lead-alloy sheath in Table 5 has been deleted and replaced by a equation in Clause 14. The subsequent tables have been renumbered.
- (c) A note has been added to the Scope, giving a reference to other Standards for flexible cables above 25 mm².
- (d) A requirement for insulation to have not less than 1% carbon black content has been added for insulated unprotected aerial cables.
- (e) The V-90 insulated and non-metallic sheathed single-core, and multicore flat cables incorporate a new 3V-90 sheath.

The Standard is one of a series of Approval and Test Specifications issued by Standards Australia. These Specifications are accompanied by a general Specification, AS 3100, containing definitions and general requirements for electric materials and equipment. The purpose of these Specifications is to outline the conditions which must be met to secure approval for the sale and use of electrical equipment in Australia. Only safety matters and conditions closely allied thereto are covered. For guidance on details for enquiry and order, see Appendix A.

In the preparation of this Standard, consideration was given to IEC 502:1983 *Extruded solid dielectric insulated power cables for rated voltages from 1 kV to 30 kV* and acknowledgment is made of the assistance received from that source. The dimensions and sheath thickness for fixed circular cables are identical with the values in IEC 502.

The nominal cross-sectional areas of the conductors specified in this Standard are identical with the values recommended in IEC 228:1978 *Conductors of insulated cables*.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
1 SCOPE	5
2 REFERENCED DOCUMENTS	5
3 DEFINITIONS	5
4 VOLTAGE DESIGNATION	6
5 MAXIMUM CONTINUOUS CONDUCTOR TEMPERATURE	6
6 CONDUCTORS	6
7 INSULATION	6
8 LAY-UP OF CORES	8
9 FILLERS, BARRIER TAPES AND BINDERS	8
10 BEDDING	9
11 METALLIC LAYERS	9
12 SEPARATION SHEATH	10
13 ARMOUR	10
14 METAL SHEATH	11
15 NON-METALLIC SHEATH	11
16 SERVING	12
17 MARKING	12
18 CONSTRUCTION AND DIMENSIONS	13
19 TESTS	14

TABLES

1 TESTS AND CRITERIA FOR INSULATION	8
2 APPROXIMATE THICKNESS OF BEDDING	9
3 DIAMETER OF ROUND GALVANIZED ARMOUR WIRE	10
4 THICKNESS OF STEEL ARMOUR TAPE	10
5 TESTS AND CRITERIA FOR NON-METALLIC AND SEPARATION SHEATHS ...	13
6 TESTS ON CABLE—CRITERIA, CATEGORY AND REFERENCE	15
7 CONSTRUCTION AND DIMENSIONS OF 0.6/1 kV INSULATED (UNPROTECTED), SINGLE-CORE CABLES	16
8 CONSTRUCTION AND DIMENSIONS OF 0.6/1 kV INSULATED AND NON-METALLIC SHEATHED SINGLE-, 2-, 3- AND 4-CORE CIRCULAR CABLES	17
9 CONSTRUCTION AND DIMENSIONS OF 0.6/1 kV INSULATED (UNPROTECTED), SINGLE-CORE AND 2- AND 3-CORE PARALLEL-WEBBED FLAT AERIAL CABLES	18
10 CONSTRUCTION AND DIMENSIONS OF 0.6/1 kV INSULATED (UNPROTECTED), 3- AND 4-CORE TWISTED AERIAL CABLES	19
11 CONSTRUCTION AND DIMENSIONS OF 0.6/1 kV INSULATED AND NON-METALLIC SHEATHED 2-, 3- AND 4-CORE FLAT CABLES	19
12 CONSTRUCTION AND DIMENSIONS OF 0.6/1 kV INSULATED, BEDDED, GALVANIZED-STEEL, SINGLE WIRE ARMoured 2-, 3- AND 4-CORE CIRCULAR CABLES WITH OR WITHOUT OPTIONAL FURTHER PROTECTION ...	20
13 CONSTRUCTION AND DIMENSIONS OF 0.6/1 kV INSULATED LEAD-ALLOY SHEATHED SINGLE-, 2-, 3- AND 4-CORE CIRCULAR CABLES WITH OR WITHOUT OPTIONAL FURTHER PROTECTION	22
14 CONSTRUCTION AND DIMENSIONS OF 0.6/1 kV INSULATED, LEAD-ALLOY SHEATHED, GALVANIZED-STEEL SINGLE-WIRE ARMoured 2-, 3- AND 4-CORE CIRCULAR CABLES WITH OR WITHOUT OPTIONAL FURTHER PROTECTION	25
15 CONSTRUCTION AND DIMENSIONS OF 0.6/1 kV INSULATED (UNPROTECTED), SINGLE-CORE CIRCULAR FLEXIBLE CABLES	27
16 CONSTRUCTION AND DIMENSIONS OF 0.6/1 kV INSULATED AND NON-METALLIC SHEATHED SINGLE-, 2-, 3- AND 4-CORE CIRCULAR FLEXIBLE CABLES	27

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-