



NSAI
Standards

Irish Standard
I.S. EN 15882-5:2021

Extended application of results from fire resistance tests for service installations - Part 5: Combined penetration seals

I.S. EN 15882-5:2021

Incorporating amendments/corrigenda/National Annexes issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard — national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation — recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

This document replaces/revises/consolidates the NSAI adoption of the document(s) indicated on the CEN/CENELEC cover/Foreword and the following National document(s):

NOTE: The date of any NSAI previous adoption may not match the date of its original CEN/CENELEC document.

This document is based on:

EN 15882-5:2021

Published:

2021-10-13

This document was published under the authority of the NSAI and comes into effect on:

2021-10-31

ICS number:

13.220.99

NOTE: If blank see CEN/CENELEC cover page

NSAI
1 Swift Square,
Northwood, Santry
Dublin 9

T +353 1 807 3800
F +353 1 807 3838
E standards@nsai.ie
W NSAI.ie

Sales:
T +353 1 857 6730
F +353 1 857 6729
W standards.ie

Údarás um Chaighdeáin Náisiúnta na hÉireann

National Foreword

I.S. EN 15882-5:2021 is the adopted Irish version of the European Document EN 15882-5:2021, Extended application of results from fire resistance tests for service installations - Part 5: Combined penetration seals

This document does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

For relationships with other publications refer to the NSAI web store.

Compliance with this document does not of itself confer immunity from legal obligations.

In line with international standards practice the decimal point is shown as a comma (,) throughout this document.

This page is intentionally left blank

EUROPEAN STANDARD

EN 15882-5

NORME EUROPÉENNE

EUROPÄISCHE NORM

October 2021

ICS 13.220.99

English Version

Extended application of results from fire resistance tests for service installations - Part 5: Combined penetration seals

Application étendue des résultats des essais de
résistance au feu des installations de service - Partie 5 :
Calfeutrements de trémie combinés

Erweiterter Anwendungsbereich der Ergebnisse aus
Feuerwiderstandsprüfungen für Installationen - Teil 5:
Kombinierte Abschottungen

This European Standard was approved by CEN on 25 July 2021.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword	3
1 Scope	4
2 Normative references	4
3 Terms and definitions	5
4 Extended application principles	5
5 Pre-conditions for extended application — Fire Resisting Ducts (ventilation ducts) . 6	
5.1 Basic tests required	6
5.2 Additional collaborative test requirements for the EXAP test with respect to fire resisting ducts (ventilation ducts).....	7
6 Specific rules to be applied to combined penetration applications — Fire resisting ducts	15
6.1 General.....	15
6.2 Service penetration field of extended application (permitted variations)	16
7 Pre-conditions for extended application — Fire dampers	17
7.1 Basic tests required	17
7.2 Additional collaborative test requirements for the EXAP test with respect to fire dampers general	19
8 Specific rules to be applied to combined penetration applications — Fire dampers 26	
8.1 General.....	26
8.2 Field of extended application	27
9 Extended application report	29
Annex A (informative) Examples of the EXAP field of application — Explanatory notes	30
A.1 Worked example table.....	30
A.2 EXAP field application flow chart.....	32
A.3 Template for worked example.....	32
Annex B (normative) Combined penetration seal EXAP test setup and requirements — Explanatory notes	35
B.1 General.....	35
B.2 Test furnace	35
B.3 Fire resisting duct and service combinations.....	35
B.4 Fire damper and service combinations	36
B.5 Penetration sealing system	36
Bibliography	37

European foreword

This document (EN 15882-5:2021) has been prepared by Technical Committee CEN/TC 127 “Safety in fire”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2022, and conflicting national standards shall be withdrawn at the latest by April 2022.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This series has the general title *Extended application of results from fire resistance tests for service installations* and consists of the following parts:

- Part 1: Fire resisting ducts
- Part 2: Fire dampers
- Part 3: Penetration seals
- Part 5: Combined penetration seals

Any feedback and questions on this document should be directed to the users’ national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

EN 15882-5:2021 (E)

1 Scope

The purpose of this document is to provide the principles and guidance for the preparation of extended application documents for combined penetration seals where the systems were tested in accordance with (EN 1366-3 and EN 1366-1) or (EN 1366-3 and EN 1366-2). The field of the extended application document is additional to the direct field of application given within EN 1366-1, EN 1366-2 and EN 1366-3 and can be applied on a number of tests from each standard, which provide the relevant information for the formulation of an extended application.

This EXAP is intended to allow the penetration sealing of more than one service (e.g. cables, pipes, conduits) and four-sided fire resisting ducts (ventilation ducts) or fire dampers in the same penetration.

This EXAP is not used for extended applications in accordance with EN 1366-8, EN 1366-10 and/or EN 1366-12 (this will be dealt with in the next revision of the standard).

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1, *Fire resistance tests - Part 1: General requirements*

EN 1363-2, *Fire resistance tests - Part 2: Alternative and additional procedures*

EN 1366-1, *Fire resistance tests for service installations — Part 1: Ventilation ducts*

EN 1366-2, *Fire resistance tests for service installations - Part 2: Fire dampers*

EN 1366-3, *Fire resistance tests for service installations - Part 3: Penetration seals*

EN 15882-1, *Extended application of results from fire resistance tests for service installations — Part 1: Ducts*

EN 13501-1, *Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests*

EN 13501-2, *Fire classification of construction products and building elements - Part 2: Classification using data from fire resistance tests, excluding ventilation services*

EN ISO 13943, *Fire safety - Vocabulary (ISO 13943)*

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-