Australian Standard®

Instrument transformers

Part 2: Inductive voltage transformers (IEC 60044-2:Ed.1.2 (2003) MOD)



This is a free page sample. Access the full version online.

This Australian Standard® was prepared by Committee EL-013, Measurement and Protection Transformers. It was approved on behalf of the Council of Standards Australia on 17 January 2007.

This Standard was published on 20 February 2007.

The following are represented on Committee EL-013:

- Australian Electrical and Electronic Manufacturers Association
- Cigre APA2
- Energy Networks Association
- National Measurement Institute
- University of South Australia

This Standard was issued in draft form for comment as DR 06515.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through public comment period.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting **www.standards.org.au**

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at **mail@standards.org.au**, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard[®]

Instrument transformers

Part 2: Inductive voltage transformers (IEC 60044-2:Ed.1.2 (2003) MOD)

Originated as part of AS C45—1928. Previous edition AS 60044.2—2003. Second edition 2007.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 476, Sydney, NSW 2001, Australia ISBN 0 7337 8027 X

ii

PREFACE

This Standard was prepared by the Standards Australia Committee EL-013, Measurement and Protection Transformers to supersede AS 60044.2—2003.

The objective of this Standard is to provide users and manufacturers of voltage transformers with definitions of terms, safety requirements, methods of specifying performance and methods of test.

This Standard is Part Two of a series covering instrument transformers. This series consists of the following Standards:

AS

60044 Instrument transformers

60044.1 Part 1: Current transformers

60044.2 Part 2: Single-phase inductive voltage transformers (this Standard)

This Standard is an adoption with national modifications of IEC 60044-2, Ed.1.2 (2003), *Instrument transformers*, Part 2: *Inductive voltage transformers* (including Amendment 1:2001 and Amendment 2:2002).

Variations to IEC 60044-2, Ed.1.2 (2003) are indicated at the appropriate places throughout this standard. Strikethrough (example) identifies IEC text, tables and figures which, for the purposes of this Australian Standard, are deleted. Where text, tables or figures are added, each is set in its proper place and identified by shading (example). Added figures are not themselves shaded, but are identified by a shaded border.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text 'this Part of IEC 60044' should read 'this Part of AS 60044'.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

In January 1997, the IEC commenced numbering its Standards from 60 000 by adding 60 000 to the number of each existing Standard. Publications printed earlier than 1997 will continue to carry the old series of numbers.

Attention is drawn to the following differences between this Standard and AS 1243—1982:

- (a) This Standard introduces temperature rise testing of voltage transformers with voltage factors of 1.5 for 30 s, 1.9 for 30 s and 1.9 for 8 h starting after the voltage transformers have reached equilibrium at 1.2 U_n . See Clause 5.4, Limits of temperature rise.
- (b) This Standard has a new thermal class for windings in oil and hermetically sealed that allows 65 K temperature rise (see Table 3, Limits of temperature rise of windings).
- (c) This Standard introduces requirements and tests for winding withstand capability. See Clause 6.2, Short-circuit withstand capability.
- (d) This Standard has highest voltages for equipment of 170 kV and 245 kV in place of 245 kV in AS 1243—1982. See Clause 6.1.1, Rated insulation levels for primary windings).

iii

- (e) This Standard introduces reduced levels of permissible partial discharges across the complete range of system earthing types and voltages, with increases in prestress voltage level (from the current 1.3 $U_{\rm m}$ level to the induced voltage withstand test level) and in testing voltage level (from 1.1 $U_{\rm m}$ to 1.3 $U_{\rm m}$). See Clause 6.1.2.3, Partial discharges, and Clause 9.2.4, Partial discharge measurement.
- (f) This Standard introduces requirements for minimum insulator creepage distance and arcing/creepage ratio for four various pollution levels. See Clause 6.1.5, Requirements for the external insulation.
- (g) This Standard requires repeated dielectric testing to be performed at 80% of the initial power frequency voltage (and not 75% as in AS 1243—1982). See Clause 7.2, Routine tests.
- (h) This Standard covers measurement of dielectric dissipation factor as a special test, and not as a routine test as does AS 1243—1982. See Clause 7.3, Special tests.
- (i) This Standard requires testing of radio interference voltage with a prestress voltage of $1.5 \text{ U}_{\text{m}}/\sqrt{3}$, and a limit of 300 pC or 2500 μ V at $1.1 \text{ U}_{\text{m}}/\sqrt{3}$. This test is also required for voltages 123 kV and upwards (and not from 245 kV as in AS 1243—1982). See Clause 8.5, Radio interference voltage measurement.
- (j) This Standard includes requirements for measurement of partial discharges that are stricter than those in AS 1243—1982 (which calls up AS 2532 which has been withdrawn). See Clause 9.2.4, Partial discharge measurement.
- (k) This Standard introduces new special tests of chopped impulse on primary winding and mechanical testing of primary terminals. See Clause 7.3, Special tests.
- (1) This Standard requires that testing for accuracy be done at a primary voltage of 0.8 to $1.2 U_n$ and a power factor of 0.8 lagging. AS 1243—1982 requires that testing for accuracy be done at a primary voltage of 0.9 to $1.1 U_n$ and a power factor of 1. See Clause 12.2, Limits of voltage error and phase displacement for measuring voltage transformers.
- (m) This Standard has Classes 3P and 6P and does not have the Classes 1P, 2P and 5P of AS 1243—1982. See Clause 13.1.1, Standard accuracy classes for protective voltage transformers.
- (n) This Standard does not include requirements for voltage transformers for laboratory use (Class L in AS 1243). The committee considered that this class is no longer required.
- (o) This Standard introduces a new special test for transmitted overvoltages. See Clause 7.3, Special tests.

The term 'normative' is used to define the application of the annex to which it applies. A normative annex is an integral part of a standard.



This is a free preview. Purchase the entire publication at the link below:

Product Page

S Looking for additional Standards? Visit Intertek Inform Infostore

> Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation