



NSAI
Standards

Irish Standard
I.S. EN 16165:2021

Determination of slip resistance of pedestrian surfaces - Methods of evaluation

I.S. EN 16165:2021

Incorporating amendments/corrigenda/National Annexes issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard — national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation — recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

This document replaces/revises/consolidates the NSAI adoption of the document(s) indicated on the CEN/CENELEC cover/Foreword and the following National document(s):

NOTE: The date of any NSAI previous adoption may not match the date of its original CEN/CENELEC document.

This document is based on:

EN 16165:2021

Published:

2021-10-27

*This document was published
under the authority of the NSAI
and comes into effect on:*

2021-11-15

ICS number:

17.040.20

91.060.30

93.080.10

NOTE: If blank see CEN/CENELEC cover page

NSAI
1 Swift Square,
Northwood, Santry
Dublin 9

T +353 1 807 3800
F +353 1 807 3838
E standards@nsai.ie
W NSAI.ie

Sales:
T +353 1 857 6730
F +353 1 857 6729
W standards.ie

Údarás um Chaighdeáin Náisiúnta na hÉireann

National Foreword

I.S. EN 16165:2021 is the adopted Irish version of the European Document EN 16165:2021, Determination of slip resistance of pedestrian surfaces - Methods of evaluation

This document does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

For relationships with other publications refer to the NSAI web store.

Compliance with this document does not of itself confer immunity from legal obligations.

In line with international standards practice the decimal point is shown as a comma (,) throughout this document.

This page is intentionally left blank

EUROPEAN STANDARD

EN 16165

NORME EUROPÉENNE

EUROPÄISCHE NORM

October 2021

ICS 17.040.20; 91.060.30; 93.080.10

Supersedes CEN/TS 16165:2016

English Version

Determination of slip resistance of pedestrian surfaces - Methods of evaluation

Détermination de la résistance à la glissance des
surfaces piétonnières - Méthodes d'évaluation

Bestimmung der Rutschhemmung von Fußböden -
Ermittlungsverfahren

This European Standard was approved by CEN on 25 July 2021.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	3
Introduction	4
1 Scope.....	5
2 Normative references.....	5
3 Terms and definitions	5
3.1 General terms.....	5
3.2 Terms related to ramp tests.....	6
3.3 Terms related to pendulum tests.....	6
3.4 Terms related to tribometer tests	6
4 Test methods	7
Annex A (normative) Barefoot ramp test	8
Annex B (normative) Shod ramp test.....	14
Annex C (normative) Pendulum test	21
Annex D (normative) Tribometer test.....	46
Bibliography.....	53

European foreword

This document (EN 16165:2021) has been prepared by Technical Committee CEN/TC 339 “Slip resistance of pedestrian surfaces - Methods of evaluation”, the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2022, and conflicting national standards shall be withdrawn at the latest by April 2022.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes CEN/TS 16165:2016.

The main changes compared to the previous edition are as follows:

- a) description of test surface used in the barefoot ramp test and the shod ramp test changed;
- b) calibration procedure of the test device used in the barefoot ramp test changed;
- c) angles of slip for the three standard surfaces used in the barefoot ramp test changed;
- d) procedure for verification and correction in the barefoot ramp test changed;
- e) description of the test procedure used in the barefoot ramp test changed;
- f) description of test footwear used in the shod ramp test changed;
- g) angles of slip for the three standard surfaces used in the shod ramp test changed;
- h) information when slider pads and slider assemblies shall be re-prepared or discarded added to the pendulum test;
- i) description of the verification procedure used in the pendulum test and the tribometer test changed;
- j) Reference surfaces for pendulum test and tribometer tests were removed;
- k) procedure for the preparation of sliders used in the tribometer test changed.

Any feedback and questions on this document should be directed to the users’ national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

EN 16165:2021 (E)**Introduction**

This document describes four test methods commonly used in Europe for the determination of the slip resistance of floorings.

The method in Annex A describes the test method based on the ramp using water as the test liquid and with the operator barefoot. This method cannot be used *in situ*. It is referred to as the “Barefoot ramp method”.

The method in Annex B describes the test method based on the ramp using oil as the test liquid and with the operator wearing specified shoes. This method cannot be used *in situ*. It is referred to as the “Shod ramp test”.

NOTE Oil is used as the test liquid to make the test more sensitive.

The method in Annex C describes the test method based on the pendulum in dry and wet conditions using specified rubber sliders. This method can be used *in situ*. It is referred to as the “Pendulum test”.

The method in Annex D describes the test method based on the tribometer in dry and wet conditions using specified rubber sliders. This method can be used *in situ*. It is referred to as the “Tribometer test”.

The purpose of this document is to harmonize the procedures used when using any of the above test methods. It is not intended to promote any particular test method to Product Group Technical Committees or to limit their choice.

The test methods given in this document cannot be compared with each other. The results can only be compared with results that are obtained with the same test method.

1 Scope

This document specifies test methods for determining the slip resistance of surfaces used by pedestrians.

NOTE It is also possible to use this document for measurements where persons might walk on trafficked areas.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN ISO 868, *Plastics and ebonite — Determination of indentation hardness by means of a durometer (Shore hardness) (ISO 868)*

ISO 48-2, *Rubber, vulcanized or thermoplastic — Determination of hardness — Part 2: Hardness between 10 IRHD and 100 IRHD*

ISO 48-4, *Rubber, vulcanized or thermoplastic — Determination of hardness — Part 4: Indentation hardness by durometer method (Shore hardness)*

ISO 5725-2, *Accuracy (trueness and precision) of measurement methods and results — Part 2: Basic method for the determination of repeatability and reproducibility of a standard measurement method*

ISO 5725-5, *Accuracy (trueness and precision) of measurement methods and results — Part 5: Alternative methods for the determination of the precision of a standard measurement method*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1 General terms

3.1.1

pedestrian surface

surface which is designed for people to walk upon

3.1.2

test liquid

standardized liquid applied on the surface for the purpose of the test

3.1.3

friction

resistance to relative motion between two bodies in contact, e.g. the test slider or the footwear sole and the pedestrian surface

Note 1 to entry: The frictional force is the force acting tangentially in the contact area.

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-