



NSAI
Standards

Irish Standard
I.S. EN 15316-4-2:2017&AC:2017

Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 4-2: Space heating generation systems, heat pump systems, Module M3-8-2, M8-8-2

I.S. EN 15316-4-2:2017&AC:2017

Incorporating amendments/corrigenda/National Annexes issued since publication:

EN 15316-4-2:2017/AC:2017

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard — national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation — recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

This document replaces/revises/consolidates the NSAI adoption of the document(s) indicated on the CEN/CENELEC cover/Foreword and the following National document(s):

NOTE: The date of any NSAI previous adoption may not match the date of its original CEN/CENELEC document.

This document is based on:

EN 15316-4-2:2017

Published:

2017-04-26

This document was published under the authority of the NSAI and comes into effect on:

2017-11-05

ICS number:

91.140.10

NOTE: If blank see CEN/CENELEC cover page

NSAI
1 Swift Square,
Northwood, Santry
Dublin 9

T +353 1 807 3800
F +353 1 807 3838
E standards@nsai.ie
W NSAI.ie

Sales:
T +353 1 857 6730
F +353 1 857 6729
W standards.ie

Údarás um Chaighdeáin Náisiúnta na hÉireann

National Foreword

I.S. EN 15316-4-2:2017&AC:2017 is the adopted Irish version of the European Document EN 15316-4-2:2017, Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 4-2: Space heating generation systems, heat pump systems, Module M3-8-2, M8-8-2

This document does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

For relationships with other publications refer to the NSAI web store.

Compliance with this document does not of itself confer immunity from legal obligations.

In line with international standards practice the decimal point is shown as a comma (,) throughout this document.

This page is intentionally left blank

EUROPEAN STANDARD

EN 15316-4-2:2017/AC

NORME EUROPÉENNE

October 2017

EUROPÄISCHE NORM

ICS 91.140.10

English version

Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 4-2: Space heating generation systems, heat pump systems, Module M3-8-2, M8-8-2

Performance énergétique des bâtiments -
Méthode de calcul des besoins énergétiques
et des rendements des systèmes - Partie 4-2 :
Systèmes de génération de chauffage des
locaux, systèmes de pompes à chaleur
Module M3-8-2, M8-8-2

Energetische Bewertung von Gebäuden -
Verfahren zur Berechnung der
Energieanforderungen und Nutzungsgrade
der Anlagen - Teil 4-5: Fernwärme und
Fernkälte, Modul M3-8-5, M4-8-5, M8-8-5,
M11-8-5

This corrigendum becomes effective on 18 October 2017 for incorporation in the official English version of the EN.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

© 2017 CEN All rights of exploitation in any form and by any means reserved worldwide for CEN national Members.
Tous droits d'exploitation sous quelque forme et de quelque manière que ce soit réservés dans le monde entier
aux membres nationaux du CEN.
Alle Rechte der Verwertung, gleich in welcher Form und in welchem Verfahren, sind weltweit den nationalen
Mitgliedern von CEN vorbehalten.

Ref. No.: EN 15316-4-2:2017/AC:2017 E

EN 15316-4-2:2017/AC:2017 (E)

1 Modifications to Table D.3

Move the table on a landscape page to have a full view of the formulas:

Table D.3 — COP and efficiency based on Carnot cycle

Reference testing point	Carnot COP COP_{exer}	Load Ratio $LR_{exer;XX}$	Exergetic efficiency $f_{LR,exer;XX}$
Formula Used ^a	$\frac{\vartheta_{gen,out}(t) + 273,15 - \frac{\Delta\vartheta_{gen,out}(t)}{2}}{\vartheta_{gen,out}(t) - \vartheta_{gen,in}(t) - \frac{(\Delta\vartheta_{gen,out}(t) - \Delta\vartheta_{gen,in}(t))}{2}}$	$\frac{COP_{exer;XX}}{COP_{exer;biv}} \times \left[\frac{(\vartheta_{out;biv} + 273,15 - 0,5\Delta\vartheta_{out;biv}) / (\vartheta_{in;biv} + 273,15 + 0,5\Delta_{in;biv})}{(\vartheta_{out;XX} + 273,15 - 0,5\Delta_{out;X}) / (\vartheta_{in;XX} + 273,15 + 0,5\Delta_{in;XX})} \right]^{n_{exer}}$	$\frac{COP_{ref;XX}}{COP_{exer;XX}}$
A	$COP_{exer;A}$	$LR_{exer;A}$	$f_{LR,exer;A}$
B	$COP_{exer;B}$	$LR_{exer;B}$	$f_{LR,exer;B}$
C	$COP_{exer;C}$	$LR_{exer;C}$	$f_{LR,exer;C}$
D	$COP_{exer;D}$	$LR_{exer;D}$	$f_{LR,exer;D}$
E (biv)	$COP_{exer;BIV}$	$LR_{exer;BIV}$	$f_{LR,exer;biv}$
F (TOL)	$COP_{exer;TOL}$	$LR_{exer;TOL}$	$f_{LR,exer;TOL}$
G			
Description	Symbol	Unit	Test results
Power thermostat OFF	P_HTO	W	
Power Standby	P_stby	W	
Power Off mode	P_off	W	
Degradation factor	F_cd	-	
^a Formulas include the temperature spreads ($\Delta\vartheta$) that are neglected in the standard ($\Delta\vartheta = 0$).			

This page is intentionally left blank

EUROPEAN STANDARD

EN 15316-4-2

NORME EUROPÉENNE

EUROPÄISCHE NORM

April 2017

ICS 91.140.10

Supersedes EN 15316-4-2:2008

English Version

Energy performance of buildings - Method for calculation
of system energy requirements and system efficiencies -
Part 4-2: Space heating generation systems, heat pump
systems, Module M3-8-2, M8-8-2

Performance énergétique des bâtiments - Méthode de
calcul des besoins énergétiques et des rendements des
systèmes - Partie 4-2 : Systèmes de génération de
chauffage des locaux, systèmes de pompes à chaleur
Module M3-8-2, M8-8-2

Energetische Bewertung von Gebäuden - Verfahren zur
Berechnung der Energieanforderungen und
Nutzungsgrade der Anlagen - Teil 4-5: Fernwärme und
Fernkälte, Modul M3-8-5, M4-8-5, M8-8-5, M11-8-5

This European Standard was approved by CEN on 27 February 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

This document consolidates EN 15316-4-2:2017 and the corrigendum EN 15316-4-2:2017/AC:2017.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents	Page
European foreword.....	4
Introduction	5
1 Scope.....	6
2 Normative references.....	9
3 Terms and definitions	9
4 Symbols and abbreviations	13
4.1 Symbols.....	13
4.2 Subscripts.....	13
5 Description of the methods	14
5.1 General.....	14
5.2 Multiple heat generators	14
5.3 System boundary.....	15
5.3.1 General.....	15
5.3.2 Physical factors taken into account:.....	15
5.4 Schematisation of the heat pump for heating.....	15
5.5 Energy input needed to meet the heat requirements for heat pumps system.....	16
5.6 Auxiliary energy ($W_{HW;gen;aux}$)	18
5.7 Recoverable, recovered and unrecoverable heat losses	18
5.8 Calculation by zones.....	18
5.9 Combined heating and domestic hot water preparation.....	19
6 Generation with heat pump systems - Energy calculation (hourly, bin) - Method A	19
6.1 Output data.....	19
6.2 Input data.....	20
6.3 Multiple heat generators	26
6.4 Calculation time steps	26
6.5 Flow chart	26
6.6 Energy requirements for space heating and DHW mode for the time step considered	27
6.7 COP and energy used for heating, storage and domestic hot water	28
6.8 Auxiliary energy ($W_{H;gen;aux}$)	39
6.9 Energy used from the heat source.....	39
6.10 Calculation of back-up heater.....	40
6.11 Total losses and total recoverable heat losses of the generation subsystem.....	40
7 Method B - Monthly and annual energy calculation method.....	43
7.1 Calculation time steps	43
7.2 Output data.....	43
7.3 Principle of the calculation method B.....	43
7.4 Additional input Data	44
7.5 Construction of the bins - Step 1	47
7.6 Determination of energy requirement of the single bins - Step 2	50
7.7 Determination of thermal performance of the heat pump (step 3).....	52
7.8 Determination of back-up energy of the single bins (step 4).....	53

7.9	Calculation of auxiliary energy input (step 5).....	53
7.10	Calculation of recoverable generation subsystem losses (step 6).....	53
7.11	Calculation of the energy from the heat source (step 7)	54
7.12	Calculation of the total driving energy input to cover the requirements (step 8).....	54
8	Quality control.....	54
8.1	Hourly, bin or monthly method.....	54
8.2	Main sources of errors.....	55
9	Compliance check.....	55
Annex A (normative) Template for input data.....		56
A.1	Heat pump description data	56
A.2	System design data.....	60
A.3	Operating conditions.....	62
Annex B (informative) Default values		64
B.1	Heat pump description data	64
B.2	System design data.....	68
B.3	- Operating conditions	70
Annex C (informative) Tables of COP and energy at full load.....		72
C.1	General	72
C.2	Air - Water electrically driven heat pumps	72
C.3	COP and energy for exhaust air/ water electrically driven heat pump	73
C.4	COP and energy for water or brine/ water electrically driven heat pump.....	74
C.5	Air/water combustion-engine driven heat pumps.....	75
Annex D (normative) Adaptation of the COP to different conditions of temperature conditions.....		77
D.1	Principle.....	77
D.2	Application to electrically-driven heat pump	78
D.3	Application to thermally-driven heat pumps.....	78
D.4	Correction of COP with adaptation to the operational temperature spread	79
D.5	Tests results form EN 14825	83
D.6	Input data for the calculation of COP and capacity at operating conditions.....	83
Bibliography		85

EN 15316-4-2:2017 (E)

European foreword

This document (EN 15316-4-2:2017) has been prepared by Technical Committee CEN/TC 228 “Heating systems and water based cooling systems in buildings”, the secretariat of which is held by DIN.

This document supersedes EN 15316-4-2:2008.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2017, and conflicting national standards shall be withdrawn at the latest by October 2017.

The revision keeps the main principles of the calculation unchanged but the structure of the document was changed. Informative content was removed to the accompanying technical report CEN/TR 15316-6-2. The provisions cover also other energy carriers than heat now. The values may be altered in a national annex.

Calculation methods to determine energy source indicators like the renewable energy ratio have been added.

The main changes compared to EN 15316-4-2:2008 are:

- a) type of heat pumps are now limited to hot water production at the output of the condenser;
- b) informative content was removed to the accompanying technical report CEN/TR 15316-6-2;
- c) calculation for performance of the heat pumps at different conditions is based on interpolation provisions;
- d) input data for energy performance of the heat pumps are based on part load and/or full load information;
- e) Annex A contains a template for the data and parameters used in the standards and Annex B a set of default values.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document includes the corrigendum EN 15316-4-2:2017/AC:2017 which corrects Table D.3.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

This European Standard is part of a series of standards aiming at international harmonization of the methodology for the assessment of the energy performance of buildings, called “set of EPB standards”.

All EPB standards follow specific rules to ensure overall consistency, unambiguity and transparency.

All EPB standards provide a certain flexibility with regard to the methods, the required input data and references to other EPB standards, by the introduction of a normative template in Annex A and Annex B with informative default choices.

EPB standards deal with energy performance calculation and other related aspects (like system sizing) to provide the building services considered in the EPBD.

CEN/TC 228 deals with heating systems in buildings. Subjects covered by CEN/TC 228 are:

- energy performance calculation for heating systems;
- inspection of heating systems;
- design of heating systems;
- installation and commissioning of heating systems.

This standard specifies to take into account the energy performance of heat pump systems used for domestic or heating purpose.

For the correct use of this standard, Annex A is to be used to specify the choices with the required input data. Default values are presented in Annex B. In case the standard is used in the context of national or regional legal requirements, mandatory choices may be given at national or regional level for such specific applications, in particular for the application within the context of EU Directives transposed into national legal requirements. These choices can be made available as National Annex or as separate (e.g. legal) document. It is expected, if the default values and choices in Annex A are not followed due to national regulations, policy or traditions, that:

- either the national standardization body will consider the possibility to add or include a National Annex in agreement with the template of Annex A.
- or the national or regional authorities will, in the building regulations, reference the standard and prepare data sheets containing the national or regional choices and values, in agreement with the template of Annex A.

This updated standard covers hourly, monthly, annual time-steps and temperatures classes (bin method).

EN 15316-4-2:2017 (E)

1 Scope

This European Standard covers heat pumps for space heating, heat pump water heaters (HPWH) and heat pumps with combined space heating and domestic hot water production in alternate or simultaneous operation, where the same heat pump delivers the heat to cover the space heating and domestic hot water heat requirement.

The standard provides a calculation method under steady conditions that corresponds to one calculation step.

The results of this calculation are incorporated in larger building models and take in account the influence of the external conditions and building control that influence the energy requirements for heating supplied by the heat pump system.

The scope of this part is to standardize the:

- required inputs;
- calculation methods;
- required outputs

Generation for space heating and domestic hot water production of the following heat pump systems, including control of:

- electrically-driven vapour compression cycle (VCC) heat pumps;
- combustion engine-driven vapour compression cycle heat pumps;
- thermally-driven vapour absorption cycle (VAC) heat pumps,

using combinations of heat source and heat distribution listed in Table 1.

Table 1 — Heating sources and energy distribution

Source	Distribution
Outdoor air	Water
Exhaust-air	
Indirect ground source with brine	
Indirect ground source with water	
Direct ground source (Direct expansion (DX))	
Surface water	
Ground water	

This standard does not cover sizing or inspection of heat pumps.

This standard deals with heat generators for heating or for combined domestic hot water and heating service. Generators for domestic hot water only are taken into account into module M8-8.

NOTE 1 Heat pumps for cooling systems are taken into account into module M4-8.

NOTE 2 Heat pumps for space heating using air (distribution) are taken into account in module M5-8.

Other generation systems such as boilers are covered in other sub modules of part M3-8.

This is the revision of EN 15316-4-2:2008. The revision covers the adaptation of the standard to hourly and monthly energy calculation.

Table 2 shows the relative position of this standard within the set of EPB standards in the context of the modular structure as set out in EN ISO 52000-1.

NOTE 3 In CEN ISO/TR 52000-2 the same table can be found, with, for each module, the numbers of the relevant EPB standards and accompanying technical reports that are published or in preparation.

NOTE 4 The modules represent EPB standards, although one EPB standard may cover more than one module and one module may be covered by more than one EPB standard, for instance a simplified and a detailed method respectively. See also Clause 2 and Tables A.1 and B.1.

EN 15316-4-2:2017 (E)

Table 2 — Position of this standard, within the modular structure of the set of EPB standards

Overarching		Building (as such)		Technical Building Systems										
	Descriptions		Descriptions		Descriptions	Heating	Cooling	Ventilation	Humidification	Dehumidification	Hot Domestic water	Lighting	Building automation and control	Electricity production
sub 1		M1	sub1	M2	sub1	M3	M4	M5	M6	M7	M8	M9	M10	M11
1	General		1	General	1	General	15316-1				15316-1			
2	Common terms and definitions; symbols, units and subscripts		2	Building Energy Needs	2	Needs					12831-3 ?			
3	Applications		3	(Free) Indoor Conditions without Systems	3	Maximum Load and Power	12831-1				12831-3			
4	Ways to Express Energy Performance		4	Ways to Express Energy Performance	4	Ways to Express Energy Performance	15316-1				15316-1			
5	Building Functions and Building Boundaries		5	Heat Transfer by Transmission	5	Emission and control	15316-2	15316-2						
6	Building Occupancy and Operating Conditions		6	Heat Transfer by Infiltration and Ventilation	6	Distribution and control	15316-3	15316-3			15316-3			
7	Aggregation of Energy Services and Energy Carriers		7	Internal Heat Gains	7	Storage and control	15316-5				15316-5 15316-4-3			
8	Building Partitioning		8	Solar Heat Gains	8	Generation								
					8-1	Combustion boilers	15316-4-1				15316-4-1			
					8-2	Heat pumps	15316-4-2				15316-4-2			
					8-3	Thermal solar Photovoltaics	15316-4-3				15316-4-3			15316-4-3
					8-4	On-site cogeneration	15316-4-4				15316-4-4			15316-4-4
					8-5	District heating and cooling	15316-4-5	15316-4-5						15316-4-5
					8-6	Direct electrical heater	15316-4-6				15316-4-6			
					8-7	Wind turbines								15316-4-7
					8-8	Radiant heating, stoves	15316-4-8							
9	Calculated Energy Performance		9	Building Dynamics (thermal mass)	9	Load dispatching and operating conditions								
10	Measured Energy Performance		10	Measured Energy Performance	10	Measured Energy Performance	15378-3				15378-3			
11	Inspection		11	Inspection	11	Inspection	15378-1				15378-1			
12	Ways to Express Indoor Comfort		12	-	12	BMS								
13	External Environment Conditions													
14	Economic Calculation	1545 9-1												

NOTE The shaded modules are not applicable

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-