



NSAI
Standards

Irish Standard
I.S. HD 60364-7-715:2005

Electrical installations of buildings -- Part 7-715: Requirements for special installations or locations - Extra-low- voltage lighting installations (IEC 60364 -7-715:1999 (MOD))

I.S. HD 60364-7-715:2005

Incorporating amendments/corrigenda issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation - recommendation based on the consensus of an expert panel and subject to public consultation.

SWIFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

| | | |
|--|---|---|
| <i>This document replaces:</i> | <i>This document is based on:</i> HD 60364-7-715:2005 | <i>Published:</i> 14 July, 2005 |
| This document was published under the authority of the NSAI and comes into effect on: 24 February, 2007 | | ICS number: 29.140.50 91.140.50 |
| NSAI 1 Swift Square, Northwood, Santry Dublin 9 | T +353 1 807 3800 F +353 1 807 3838 E standards@nsai.ie W NSAI.ie | Sales: T +353 1 857 6730 F +353 1 857 6729 W standards.ie |
| Údarás um Chaighdeáin Náisiúnta na hÉireann | | |

HARMONIZATION DOCUMENT

HD 60364-7-715

DOCUMENT D'HARMONISATION

HARMONISIERUNGSDOKUMENT

July 2005

ICS 29.140.50; 91.140.50

English version

Electrical installations of buildings **Part 7-715: Requirements for special installations or locations –** **Extra-low-voltage lighting installations** (IEC 60364-7-715:1999, modified)

Installations électriques des bâtiments
Partie 7-715: Règles pour les installations
et emplacements spéciaux –
Installations d'éclairage à très basse
tension
(CEI 60364-7-715:1999, modifiée)

Elektrische Anlagen von Gebäuden
Teil 7-715: Anforderungen für
Betriebsstätten, Räume und Anlagen
besonderer Art –
Kleinspannungs-Beleuchtungsanlagen
(IEC 60364-7-715:1999, modifiziert)

This Harmonization Document was approved by CENELEC on 2005-03-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for implementation of this Harmonization Document on a national level.

Up-to-date lists and bibliographical references concerning such national implementation may be obtained on application to the Central Secretariat or to any CENELEC member.

This Harmonization Document exists in three official versions (English, French, German).

CENELEC members are the national electrotechnical committees of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

The text of the International Standard IEC 60364-7-715:1999, prepared by IEC TC 64, Electrical installations and protection against electric shock, together with the common modifications prepared by SC 64B, Protection against thermal effects, of Technical Committee CENELEC TC 64, Electrical installations and protection against electric shock, was submitted to the formal vote and was approved by CENELEC as HD 60364-7-715 on 2005-03-01.

The following dates were fixed:

- | | | |
|--|-------|------------|
| – latest date by which the existence of the HD has to be announced at national level | (doa) | 2005-09-01 |
| – latest date by which the HD has to be implemented at national level by publication of a harmonized national standard or by endorsement | (dop) | 2006-03-01 |
| – latest date by which the national standards conflicting with the HD have to be withdrawn | (dow) | 2008-03-01 |

In this standard, the common modifications to the International Standard are indicated by a vertical line in the left margin of the text.

Clauses, subclauses, annexes and notes which are additional to those of IEC 60364-7-715 are prefixed "Z".

Annex ZA has been added by CENELEC.

Introduction

The requirements of this part of HD 60364 modify or replace certain of the general requirements of HD 60364.

The clause numbering of Part 7-715 follows the pattern and corresponding references of HD 60364.

The numbers following the particular number of Part 7-715 are those of the corresponding parts or clauses of HD 60364.

The absence of reference to a part or a clause means that the general requirements of HD 60364 are applicable.

Numbering in parenthesis corresponds to the numbering of the “non restructured” IEC 60364 (HD 384) dated before 2002.

715 Extra-low-voltage lighting installations

715.1 Scope

The particular requirements of this part apply to extra-low-voltage lighting installations supplied from sources with a maximum rated voltage of 50 V a.c. or 120 V d.c.

NOTE 1 For the definition of an extra-low-voltage lighting system, see EN 60598-1.

NOTE 2 AC voltages are given as r.m.s. values.

NOTE Z1 The maximum d.c. value for SELV luminaires is under consideration.

715.2 Normative references

See Annex ZA.

715.411 Protection against both direct and indirect contact

715.411.1 For extra-low-voltage lighting installations only SELV shall be applied. Where bare conductors are used (see 715.521.7), the maximum voltage shall be 25 V a.c. or 60 V d.c. according to 411.1.4.3 of HD 384.4.41.

715.411.1.2 Safety isolating transformers shall conform with EN 61558-2-6.

Parallel operation of transformers in the secondary circuit is allowed only if they are also paralleled in the primary circuit and the transformers have identical electrical characteristics.

Safety isolating converters shall conform to EN 61347-2-2, Annex I.

Parallel operation of converters is not accepted.

715.43 Protection against overcurrent

The SELV circuit shall be protected against overcurrent either by a common protective device or a protective device for each SELV circuit, in accordance with the requirements of HD 384.4.43.

NOTE 1 When selecting the protective device for the primary circuit, account should be taken of the magnetising current of the transformer.

Self-resetting overcurrent protective devices shall only be required for transformers up to 50 VA.

NOTE 2 Overcurrent protection may be provided by a protective device complying with the requirements of 715.482.5.2.

715.46 (715.536) Isolation and switching

715.462.5 Where transformers are operated in parallel the primary circuit shall be permanently connected to a common isolating device.

715.482 (715.422) Protection against fire

715.482.2 (715.422.3) Nature of processed or stored materials

715.482.2.3 (422.3.3) The manufacturer's installation instructions shall be followed, including those relating to mounting on flammable or non-flammable surfaces. See also HD 60364-5-559.

NOTE Z1 Luminaires suitable for direct mounting on normally flammable surfaces are marked with the symbol



715.482.4 (422.5) Fire risk of transformers/converters

715.482.4.1 (422.5.1) Transformers shall be either:

- protected on the primary side by the protective device required in 715.482.5.2; or
- short-circuit proof transformers (both inherently and non-inherently proof), see Annex A for the symbol.

715.482.4.2 Electronic converters shall comply with EN 61347-2-2, and with the requirements of EN 60598-2-23.

NOTE It is recommended that converters marked with the symbol



are used. See Annex A for the symbol.

715.482.5 Fire risk by short circuit

715.482.5.1 If both circuit conductors are uninsulated, they shall be either:

- provided with a special protective device complying with the requirements of 715.482.5.2; or
- systems complying with EN 60598-2-23.

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-