



National Standards Authority of Ireland

IRISH STANDARD

I.S. EN 12094-8:2006

ICS 13.220.20

**FIXED FIREFIGHTING SYSTEMS -
COMPONENTS FOR GAS EXTINGUISHING
SYSTEMS - PART 8: REQUIREMENTS AND
TEST METHODS FOR CONNECTORS**

National Standards
Authority of Ireland
Glasnevin, Dublin 9
Ireland

Tel: +353 1 807 3800
Fax: +353 1 807 3838
<http://www.nsai.ie>

Sales
<http://www.standards.ie>

*This Irish Standard was
published under the
authority of the National
Standards Authority of
Ireland and comes into
effect on:
7 July 2006*

**NO COPYING WITHOUT NSAI
PERMISSION EXCEPT AS
PERMITTED BY COPYRIGHT
LAW**

© NSAI 2006

Price Code H

Údarás um Chaighdeán Náisiúnta na hÉireann

EUROPEAN STANDARD

EN 12094-8

NORME EUROPÉENNE

EUROPÄISCHE NORM

April 2006

ICS 13.220.20

Supersedes EN 12094-8:1998

English Version

Fixed firefighting systems - Components for gas extinguishing systems - Part 8: Requirements and test methods for connectors

Installations fixes de lutte contre l'incendie - Éléments constitutifs des installations d'extinction à gaz - Partie 8: Exigences et méthodes d'essai pour raccords

Ortsfeste Brandbekämpfungsanlagen - Bauteile für Löschanlagen mit gasförmigen Löschmitteln - Teil 8: Anforderungen und Prüfverfahren für Verbindungen

This European Standard was approved by CEN on 9 March 2006.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents	Page
Foreword	3
Introduction	5
1 Scope	6
2 Normative references	6
3 Terms and definitions	6
4 Requirements.....	7
4.1 General design.....	7
4.2 Connection threads.....	8
4.3 Resistance to leakage.....	8
4.4 Resistance to bursting.....	8
4.5 Resistance of type 2 and type 4 connectors to pressure and heat	8
4.6 Resistance of type 2 and type 4 connectors to heat and cold shock.....	9
4.7 Resistance of flexible connectors to cold	9
4.8 Resistance of type 2 connectors to flexing	9
4.9 Documentation	9
5 Type test methods	10
5.1 Conditions	10
5.2 Samples	10
5.3 Compliance.....	11
5.4 Test for resistance to leakage	11
5.5 Test for resistance to bursting	11
5.6 Test for resistance of type 2 and type 4 connectors to pressure and heat	12
5.7 Test for resistance of type 2 and type 4 connectors to heat and cold shock	12
5.8 Test for resistance of flexible connectors to cold.....	12
5.9 Test for resistance of type 2 connectors to flexing.....	12
6 Marking	12
7 Evaluation of conformity	13
7.1 General	13
7.2 Initial type testing.....	13
7.3 Factory production control (FPC).....	14
Annex ZA (informative) Clauses of this European Standard addressing the provisions of the Construction Products Directive	18
ZA.1 Scope and relevant characteristics	18
ZA.2 Procedure for the attestation of conformity of connectors	19
ZA.3 CE Marking and labelling.....	20
Bibliography.....	22

Foreword

This European Standard (EN 12094-8:2006) has been prepared by Technical Committee CEN/TC 191 "Fixed firefighting systems", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2006, and conflicting national standards shall be withdrawn at the latest by April 2009.

This European Standard supersedes EN 12094-8:1998.

This European Standard has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA, which is an integral part of this European Standard.

This European Standard is part of a series concerned with gas extinguishing system components.

The following European Standards are planned to cover:

- gas extinguishing systems (EN 12094),
- sprinkler systems (EN 12259 and EN 12845),
- powder systems (EN 12416),
- explosion protection systems (EN 26184),
- foam systems (EN 13565),
- hose systems (EN 671),
- smoke and heat control systems (EN 12101),
- water spray systems (EN 14816).

This standard has the general title "Fixed firefighting systems – Components for gas extinguishing systems" and will consist of the following parts:

- Part 1: Requirements and test methods for electrical automatic control and delay devices,
- Part 2: Requirements and test methods for non-electrical automatic control and delay devices,
- Part 3: Requirements and test methods for manual triggering and stop devices,
- Part 4: Requirements and test methods for container valve assemblies and their actuators,
- Part 5: Requirements and test methods for high and low pressure selector valves and their actuators,
- Part 6: Requirements and test methods for non-electrical disable devices,
- Part 7: Requirements and test methods for nozzles for CO₂ systems,

EN 12094-8:2006 (E)

- Part 8: Requirements and test methods for connectors,
- Part 9: Requirements and test methods for special fire detectors,
- Part 10: Requirements and test methods for pressure gauges and pressure switches,
- Part 11: Requirements and test methods for mechanical weighing devices,
- Part 12: Requirements and test methods for pneumatic alarm devices,
- Part 13: Requirements and test methods for check valves and non-return valves,
- Part 16: Requirements and test methods for odorizing devices for CO₂ low pressure systems,
- Part 20: Requirements and test methods for the compatibility of components.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

Introduction

It has been assumed in the preparation of this European Standard that the execution of its provisions is entrusted to appropriately qualified and experienced people.

All pressure data in this European Standard are given as gauge pressures in bar, unless otherwise stated.

NOTE 1 bar = 10^5 N m^{-2} = 100 kPa.

EN 12094-8:2006 (E)

1 Scope

This European Standard specifies requirements and describes test methods for flexible and rigid connectors used in CO₂ -, Inert Gas- or Halocarbon gas fire extinguishing systems.

This European Standard is applicable to connectors used:

- between container valves and the manifold (type 1 and type 5 connector);
- in pneumatic pilot lines (type 3 connector);
- in distribution pipework of fire extinguishing installations downstream of the manifold/selector valve (type 2 or type 4 connector).

2 Normative references

The following referenced documents are indispensable for the application of this European Standard. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN ISO 9001:2000, *Quality management systems — Requirements (ISO 9001:2000)*

3 Terms and definitions

For the purposes of this European Standard, the following terms and definitions apply.

3.1

CO₂-high-pressure installation

fire extinguishing installation in which the CO₂ is stored at ambient temperature. For example, the pressure of the CO₂ in storage is $p_{abs} = 58,6$ bar at 21 °C

3.2

CO₂-low-pressure installation

fire extinguishing installation in which the CO₂ is stored at low temperature, normally -19 °C to -21 °C

3.3

fill ratio

mass of extinguishing medium related to the net capacity of a container expressed as kilograms per litre (kg/l)

3.4

connector

component that joins two parts

3.5

Halocarbon Gas

extinguishing agent that contains as primary components one or more organic compounds containing one or more of the elements fluorine, chlorine, bromine or iodine

3.6

Halocarbon Gas installation

fire extinguishing installation in which the Halocarbon Gas is stored at ambient temperature

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-