



National Standards Authority of Ireland

IRISH STANDARD

I.S. EN 12094-6:2006

ICS 13.220.20

**FIXED FIREFIGHTING SYSTEMS -
COMPONENTS FOR GAS EXTINGUISHING
SYSTEMS - PART 6: REQUIREMENTS AND
TEST METHODS FOR NONELECTRICAL
DISABLE DEVICES**

National Standards
Authority of Ireland
Glasnevin, Dublin 9
Ireland

Tel: +353 1 807 3800
Fax: +353 1 807 3838
<http://www.nsai.ie>

Sales
<http://www.standards.ie>

*This Irish Standard was
published under the
authority of the National
Standards Authority of
Ireland and comes into
effect on:
7 July 2006*

**NO COPYING WITHOUT NSAI
PERMISSION EXCEPT AS
PERMITTED BY COPYRIGHT
LAW**

© NSAI 2006

Price Code I

Údarás um Chaighdeán Náisiúnta na hÉireann

EUROPEAN STANDARD

EN 12094-6

NORME EUROPÉENNE

EUROPÄISCHE NORM

April 2006

ICS 13.220.20

Supersedes EN 12094-6:2000

English Version

Fixed firefighting systems - Components for gas extinguishing systems - Part 6: Requirements and test methods for non-electrical disable devices

Installations fixes de lutte contre l'incendie - Éléments constitutifs des installations d'extinction à gaz - Partie 6: Exigences et méthodes d'essai pour dispositifs non électriques de mise hors service

Ortsfeste Brandbekämpfungsanlagen - Bauteile für Löschanlagen mit gasförmigen Löschmitteln - Teil 6: Anforderungen und Prüfverfahren für nicht-elektrische Blockiereinrichtungen

This European Standard was approved by CEN on 9 March 2006.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents	Page
Foreword	3
Introduction	5
1 Scope	6
2 Normative references	6
3 Terms and definitions	6
4 Requirements	7
4.1 General design	7
4.2 Disabling valves	8
4.3 Disable devices other than valves	8
4.4 Operating force	10
4.5 Documentation	10
5 Type test methods	10
5.1 Conditions	10
5.2 Samples	11
5.3 Compliance.....	11
5.4 Function.....	11
5.5 Test for resistance to load.....	11
5.6 Determination of operational force.....	12
5.7 Test for resistance to corrosion	12
5.8 Test for resistance to stress corrosion	12
5.9 Vibration test	13
5.10 Operational reliability	13
6 Marking	13
7 Evaluation of conformity	14
7.1 General	14
7.2 Initial type testing.....	14
7.3 Factory production control (FPC).....	15
Annex ZA (informative) Clauses of this European Standard addressing the provisions of the EU Construction Products Directive	19
ZA.1 Scope and relevant characteristics	19
ZA.2 Procedure for the attestation of conformity of non-electrical disable devices	20
ZA.3 CE Marking and labelling.....	21
Bibliography	23

Foreword

This European Standard (EN 12094-6:2006) has been prepared by Technical Committee CEN/TC 191 "Fixed firefighting systems", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2006, and conflicting national standards shall be withdrawn at the latest by April 2009.

This European Standard supersedes EN 12094-6:2000.

This European Standard has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA, which is an integral part of this European Standard.

This European Standard is part of a series concerned with gas extinguishing system components.

The following European Standards are planned to cover:

- gas extinguishing systems (EN 12094),
- sprinkler systems (EN 12259 and EN 12845),
- powder systems (EN 12416),
- explosion protection systems (EN 26184),
- foam systems (EN 13565),
- hose systems (EN 671),
- smoke and heat control systems (EN 12101),
- water spray systems (EN 14816).

This standard has the general title "Fixed firefighting systems – Components for gas extinguishing systems" and will consist of the following parts:

- Part 1: Requirements and test methods for electrical automatic control and delay devices,
- Part 2: Requirements and test methods for non-electrical automatic control and delay devices,
- Part 3: Requirements and test methods for manual triggering and stop devices,
- Part 4: Requirements and test methods for container valve assemblies and their actuators,
- Part 5: Requirements and test methods for high and low pressure selector valves and their actuators,
- Part 6: Requirements and test methods for non-electrical disable devices,
- Part 7: Requirements and test methods for nozzles for CO₂ systems,

EN 12094-6:2006 (E)

- Part 8: Requirements and test methods for connectors,
- Part 9: Requirements and test methods for special fire detectors,
- Part 10: Requirements and test methods for pressure gauges and pressure switches,
- Part 11: Requirements and test methods for mechanical weighing devices,
- Part 12: Requirements and test methods for pneumatic alarm devices,
- Part 13: Requirements and test methods for check valves and non-return valves,
- Part 16: Requirements and test methods for odorizing devices for CO₂ low pressure systems,
- Part 20: Requirements and test methods for the compatibility of components.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

Introduction

It has been assumed in the preparation of this European Standard that the execution of its provisions is entrusted to appropriately qualified and experienced people.

All pressure data in this European Standard are given as gauge pressures in bar, unless otherwise stated.

NOTE 1 bar = 10^5 N m^{-2} = 100 kPa.

EN 12094-6:2006 (E)

1 Scope

This European Standard specifies requirements and test methods for non-electrical disable devices for CO₂, Inert gas- or Halocarbon gas fire extinguishing systems.

Examples are:

- a) an isolating valve in the pipework to the flooding zone or in a pneumatic pilot line;
- b) a device blocking the actuator at the bank of containers or the container valve in single-zone installations or the actuator of selector valves in multiple-zone installations.

2 Normative references

The following referenced documents are indispensable for the application of this European Standard. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 12094-5, *Fixed firefighting systems — Components for gas extinguishing systems — Part 5: Requirements and test methods for high and low pressure selector valves and their actuators*

EN 60068-2-6:1995, *Environmental testing — Part 2: Tests — Tests Fc: Vibration (sinusoidal) (IEC 60068-2-6:1995 + Corrigendum 1995)*

EN ISO 9001:2000, *Quality management systems — Requirements (ISO 9001:2000)*

3 Terms and definitions

For purposes of this European Standard, the following terms and definitions apply.

3.1

activated condition

condition when the system operates after alarm

3.2

actuator

component which causes a valve to operate

3.3

CO₂-high-pressure installation

fire extinguishing installation in which the CO₂ is stored at ambient temperature. For example, the pressure of the CO₂ in storage is $p_{abs} = 58,6$ bar at 21 °C

3.4

CO₂-low-pressure installation

fire extinguishing installation in which the CO₂ is stored at low temperature, normally –19 °C to –21 °C

3.5

disabled state

state of the non-electrical disable device, when operated and disabling the release of the extinguishing agent into the flooding zone

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-