



National Standards Authority of Ireland

STANDARD

ENV 1363-3:1999

ICS 13.220.50

National Standards
Authority of Ireland
Dublin 9
Ireland

Tel: (01) 807 3800
Fax: (01) 807 3838

FIRE RESISTANCE TESTS -

PART 3: VERIFICATION OF FURNACE

PERFORMANCE

*This Irish Standard was
published under the
authority of the National
Standards Authority of
Ireland
and comes into effect on:
April 8, 1999*

**NO COPYING WITHOUT NSAI
PERMISSION EXCEPT AS
PERMITTED BY COPYRIGHT
LAW**

© NSAI 1999

Price Code H

Údarás um Chaighdeán Náisiúnta na hÉireann

EUROPEAN PRESTANDARD
PRÉNORME EUROPÉENNE
EUROPÄISCHE VORNORM

ENV 1363-3

December 1998

ICS 13.220.50

Descriptors: buildings, structural members, fire resistance, fire tests, verification

English version

**Fire resistance tests - Part 3: Verification of furnace
performance**

This European Prestandard (ENV) was approved by CEN on 5 December 1998 as a prospective standard for provisional application.

The period of validity of this ENV is limited initially to three years. After two years the members of CEN will be requested to submit their comments, particularly on the question whether the ENV can be converted into a European Standard.

CEN members are required to announce the existence of this ENV in the same way as for an EN and to make the ENV available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force (in parallel to the ENV) until the final decision about the possible conversion of the ENV into an EN is reached.

CEN members are the national standards bodies of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Central Secretariat: rue de Stassart, 36 B-1050 Brussels

Contents	Page
Foreword	3
Introduction	4
1 Scope	5
2 Normative references	5
3 Definitions	5
4 Test equipment	5
5 Test conditions	6
6 Measuring elements	6
7 Installation of measuring element	7
8 Conditioning	7
9 Application of instrumentation	7
10 Test procedure	8
11 Verification criteria	8
12 Report	10
Annex A (Informative) Additional measurements	11

Foreword

This European Prestandard has been prepared by Technical Committee CEN/TC 127 "Fire safety in buildings", the secretariat of which is held by BSI.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to announce this European Prestandard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

Introduction

The general requirements for fire resistance testing including the specifications of the apparatus to be used are given in EN1363-1. However, the specification for the thermal exposure provided by fire resistance furnaces only requires that they are able to follow a defined temperature-time relationship when controlled with thermocouples of a prescribed type. In order to have a reproducible test method, it is important that the thermal exposures produced by fire resistance furnaces of different design are within defined limits. The purpose of this document is to verify the thermal exposure performance of furnaces used for the fire resistance testing of separating elements.

In addition to verifying the thermal exposure in furnaces, the procedure also verifies that the static pressure distribution in the furnace is within defined limits and the oxygen concentration are within the limits given in EN 1363-1. Variations in pressure and oxygen content will affect the integrity measurements when using the cotton pad and variations in oxygen content will also affect the rate of combustion of combustible test specimens.

The verification procedure is performed using an arrangement of measuring elements mounted within a supporting construction. The measuring elements consist of two steel plates separated by insulation. The test construction is exposed to the standard heating and pressure conditions given in EN 1363-1 for 60 minutes and measurements are made of the exposed face temperature of the steel plate of the measuring elements. In addition measurements are also made in the furnace of the static pressure distribution at several positions and of the oxygen concentration.

The thermal exposure performance of the furnace is deemed acceptable if the measurements obtained from the measuring elements and the static pressure distribution are within defined limits and the oxygen concentration is within the limits given in EN 1363-1.

Caution

The attention of all persons concerned with managing and carrying out fire resistance tests is drawn to the fact that fire testing may be hazardous and that there is a possibility that toxic and/or harmful smoke and gases may be evolved during the test. Mechanical and operational hazards may also arise during the construction of the test elements or structures, their testing and disposal of test residues.

An assessment of all potential hazards and risks to health shall be made and safety precautions shall be identified and provided. Written safety instructions shall be issued. Appropriate training shall be given to relevant personnel. Laboratory personnel shall ensure that they follow written safety instructions at all times.

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-