



National Standards Authority of Ireland

IRISH STANDARD

I.S. 202:Part 10:2003

ICS 29.060.20

**CABLES OF RATED VOLTAGES UP TO AND
INCLUDING 450/750V AND HAVING
CROSS-LINKED INSULATION
PART 10: EPR INSULATED AND
POLYURETHANE SHEATHED FLEXIBLE
CABLES**

National Standards
Authority of Ireland
Dublin 9
Ireland

Tel: (01) 807 3800
Tel: (01) 807 3838

*This Irish Standard was
published under the
authority of the National
Standards Authority of
Ireland
and comes into effect on:
October 10, 2003*

**NO COPYING WITHOUT NSAI
PERMISSION EXCEPT AS
PERMITTED BY COPYRIGHT
LAW**

© NSAI 2003

Price Code H

Údarás um Chaighdeán Náisiúnta na hÉireann

CONTENTS

	Page
Declaration	2
Foreword	3
1. Scope	4
2. Normative	4
3. EPR insulated and polyurethane sheathed flexible cable (300/500V)	
3.1 Code designation	4
3.2 Rated voltage	4
3.3 Construction	4
3.4 Tests	5
3.5 Guide to use	5
4. EPR insulated and polyurethane sheathed flexible cable (450/750V)	
4.1 Code designation	8
4.2 Rated voltage	8
4.3 Construction	8
4.4 Tests	9
4.5 Guide to use	9
Annex A Requirements and additional test methods for polyurethane sheath (Normative)	13
Annex B Bibliography (Informative)	19
Tables	
I Dimensions of type H05BQ-F	6
II Tests for type H05BQ-F	7
III Dimensions of type H07BQ-F	10
IV Tests for type H07BQ-F	11

I.S. 202:Part 10:2003

DECLARATION
OF
SPECIFICATION
ENTITLED

CABLES OF RATED VOLTAGES UP TO AND INCLUDING 450/750V AND HAVING CROSS-LINKED
INSULATION

PART 10: EPR INSULATED AND POLYURETHANE SHEATHED FLEXIBLE CABLES

AS

THE IRISH STANDARD SPECIFICATION FOR

CABLES OF RATED VOLTAGES UP TO AND INCLUDING 450/750V AND HAVING CROSS-LINKED
INSULATION

PART 10: EPR INSULATED AND POLYURETHANE SHEATHED FLEXIBLE CABLES

NSAI in exercise of the power conferred by section 16 (5) of the National Standards Authority of Ireland Act, 1996 (No. 28 of 1996) and with the consent of the Minister for Enterprise Trade and Employment, hereby declares as follows:

1. This instrument may be cited as the Standard Specification (Cables of rated voltages up to and including 450/750V and having cross-linked insulation Part 10: EPR Insulated and Polyurethane Sheathed Flexible Cables) Declaration, 2003.
2. (1) The Specification set forth in the Schedule to this declaration is hereby declared to be the standard specification for Cables of rated voltages up to and including 450/750V and having cross-linked insulation Part 10: EPR Insulated and Polyurethane Sheathed Flexible Cables.
(2) The said standard specification maybe cited as Irish Standard 202:Part 10:2003 or as I.S. 202:Part 10:2003.
3. (1) The Standard Specification, Rubber Insulated Cable and Flexible Cords of Rated Voltage up to and including 450/750V Declaration 1989, is hereby revoked.
(2) Reference in any other standard specification to the Instrument hereby revoked and to Irish Standard 202:1989 thereby prescribed, shall be construed, respectively, as references to this Instrument and to Irish Standard 202:2003.

FOREWORD

The Irish Standard Specification I.S. 202 Part 10:2003, was prepared by the National Standards Authority of Ireland on the basis of a submission from Technical Committee No. 14 which is a Technical Subcommittee of the Electro-Technical Council of Ireland. The ETCI is the national body responsible for the harmonization of standards in the field of electro-technology and represents Ireland in IEC and CENELEC.

I.S. 202 now has the following parts:

- I.S. 202:Part 1 General requirements
- I.S. 202:Part 2 Test methods
- I.S. 202:Part 3 Heat resistant silicone rubber insulated cables
- I.S. 202:Part 4 Cords and flexible cables
- I.S. 202:Part 5 (Spare)
- I.S. 202:Part 6 Arc welding cables
- I.S. 202:Part 7 Cables with increased heat resistance for internal wiring for a conductor temperature of 110°C
- I.S. 202:Part 8 Polychloroprene or equivalent synthetic elastomer sheathed cable for use as decorative chains
- I.S. 202:Part 9 Single core non-sheathed cables for fixed wiring having low emission of smoke and corrosive gases
- I.S. 202:Part 10 EPR insulated and polyurethane sheathed flexible cables
- I.S. 202:Part 11 EVA cords and flexible cables
- I.S. 202:Part 12 Heat resistant EPR cords and flexible cables
- I.S. 202:Part 13 Single and multicore flexible cables, insulated and sheathed with crosslinked compound and having low emission of smoke and corrosive gases
- I.S. 202:Part 14 Cords for applications requiring high flexibility
- I.S. 202:Part 15 - Multicore cables insulated and shielded with heat-resistant silicone rubber
- I.S. 202:Part 16 - Water resistant polychloroprene or equivalent synthetic elastomer sheathed cables

In order that this revision of Part 10 of I.S. 202 does not introduce unnecessary changes to long-established clause numbers, the Normative References (which would otherwise be inserted as clause 2) are given in Annex A.

I.S. 202:Part 10:2003

Schedule
Cables of Rated Voltages up to and including 450/750V and having cross-linked insulation
Part 10 : EPR Insulated and Polyurethane Sheathed Flexible Cable

1. Scope

This Part 10 of the Standard details the particular requirements for ethylene-propylene rubber insulated, and thermoplastic polyurethane sheathed cable for a maximum conductor temperature of 90°C and lowest handling temperature of -40°C.

Each cable shall comply with the appropriate requirements given in Part 1 of this HD and the particular requirements of this Part.

NOTE 1: The sheath specified in this Part of I.S. 202 is unvulcanised. The requirements and special additional test methods are therefore included as Annex A to this Part.

NOTE 2: The overall dimensions of the cables in this Part of I.S. 202 have been calculated in accordance with EN 60719.

2. Normative references

I.S. 202:Part 10 incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to, or revisions of, any of these publications apply to I.S. 202:Part 10 only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies.

I.S. 270 Conductors of insulated cables (Endorsing IEC 228 and 228A)

I.S. EN 60811 *Series* Insulating and sheathing materials of electric and optical cables - Common test methods

I.S. EN 60719 Calculation of the lower and upper limits for the average outer dimensions of cables with circular copper conductors and of rated voltages up to and including 450/750V

3. EPR insulated and polyurethane sheathed flexible cable (300/500V)

3.1 Code designation

H05BQ-F

3.2 Rated voltage

300/500V

3.3 Construction

3.3.1 Conductor

Number of conductors: 2, 3, 4 or 5.

The conductors shall be in accordance with the requirements given in I.S. 270 for Class 5 conductors. The wires may be plain or tinned.

3.3.2 Separator

A separator of suitable material may be applied around each conductor.

3.3.3 Insulation

The insulation shall be rubber compound of Type EI 6 applied around each conductor.

The insulation shall be applied by extrusion.

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-