



National Standards Authority of Ireland

STANDARD

I.S. EN 1366-8:2004

ICS 13.220.50

National Standards
Authority of Ireland
Dublin 9
Ireland

Tel: (01) 807 3800
Fax: (01) 807 3838

FIRE RESISTANCE TESTS FOR SERVICE

INSTALLATIONS - PART 8: SMOKE

EXTRACTION DUCTS

*This Irish Standard was
published under the
authority of the National
Standards Authority of
Ireland
and comes into effect on:
October 26, 2004*

**NO COPYING WITHOUT NSAI
PERMISSION EXCEPT AS
PERMITTED BY COPYRIGHT
LAW**

© NSAI 2004

Price Code L

Údarás um Chaighdeáin Náisiúnta na hÉireann

EUROPEAN STANDARD

EN 1366-8

NORME EUROPÉENNE

EUROPÄISCHE NORM

July 2004

ICS 13.220.50

English version

Fire resistance tests for service installations - Part 8: Smoke extraction ducts

Essai de résistance au feu des installations de service -
Partie 8: Conduits d'extraction de fumées

Feuerwiderstandsprüfungen für Installationen - Teil 8:
Entrauchungsleitungen

This European Standard was approved by CEN on 1 April 2004.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents

	Page
Foreword	4
Introduction	5
1 Scope	6
2 Normative references	6
3 Terms and definitions	7
4 Test equipment	7
4.1 General	7
4.2 Furnace	7
4.3 Perforated plate	7
4.4 Inlet nozzles	9
4.5 Ambient temperature leakage measuring device	9
4.6 Pressure sensors for differential pressure control	9
4.7 Welded connecting tube	9
4.8 Extraction fan connecting duct	9
4.9 Extraction fan	9
4.10 Thermocouples	9
4.11 Surface thermocouples	9
4.12 Oxygen measuring equipment	10
4.13 Restraining equipment	10
4.14 Observation window	10
5 Test conditions	10
6 Test specimen	10
6.1 Size	10
6.2 Number	11
6.3 Design	11
7 Installation of test specimen	11
7.1 General	11
7.2 Standard supporting construction	11
7.3 Duct arrangement	12
7.4 Restraint of ducts	12
7.5 Perforated plate	13
8 Conditioning	13
8.1 General	13
8.2 Hygroscopic sealing materials	13
9 Application of instrumentation	13
9.1 Thermocouples	13
9.2 Pressure	13
9.3 Oxygen measurements	14
9.4 Observations on reduction of cross-section	14
10 Test procedure	14
10.1 Pre-test calibration	14
10.2 Leakage measurement at ambient temperature	14
10.3 Fire test	15

11	Performance criteria	16
11.1	General requirements	16
11.2	Criteria at ambient temperature.....	16
11.3	Criteria under fire conditions.....	17
12	Test report	17
13	Direct field of application of test results	18
13.1	General.....	18
13.2	Vertical and horizontal ducts	18
13.3	Sizes of ducts	18
13.4	Pressure difference.....	19
13.5	Number of sides of duct.....	19
	Figure 6 – Arrangement of gas-testing probes.....	25
	Annex A (informative) Surface temperature and volume/mass flow measurements	33
	Bibliography	37

EN 1366-8:2004 (E)

Foreword

This document (EN 1366-8:2004) has been prepared by Technical Committee CEN/TC 127 'Fire safety in buildings', the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by January 2005, and conflicting national standards shall be withdrawn at the latest by January 2005.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of the Construction Products Directive.

EN 1366 '*Fire resistance tests for service installations*' consists of the following Parts:

Part 1: Ducts

Part 2: Fire dampers

Part 3: Penetration seals

Part 4: Linear joint seals (in course of preparation)

Part 5: Service ducts and shafts

Part 6: Raised access and hollow core floors (in course of preparation)

Part 7: Conveyor systems and their closures

Part 8: Smoke extraction ducts

Part 9: Single compartment smoke extraction ducts (in course of preparation)

Part 10: Smoke control dampers (in course of preparation)

Part 11: Fire protective systems for essential services (in course of preparation).

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-