



NSAI
Standards

Irish Standard
I.S. EN 50483-4:2009

Test requirements for low voltage aerial bundled cable accessories -- Part 4: Connectors

I.S. EN 50483-4:2009

Incorporating amendments/corrigenda issued since publication:

<i>This document replaces:</i>	<i>This document is based on:</i> EN 50483-4:2009	<i>Published:</i> 30 January, 2009
This document was published under the authority of the NSAI and comes into effect on: 22 April, 2009		ICS number: 29.240.20
NSAI 1 Swift Square, Northwood, Santry Dublin 9	T +353 1 807 3800 F +353 1 807 3838 E standards@nsai.ie W NSAI.ie	Sales: T +353 1 857 6730 F +353 1 857 6729 W standards.ie
Price Code: N		
Údarás um Chaighdeáin Náisiúnta na hÉireann		

EUROPEAN STANDARD

EN 50483-4

NORME EUROPÉENNE

EUROPÄISCHE NORM

January 2009

ICS 29.240.20

English version

Test requirements for low voltage aerial bundled cable accessories - Part 4: Connectors

Prescriptions relatives aux essais
des accessoires pour réseaux aériens
basse tension torsadés -
Partie 4: Connecteurs

Prüfanforderungen für Bauteile für
isolierte Niederspannungsfreileitungen -
Teil 4: Verbinder

This European Standard was approved by CENELEC on 2008-12-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: avenue Marnix 17, B - 1000 Brussels

Foreword

This European Standard was prepared by a sub-group of WG 11 of the Technical Committee CENELEC TC 20, Electric cables.

The text of the draft was submitted to the formal vote and was approved by CENELEC as EN 50483-4 on 2008-12-01.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2009-12-01
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2011-12-01

This is Part 4 of CENELEC standard EN 50483 “*Test requirements for low voltage aerial bundled cable accessories*”, which has six parts:

- Part 1: Generalities;
 - Part 2: Tension and suspension clamps for self supporting system;
 - Part 3: Tension and suspension clamps for neutral messenger system;
 - Part 4: Connectors;
 - Part 5: Electrical ageing test;
 - Part 6: Environmental testing.
-

Contents

1	Scope	4
2	Normative references.....	4
3	Terms and definitions	4
4	Symbols	6
5	Characteristics.....	6
6	Marking	6
7	General test conditions	7
7.1	Generalities	7
7.2	Preconditioning of ABC	7
8	Type tests.....	8
8.1	IPC tests	8
8.2	Pre-insulated through connectors (sleeve)	25
8.3	Pre-insulated terminals (lugs)	37
	Annex A (informative) Temporary connectors – Temperature rise and overload test.....	43
	Bibliography	47
	Figures	
	Figure 1 – Test arrangement	10
	Figure 2 – Typical impact test arrangement	14
	Figure 3 – Illustrative arrangement for dielectrical test in water	16
	Figure 4 – Arrangement for dielectrical test in metallic balls	17
	Figure 5 – Typical arrangement for dielectrical test with metallic gauze	18
	Figure 6 – Test arrangement for the water tightness test	20
	Figure 7 – Orientation of the samples for the climatic ageing test.....	24
	Figure 8 – Illustrative installation of the mechanical test.....	26
	Figure 9 – Illustrative set up for dielectrical voltage test	28
	Figure 10 – Climatic ageing test arrangement.....	31
	Figure 11 – Illustrative set up of the testing assembly	33
	Figure 12 – Diagram of thermal cycles and mechanical stresses applied on phase conductor.....	34
	Figure 13 – Diagram of thermal cycles and mechanical loads on neutral conductor	36
	Figure 14 – Illustrative installation of the mechanical test.....	38
	Figure 15 – Illustrative figure of immersed lug	39
	Figure 16 – Illustrative arrangement of immersion test in sodium hydroxide solution	42
	Figure A.1 – Example of a pin connection	44
	Figure A.2 – Test loop	45
	Tables	
	Table 1 – Initial loads required for marking	26
	Table 2 – Test loads.....	26
	Table 3 – Applied tensile load.....	36
	Table 4 – Tensile loads	38

1 Scope

EN 50483 series applies to overhead line fittings for tensioning, supporting and connecting aerial bundled cables (ABC) of rated voltage U_0/U (U_m): 0,6/1 (1,2) kV.

This Part 4 applies to connectors used for the electrical connection of ABC.

The connectors are designed to be installed on ABC defined in HD 626.

Tests described in this document are type tests.

NOTE This European Standard does not invalidate existing approvals of products achieved on the basis of national standards and specifications and/or the demonstration of satisfactory service performance. However, products approved according to such national standards or specifications cannot directly claim approval to this European Standard. It may be possible, subject to agreement between supplier and purchaser, and/or the relevant conformity assessment body, to demonstrate that conformity to the earlier standard can be used to claim conformity to this standard, provided an assessment is made of any additional type testing that may need to be carried out. Any such additional testing that is part of a sequence of testing cannot be done separately.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50182:2001, *Conductors for overhead lines – Round wire concentric lay stranded conductors*

EN 50483 series, *Test requirements for low voltage aerial bundled cable accessories*

EN 60529:1991, *Degrees of protection provided by enclosures (IP Code)* (IEC 60529:1989)

HD 626, *Overhead distribution cables of rated voltage U_0/U (U_m): 0,6/1 (1,2) kV*

IEC 60050-461, *International Electrotechnical Vocabulary (IEV) – Part 461: Electric cables*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60050-461 and the following apply.

3.1

aerial bundled cable (ABC)

aerial cable consisting of a group of insulated conductors which are twisted together including, or not, a non insulated conductor

[IEV 461-08-02, modified]

NOTE The terms bundled conductors, bundled cables, bundled cores, conductor bundles and bundle could be used as equivalent to the term aerial bundled cable (ABC).

3.2

aerial-insulated-cable

insulated cable designed to be suspended overhead and outdoors

[IEV 461-08-01]

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-