

National Standards Authority of Ireland

CAPACITANCE GRADED OUTDOOR

IMMERSED TRANSFORMERS

BUSHING 52 KV UP TO 420 KV FOR OIL

IRISH STANDARD

I.S. CLC/TS 50458:2006

ICS 29.080.20

National Standards Authority of Ireland Glasnevin, Dublin 9 Ireland

Tel: +353 1 807 3800 Fax: +353 1 807 3838 http://www.nsai.ie

Sales http://www.standards.ie

This Irish Standard was published under the authority of the National Standards Authority of Ireland and comes into effect on: June 2, 2006

NO COPYING WITHOUT NSAI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW

© NSAI 2006

Price Code K

Údarás um Chaighdeáin Náisiúnta na hÉireann

This is a free page sample. Access the full version online.

TECHNICAL SPECIFICATION SPÉCIFICATION TECHNIQUE TECHNISCHE SPEZIFIKATION

CLC/TS 50458

April 2006

ICS 29.080.20

English version

Capacitance graded outdoor bushing 52 kV up to 420 kV for oil immersed transformers

Traversées à répartition capacitive immergées d'extérieur, 52 kV à 420 kV pour transformateurs immergés dans l'huile Kapazitiv gesteuerte Freiluftdurchführungen 52 kV bis 420 kV für ölgefüllte Transformatoren

This Technical Specification was approved by CENELEC on 2005-10-15.

CENELEC members are required to announce the existence of this TS in the same way as for an EN and to make the TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization Comité Européen de Normalisation Electrotechnique Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

© 2006 CENELEC - All rights of exploitation in any form and by any means reserved worldwide for CENELEC members.

Foreword

This Technical Specification was prepared by the Technical Committee CENELEC TC 36A, Insulated bushings.

The text of the draft was submitted to vote in accordance with Subclause 11.3.3.3 of Part 2 of the CENELEC Internal Regulations and was approved by CENELEC as CLC/TS 50458 on 2005-10-15.

The following date was fixed:

| _ | latest date by which the existence of the CLC/TS | | |
|---|--|-------|------------|
| | has to be announced at national level | (doa) | 2006-07-01 |

The purpose of this Technical Specification is to ensure the interchange ability between capacitance graded bushings, with comparable technical requirements, from different manufacturers.

The aim is, to reduce the multiplicity of the different designs, only regarding the interchange ability. The document gives recommendations for mounting flange dimensions, lower part details, current conductor connections and limits for the overall dimensions. This allows, on the one hand, the manufacturers of bushings to use normalised solutions within their own type series and on the other, the users to exchange bushings from different manufacturers and with different years of manufacture.

In the preparation of this Technical Specification information about existing types (especially details of the design and the dimensions taken mostly from catalogues of the European manufacturers) was the basis for discussion in WG 4 of TC 36A. The following restrictions were applied:

- technical aspects of the design of different manufacturers and the requirements of users must be considered for the values of the new Technical Specification regarding the state of art;
- there should be no single effort for one manufacturer or to the exclusion of another;
- no restriction for the technical evolution.

Conformance will require design changes for not only the manufacturer of the bushings but also transformers. Some changes may require significant modifications along with type tests which are time consuming and costly. Purchasers of transformers should also review its contents for its impact on their procurement process. For these reasons, this document will act as a guide or Technical Specification (TS) during a transitional period. During this period, the contents will act as a guide to manufacturers while allowing debate in the industry on its effectiveness and value. This transition period will not exceed ten years at which time its contents should be amended if necessary and submitted for approval as a European Standard.

CLC/TS 50458:2006

Contents

- 3 -

| | | | | Page | | |
|------------|---|---------------------------------|--|------|--|--|
| Introd | luctio | n | | 4 | | |
| 1 | Scope | | | | | |
| 2 | Norn | native r | eferences | 4 | | |
| 3 | Defir | initions | | | | |
| | 3.1 | 1 Draw-lead conductor | | | | |
| | 3.2 | Solid rod conductor | | | | |
| | 3.3 | Bottom | n terminal - current connection | 5 | | |
| 4 | Requirements | | | 5 | | |
| | 4.1 | Application | | | | |
| | 4.2 | Standa | 5 | | | |
| | 4.3 Standard values of rated current (I_r) | | ard values of rated current (<i>I</i> _r) | 5 | | |
| | 4.4 | Compl | iance | 5 | | |
| | | 4.4.1 | Test tap | 5 | | |
| | | 4.4.2 | Creepage distance | 5 | | |
| | | 4.4.3 | Insulating level | 5 | | |
| | | 4.4.4 | Operating conditions, test requirements | 5 | | |
| | 4.5 | Additio | onal requirements | 5 | | |
| | 4.6 Designation | | 6 | | | |
| | | 4.6.1 | Electrical design of oil end | 6 | | |
| | | 4.6.2 | Conductor principles and mechanical design of oil end | 6 | | |
| | | 4.6.3 | Conductor arrangement | 6 | | |
| | | 4.6.4 | Complete bushing designation | 7 | | |
| | 4.7 | Design | n details | 8 | | |
| Anne | хA | (inform | native) Example of bushing documentation | 17 | | |
| Figure 1 – | | Bushin | 8 | | | |
| Figure 2 – | | Bushin | 9 | | | |
| Figure | Figure 3 – Examples of current leader principles and mechanical design of oil | | bles of current leader principles and mechanical design of oil end | 10 | | |
| Figure 4 – | | Jointing of split rod conductor | | | | |
| Figure 5 – | | Example of bottom connection | | | | |
| Table | 1 – | Dimen | sions of air terminal stems according to IEC/TR 62271-301 | 8 | | |
| Table 2 – | | Dimensions | | | | |
| Table | able 3 – Two examples of data for split rod type inside the bore | | 15 | | | |

Introduction

The object of this Technical Specification is to specify details and dimensions of capacitance graded outdoor bushings for highest voltages for equipment from 52 kV up to 420 kV as far as it is necessary to ensure the interchange ability of bushings with comparable technical requirements. Additionally, some technical items are site specific, and are rarely able to be standardised, e.g. airside length of a bushing which depends on the different air side material, shed profiles and pollution level. This Technical Specification defines additional data or information, which must be included, by the bushing or the transformer manufacturer, in the transformer manual for the purpose of interchange ability.

1 Scope

This Technical Specification is applicable to capacitance graded outdoor bushings with values of highest voltage for equipment (U_m) from 52 kV up to 420 kV and with values of rated current (I_r) up to 3 150 A and frequencies from 15 Hz up to 60 Hz for oil immersed transformers.

The major insulation of these bushings consists either of oil-impregnated or resin-impregnated paper or other suitable insulating systems.

This Technical Specification establishes essential details and dimensions to ensure interchange ability and adequate mounting of the bushings.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

| EN 60059 | 1999 | IEC standard currents (IEC 60059:1999) |
|------------------|------|---|
| EN 60076-3 | 2001 | Power transformers – Part 3: Insulation levels and dielectric tests and external clearances in air (IEC 60076-3:2000 + corrigendum Dec. 2000) |
| EN 60137 | 2003 | Insulated bushings for alternating voltages above 1 000 V (IEC 60137:2003) |
| EN 60296 | | Specification for unused mineral oil for transformers and switchgear (IEC 60296) |
| IEC 60038 | 1983 | IEC standard voltages |
| IEC 60815 | 1986 | Guide for the selection of insulators in respect of polluted conditions |
| IEC/TR 62271-301 | 2004 | High-voltage switchgear and controlgear – Part 301: Dimensional standardization of terminals |

3 Definitions

For the definitions of generally used terms in the present Technical Specification reference should be made to EN 60137.

For the purposes of this Technical Specification the following additional definitions apply:

3.1

draw-lead conductor

conductor consisting of one or more flexible leads in parallel drawn into the central tube of the major insulation body of the bushing (preferred up to 1 000 A)

3.2

solid rod or tube conductor

conductor consisting of a round rod either removable and drawn into the central tube of the major insulation body of the bushing or fixed rod or tube and not removable (preferred from 1 250 A up to 3 150 A)



This is a free preview. Purchase the entire publication at the link below:

Product Page

S Looking for additional Standards? Visit Intertek Inform Infostore

> Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation