This is a free page sample. Access the full version online.



Irish Standard I.S. EN 12350-7:2009

Testing fresh concrete - Part 7: Air content - Pressure methods

 $\ensuremath{\mathbb{C}}$ NSAI 2009 No copying without NSAI permission except as permitted by copyright law.

Incorporating amendments/corrigenda issued since publication:

<i>This document replaces:</i> I.S. EN 12350-7:2000	<i>This document is based on:</i> EN 12350-7:2009 EN 12350-7:2000	<i>Publist</i> 8 April 28 July	, 2009	
This document was published under the authority of the NSAI and comes into effect on: 3 July, 2009				
Northwood, Santry F +3 Dublin 9 E st		. 857 6730 . 857 6729 ards.ie	Price Code: I	
Údarás um Chaighdeáin Náisiúnta na hÉireann				

EUROPEAN STANDARD

EN 12350-7

EUROPÄISCHE NORM

NORME EUROPÉENNE

April 2009

ICS 91.100.30

Supersedes EN 12350-7:2000

English Version

Testing fresh concrete - Part 7: Air content - Pressure methods

Essais pour béton frais - Partie 7 : Teneur en air - Méthode de la compressibilité

Prüfung von Frischbeton - Teil 7: Luftgehalte -Druckverfahren

This European Standard was approved by CEN on 20 January 2009.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

© 2009 CEN All rights of exploitation in any form and by any means reserved worldwide for CEN national Members.

Ref. No. EN 12350-7:2009: E

EN 12350-7:2009 (E)

Contents

Page

Forewo	ord	3
1	Scope	5
2	Normative references	5
3	Principles	5
4	Water column method	5
5	Pressure gauge method	9
6	Calculation and expression of results	13
7	Test report	14
8	Precision	14
Annex	A (Normative) Aggregate correction factor – water column method	16
Annex	B (Normative) Aggregate correction factor – pressure gauge method	18
Annex	C (Normative) Calibration of apparatus – water column method	20
Annex	D (Normative) Calibration of apparatus – pressure gauge method	23

Foreword

This document (EN 12350-7:2009) has been prepared by Technical Committee CEN/TC 104 "Concrete and related products", the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2009, and conflicting national standards shall be withdrawn at the latest by October 2009.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 12350-7:2000.

The results of a laboratory inter-comparison, in part funded by the EC under Measurement and Testing Programme, Contract MAT1-CT-94-0043 which investigated these two methods of measuring air content, did not find significant difference between them. However, it was found in this programme that the use of an internal vibrator to compact specimens of air entrained fresh concrete should only be done with caution, if loss of entrained air is to be avoided.

The determination of the aggregate correction value for the two methods has been included in normative Annexes A and B.

The method of calibrating the two types of apparatus has been included in normative Annexes C and D.

This standard is one of a series concerned with testing fresh concrete.

This series EN 12350 includes the following parts.

EN 12350 Testing fresh concrete

Part 1: Sampling;

Part 2: Slump-test;

Part 3: Vebe test;

- Part 4: Degree of compactability;
- Part 5: Flow table test;

Part 6: Density;

Part 7: Air content — Pressure methods;

Part 8: Self-compacting concrete - Slump-flow test (in preparation);

Part 9: Self-compacting concrete - V-funnel test (in preparation);

Part 10: Self-compacting concrete - L-box test (in preparation);

- Part 11: Self-compacting concrete Sieve segregation test (in preparation);
- Part 12: Self-compacting concrete J-ring test (in preparation).

CAUTION — When cement is mixed with water, alkali is released. Take precautions to avoid dry cement entering the eyes, mouth and nose whilst mixing concrete. Prevent skin contact with wet cement or concrete by wearing suitable protective clothing. If cement or concrete enters the eye, immediately wash it out thoroughly with clean water and seek medical treatment without delay. Wash wet concrete off the skin immediately

The following amendments have been made to the 2000-04 edition of this standard:

- editorial revision
- detailing and clarification of filling and compacting procedures of concrete in the container

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

1 Scope

This European Standard describes two methods for determination of air content of compacted fresh concrete, made with normal weight or relatively dense aggregate of maximum size up to 63 mm.

NOTE Neither method is applicable to concretes made with lightweight aggregates, air cooled blast-furnace slag, or aggregates with high porosity, because of the magnitude of the aggregate correction factor, compared with the entrained air content of the concrete.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 12350-1, Testing fresh concrete – Part 1: Sampling

EN 12350-6, Testing fresh concrete – Part 6: Density

3 Principles

3.1 General

There are two test methods, both of which use apparatus which employ the principle of Boyle-Mariotte's law. For the purpose of reference, the two methods are referred to as the water column method and the pressure gauge method and the apparatus as a water column meter and a pressure gauge meter.

3.2 Water column method

Water is introduced to a predetermined height above a sample of compacted concrete of known volume in a sealed container and a predetermined air pressure is applied over the water. The reduction in volume of the air in the concrete sample is measured by observing the amount by which the water level is lowered, the water column being calibrated in terms of percentage of air in the concrete sample.

3.3 Pressure gauge method

A known volume of air at a known pressure is merged in a sealed container with the unknown volume of air in the concrete sample. The dial on the pressure gauge is calibrated in terms of percentage of air for the resulting pressure.

4 Water column method

4.1 Apparatus

4.1.1 Water column meter, (see Figure 1), consisting of:

a) **Container**, a cylindrical vessel of steel or other hard metal, not readily attacked by cement paste, having a nominal capacity of at least 5 I and a ratio of diameter to height of not less than 0,75 nor more than 1,25. The outer rim and upper surface of the flange and the interior surfaces of the vessel shall be machined to a smooth finish. The container shall be watertight and in addition it, and the cover assembly,



This is a free preview. Purchase the entire publication at the link below:

Product Page

S Looking for additional Standards? Visit Intertek Inform Infostore

> Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation