



**NSAI**  
Standards

Irish Standard  
I.S. EN 60079-15:2010

# Explosive atmospheres -- Part 15: Equipment protection by type of protection n (IEC 60079-15:2010 (EQV))

## I.S. EN 60079-15:2010

*Incorporating amendments/corrigenda issued since publication:*

**The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:**

**I.S. xxx:** Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

**S.R. xxx:** Standard Recommendation - recommendation based on the consensus of an expert panel and subject to public consultation.

**SWIFT xxx:** A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

<i>This document replaces:</i> EN 60079-15:2005	<i>This document is based on:</i> EN 60079-15:2010 EN 60079-15:2005	<i>Published:</i> 21 May, 2010 27 October, 2005
This document was published under the authority of the NSAI and comes into effect on:  15 June, 2010		ICS number: 29.260.20
<b>NSAI</b> 1 Swift Square, Northwood, Santry Dublin 9	T +353 1 807 3800 F +353 1 807 3838 E standards@nsai.ie  W <b>NSAI.ie</b>	<b>Sales:</b> T +353 1 857 6730 F +353 1 857 6729 W standards.ie
Údarás um Chaighdeáin Náisiúnta na hÉireann		

EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM

**EN 60079-15**

May 2010

ICS 29.260.20

Supersedes EN 60079-15:2005

English version

**Explosive atmospheres -  
Part 15: Equipment protection by type of protection "n"  
(IEC 60079-15:2010)**

Atmosphères explosives -  
Partie 15: Protection du matériel  
par mode de protection "n"  
(CEI 60079-15:2010)

Explosionsfähige Atmosphäre -  
Teil 15: Geräteschutz  
durch Zündschutzart "n"  
(IEC 60079-15:2010)

This European Standard was approved by CENELEC on 2010-05-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

**CENELEC**

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Management Centre: Avenue Marnix 17, B - 1000 Brussels**

## Foreword

The text of document 31/833/FDIS, future edition 4 of IEC 60079-15, prepared by IEC TC 31, Equipment for explosive atmospheres, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 60079-15 on 2010-05-01.

This European Standard supersedes EN 60079-15:2005.

The significant technical changes with respect to EN 60079-15:2005 are as follows:

- addition of equipment protection levels;
- removal of the requirements for energy-limited “nL” and associated energy limited apparatus “[nL]”;
- removal of the requirements for encapsulated Devices “nC”;
- requirements for electrical connections expanded and clarified;
- requirements for luminaire ballasts expanded and clarified;
- requirements for evaluation and testing of motor rotors clarified;
- 15 kV limit for equipment protection by type of protection “n” added;
- spacing requirement for voltages above 10 kV modified;
- requirements for restricted breathing enclosures modified;
- modification to requirements for motor rotors and stators;
- addition of Annex A (informative);
- undated references to IEC 60079-0 included.

This standard is to be used in conjunction with EN 60079-0.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates were fixed:

- |  |       |            |
|--|-------|------------|
| – latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement | (dop) | 2011-02-01 |
| – latest date by which the national standards conflicting with the EN have to be withdrawn   | (dow) | 2013-05-01 |

This European Standard has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association and covers essential requirements of EC Directive 94/9/EC. See Annex ZZ.

Annexes ZA, ZY and ZZ have been added by CENELEC.

---

## **Endorsement notice**

The text of the International Standard IEC 60079-15:2010 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60034-5	NOTE	Harmonized as EN 60034-5.
IEC/TS 60034-17	NOTE	Harmonized as CLC/TS 60034-17.
IEC 60068-2-6	NOTE	Harmonized as EN 60068-2-6.
IEC 60079-7:2006	NOTE	Harmonized as EN 60079-7:2007 (not modified).
IEC 60079-17	NOTE	Harmonized as EN 60079-17.
IEC 60079-18	NOTE	Harmonized as EN 60079-18.
IEC 60079-29-2	NOTE	Harmonized as EN 60079-29-2.
IEC 60297 series	NOTE	Harmonized in EN 60297 series (not modified).

---

## CONTENTS

FOREWORD.....	8
1 Scope.....	10
2 Normative references .....	14
3 Terms and definitions .....	15
4 General .....	17
4.1 Equipment grouping and temperature classification .....	17
4.2 Potential ignition sources .....	17
5 Temperatures.....	17
5.1 Maximum surface temperature .....	17
5.2 Small components .....	18
6 Requirements for electrical equipment.....	18
6.1 General.....	18
6.2 Opening times .....	18
6.3 Minimum degree of protection .....	18
6.3.1 General .....	18
6.3.2 Degree of protection provided by installation .....	18
6.4 Clearances, creepage distances and separations .....	18
6.4.1 General .....	18
6.4.2 Determination of working voltage.....	19
6.4.3 Conformal coating .....	19
6.4.4 Comparative tracking index (CTI) .....	19
6.4.5 Measurement of creepage and clearance .....	19
6.4.6 Compound filled cable sealing boxes.....	21
6.5 Electric strength .....	26
6.5.1 Insulation from earth or frame.....	26
6.5.2 Insulation between conductive parts .....	26
7 Connection facilities and terminal compartments .....	27
7.1 General.....	27
7.2 Field wiring connections .....	27
7.2.1 General .....	27
7.2.2 Connections made using terminals complying with IEC 60947-7-1, IEC 60947-7-2, IEC 60999-1, or IEC 60999-2 .....	28
7.2.3 Field wiring connection facilities integral to “n” equipment or components.....	28
7.2.4 Connections designed to be used with cable lugs and similar devices .....	28
7.2.5 Connections using permanent arrangements .....	28
7.3 Factory connections .....	28
7.3.1 General .....	28
7.3.2 Field wiring connection methods used for factory connections .....	28
7.3.3 Other factory connections.....	28
7.3.4 Permanent connections .....	28
7.3.5 Pluggable connections.....	29
7.3.6 Terminal bridging connections .....	29
8 Supplementary requirements for non-sparking electrical machines .....	29
8.1 General.....	29
8.2 Machine enclosure .....	30

8.3	Terminal boxes.....	30
8.4	Conduit stopping boxes, cable sealing and dividing boxes.....	30
8.5	Connection facilities for external conductors.....	30
8.6	Neutral point connections.....	30
8.7	Radial air gap.....	31
8.8	Rotor cages.....	31
8.8.1	Rotor cages built from bars connected to end rings .....	31
8.8.2	Cast rotor cages .....	31
8.8.3	Assessment for possible air gap sparking .....	31
8.9	Stator winding insulation system .....	32
8.10	Surface temperature limitation.....	33
8.10.1	Prevention of thermal ignition .....	33
8.10.2	Operation with a frequency convertor or a non-sinusoidal supply.....	33
9	Supplementary requirements for non-sparking fuses and fuse assemblies.....	34
9.1	Fuses .....	34
9.2	Temperature class of equipment.....	34
9.3	Fuse mounting .....	34
9.4	Fuse enclosures .....	34
9.5	Replacement fuse identification.....	34
10	Supplementary requirements for non-sparking plugs and sockets.....	34
10.1	Plugs and sockets for external connections .....	34
10.2	Maintaining degree of protection (IP code) .....	35
10.3	Sockets that do not have plugs inserted in normal operation .....	35
11	Supplementary requirements for non-sparking luminaires.....	35
11.1	General.....	35
11.2	Construction.....	35
11.2.1	General .....	35
11.2.2	Enclosure of lamp.....	36
11.2.3	Lampholders.....	36
11.2.4	Auxiliaries.....	37
11.2.5	Creepage distances and clearances .....	38
11.2.6	Terminals .....	39
11.2.7	Internal wiring.....	39
11.3	Luminaires for tubular fluorescent bi-pin lamps.....	39
11.3.1	General .....	39
11.3.2	Maximum ambient temperature.....	39
11.3.3	Temperature class.....	39
11.3.4	Endurance tests and thermal tests.....	40
11.3.5	Resistance to dust and moisture.....	41
11.3.6	Insulation resistance and electric strength .....	41
11.4	Other equipment containing light sources .....	41
12	Supplementary requirements for equipment incorporating non-sparking cells and batteries.....	41
12.1	General.....	41
12.2	Categorization of cells and batteries.....	41
12.2.1	Type 1 cells and batteries.....	41
12.2.2	Type 2 cells and batteries.....	42
12.2.3	Type 3 cells and batteries.....	42

12.3	General requirements for cells and batteries of types 1 and 2 .....	43
12.3.1	General .....	43
12.3.2	Maximum capacity .....	43
12.3.3	Secondary cells .....	43
12.3.4	Cell connection .....	43
12.3.5	Discharge mode .....	43
12.3.6	Temperature .....	43
12.3.7	Creepage and clearance .....	43
12.3.8	Connections .....	43
12.3.9	Connecting cells in series .....	43
12.3.10	Deep discharge protection .....	43
12.3.11	Temperature test conditions .....	44
12.3.12	Battery packs .....	44
12.3.13	Battery pack connections .....	44
12.3.14	Cell electrolyte and gas release .....	44
12.3.15	Excessive load draw .....	44
12.4	Charging of type 1 and type 2 cells and batteries .....	44
12.4.1	Temperature range .....	44
12.4.2	Charger specifications .....	44
12.4.3	Charging separated cells or batteries .....	44
12.4.4	Charger limitations .....	44
12.4.5	Charging outside the hazardous area .....	44
12.4.6	Gassing during charging of type 2 cells or batteries .....	45
12.5	Requirements for type 3 secondary batteries .....	45
12.5.1	Types of permissible batteries .....	45
12.5.2	Battery containers .....	45
12.5.3	Cells .....	46
12.5.4	Connections .....	47
12.6	Verification and tests .....	47
12.6.1	Insulation resistance .....	47
12.6.2	Mechanical shock test .....	47
13	Supplementary requirements for non-sparking low power equipment .....	47
14	Supplementary requirements for non-sparking current transformers .....	49
15	Other non-sparking electrical equipment .....	49
16	General supplementary requirements for equipment producing arcs, sparks or hot surfaces .....	49
17	Supplementary requirements for enclosed-break devices and non-incendive components producing arcs, sparks or hot surfaces .....	49
17.1	Type testing .....	49
17.2	Ratings .....	49
17.2.1	Enclosed-break devices .....	49
17.2.2	Non-incendive components .....	50
17.3	Construction of enclosed-break devices .....	50
17.3.1	Free internal volume .....	50
17.3.2	Continuous operating temperature (COT) requirements .....	50
17.3.3	Seal protection .....	50
18	Supplementary requirements for hermetically sealed devices producing arcs, sparks or hot surfaces .....	50



19	Supplementary requirements for sealed devices producing arcs, sparks or hot surfaces .....	50
19.1	Non-metallic materials .....	50
19.2	Opening .....	50
19.3	Internal spaces .....	50
19.4	Handling .....	51
19.5	Gasket and seals .....	51
19.6	Type tests .....	51
20	Supplementary requirements for restricted-breathing enclosures protecting equipment producing arcs, sparks or hot surfaces .....	51
20.1	General .....	51
20.2	Constructional requirements .....	51
20.2.1	Type of equipment .....	51
20.2.2	Cable glands and conduit entries .....	52
20.2.3	Operating rods, spindles and shafts .....	52
20.2.4	Windows .....	52
20.2.5	Gasket and seal requirements .....	53
20.2.6	Non-resilient seals .....	53
20.2.7	Test port .....	53
20.2.8	Internal fans .....	54
20.2.9	Routine test exemptions .....	54
20.3	Temperature limitation .....	54
20.3.1	General .....	54
20.3.2	Temperature calculation .....	54
20.4	Additional requirements for restricted breathing luminaires .....	55
20.4.1	Mounting arrangement .....	55
20.4.2	Reflectors .....	55
20.4.3	Surface temperatures of restricted breathing luminaires .....	55
21	General information on verification and tests .....	55
22	Type tests .....	55
22.1	Representative samples .....	55
22.2	Test configuration .....	55
22.3	Tests for enclosures on which the type of protection depends .....	55
22.3.1	Thermal endurance tests .....	55
22.4	Tests for enclosed break devices and non incensive components .....	56
22.4.1	Preparation of enclosed-break device samples .....	56
22.4.2	Preparation of non-incensive component samples .....	56
22.4.3	Test conditions for enclosed-break devices and non-incensive components .....	56
22.5	Tests for sealed devices .....	57
22.5.1	Conditioning .....	57
22.5.2	Voltage test .....	57
22.5.3	Tests on devices with free space .....	57
22.5.4	Test for sealed devices for luminaires .....	58
22.6	Type test requirements for restricted-breathing enclosures .....	58
22.6.1	General .....	58
22.6.2	Test procedures .....	59
22.6.3	Alternative Type test for equipment where the nominal volume of the enclosure changes due to pressure .....	59

22.7	Test for screw lampholders.....	59
22.8	Test for starter holders for luminaires .....	60
22.9	Tests for electronic starters for tubular fluorescent lamps and for ignitors for high pressure sodium or metal halide lamps .....	60
22.9.1	General .....	60
22.9.2	Moisture resistance, insulation and electric strength test .....	60
22.9.3	Cut-out device test .....	60
22.9.4	Life test (failed lamp).....	61
22.10	Test for wiring of luminaires subject to high-voltage impulses from ignitors.....	61
22.11	Mechanical shock test for batteries .....	62
22.11.1	General .....	62
22.11.2	Test procedure .....	62
22.11.3	Evaluation criteria .....	62
22.12	Insulation resistance test for batteries .....	62
22.12.1	Test conditions .....	62
22.12.2	Evaluation criteria .....	63
22.13	Additional ignition tests for large or high-voltage machines.....	63
22.13.1	Test for cage rotor construction.....	63
22.13.2	Test for stator winding insulation system incendivity.....	63
23	Routine verifications and tests.....	64
23.1	General.....	64
23.2	Specific routine tests .....	64
23.2.1	Electric strength test.....	64
23.2.2	Alternate dielectric strength test .....	64
23.2.3	Routine test requirements for restricted-breathing enclosures .....	64
23.2.4	Routine tests for electronic starters and ignitors .....	65
24	Marking .....	66
24.1	General.....	66
24.2	Where IP marking is required equipment shall be marked in accordance with 6.3. Additional marking for batteries .....	66
24.3	Examples of marking .....	67
24.3.1	Warning markings.....	67
25	Documentation .....	68
26	Instructions.....	68
	Annex A (informative) Application, installation, and testing considerations for Ex “nA” asynchronous machines.....	69
	Bibliography.....	71
	Figure 1 – Examples for determining clearances and creepage distances .....	26
	Table 1 – Relationship of this part to IEC 60079-0 .....	10
	Table 2 – Minimum creepage distances, clearances and separations.....	20
	Table 3 – Tracking resistance of insulating materials .....	21
	Table 4 – Separation in compound-filled cable sealing boxes .....	22
	Table 5 – Assumed voltage of neutral points.....	30
	Table 6 – Potential air gap sparking risk assessment for cage rotor ignition risk factors.....	32
	Table 7 – Minimum distance between lamp and protective cover .....	36

**I.S. EN 60079-15:2010**

60079-15 © IEC:2010

– 7 –

Table 8 – Creepage distances and clearances at peak values of pulse voltages greater than 1,5 kV .....	39
Table 9 – Types and use of cells and batteries .....	42
Table 10 – Minimum creepage distances, clearances and separations for low power equipment.....	48
Table 11 – Insertion torque .....	59
Table 12 – Minimum removal torque .....	60
Table 13 – Explosion test mixtures .....	64
Table 14 – Text of warning markings .....	67

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

### **EXPLOSIVE ATMOSPHERES –**

#### **Part 15: Equipment protection by type of protection "n"**

### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60079-15 has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

This fourth edition cancels and replaces the third edition, published in 2005, and constitutes a technical revision.

The significant technical changes with respect to the previous edition are as follows:

- addition of equipment protection levels;
- removal of the requirements for energy-limited "nL" and associated energy limited apparatus "[nL]";
- removal of the requirements for encapsulated Devices "nC";
- requirements for electrical connections expanded and clarified;
- requirements for luminaire ballasts expanded and clarified;
- requirements for evaluation and testing of motor rotors clarified;

**I.S. EN 60079-15:2010**

60079-15 © IEC:2010

– 9 –

- 15 kV limit for equipment protection by type of protection "n" added;
- spacing requirement for voltages above 10 kV modified;
- requirements for restricted breathing enclosures modified;
- modification to requirements for motor rotors and stators;
- addition of Annex A (informative);
- undated references to IEC 60079-0 included.

The text of this standard is based on the following documents:

FDIS	Report on voting
31/833/FDIS	31/853/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This International Standard is to be read in conjunction with IEC 60079-0.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60079 series, under the general title: *Explosives atmospheres*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

## EXPLOSIVE ATMOSPHERES –

### Part 15: Equipment protection by type of protection "n"

#### 1 Scope

This part of IEC 60079 specifies requirements for the construction, testing and marking for Group II electrical equipment with type of protection, "n" intended for use in explosive gas atmospheres. This standard applies to electrical equipment where the rated voltage does not exceed 15 kV r.m.s. a.c. or d.c.

This part of IEC 60079 is applicable to non-sparking electrical equipment and also to electrical equipment with parts or circuits producing arcs or sparks or having hot surfaces which, if not protected in one of the ways specified in this standard, could be capable of igniting a surrounding explosive gas atmosphere. This standard describes several different methods by which this can be achieved which may be combined with other methods described in IEC 60079-0.

This standard supplements and modifies the general requirements of IEC 60079-0, except as indicated in Table 1. Where a requirement of this standard conflicts with a requirement of IEC 60079-0, the requirement of this standard takes precedence.

**Table 1 – Relationship of this part to IEC 60079-0**

Clause of IEC 60079-0			IEC 60079-0 clause application to IEC 60079-15		
Ed. 5.0 (2007) (informative)	Ed. 6.0 <sup>1</sup> (future edition) (informative)	Clause / Subclause title (normative)	Protected sparking nC	Non sparking nA	Restricted breathing nR
4	4	Equipment grouping	Applies	Applies	Applies
4.1	4.1	Group I	Excluded	Excluded	Excluded
4.2	4.2	Group II	Applies	Applies	Applies
4.3	4.3	Group III	Excluded	Excluded	Excluded
4.4	4.4	Equipment for a particular explosive atmosphere	Applies	Applies	Applies
5.1	5.1	Environmental influences	Applies	Applies	Applies
5.1.1	5.1.1	Ambient temperature	Applies	Applies	Applies
5.1.2	5.1.2	External source of heating or cooling	Applies	Applies	Applies
5.2	5.2	Service temperature	Applies	Applies	Applies
5.3.1	5.3.1	Determination of maximum surface temperature	Applies	Applies	Applies
5.3.2.1	5.3.2.1	Group I electrical equipment	Excluded	Excluded	Excluded

<sup>1</sup> Under consideration.

**I.S. EN 60079-15:2010**

60079-15 © IEC:2010

– 11 –

Clause of IEC 60079-0			IEC 60079-0 clause application to IEC 60079-15		
Ed. 5.0 (2007) (informative)	Ed. 6.0 <sup>1</sup> (future edition) (informative)	Clause / Subclause title (normative)	Protected sparking nC	Non sparking nA	Restricted breathing nR
5.3.2.2	5.3.2.2	Group II electrical equipment	Applies	Applies	Applies
5.3.2.3	5.3.2.3	Group III electrical equipment	Excluded	Excluded	Excluded
5.3.3	5.3.3	Small component temperature for Group I and Group II electrical equipment	Applies	Applies	Excluded
6.1	6.1	General	Applies	Applies	Applies
6.2	6.2	Mechanical strength	Applies	Applies	Applies
6.3	6.3	Opening times	Excluded	Excluded	Applies
6.4	6.4	Circulating currents	Applies	Applies	Applies
6.5	6.5	Gasket retention	Applies	Applies	Applies
6.6	6.6	Electromagnetic and ultrasonic radiating equipment	Applies	Applies	Applies
7.1.1	7.1.1	Applicability	Applies	Applies	Applies
7.1.2	7.1.2	Specification of materials	Applies	Applies	Applies
7.1.3	7.1.2.2	Plastic materials	Applies	Applies	Applies
7.1.4	7.1.2.3	Elastomeric materials	Applies	Applies	Applies
7.2	7.2	Thermal endurance	Applies	Applies	Applies
7.3	7.3	Resistance to light	Applies	Applies	Applies
7.4	7.4	Electrostatic charges on external non-metallic materials	Applies	Applies	Applies
7.5	9.1	Threaded holes	Applies	Applies	Applies
8.1.1	8.2	Group I	Excluded	Excluded	Excluded
8.1.2	8.3	Group II	Applies	Applies	Applies
8.1.3	8.4	Group III	Excluded	Excluded	Excluded
8.2	9.1	Threaded holes	Applies	Applies	Applies
9.1	9.1	General	Applies	Applies	Applies
9.2	9.2	Special fasteners	Excluded	Excluded	Excluded
9.3	9.3	Holes for special fasteners	Excluded	Excluded	Excluded
10	10	Interlocking devices	Excluded	Excluded	Excluded
11	11	Bushings	Applies	Applies	Applies
12	12	Materials used for cementing	Modified	Modified	Modified
13	13	Ex components	Applies	Applies	Applies
14	14	Connection facilities and termination compartments	Modified	Modified	Modified
15	15	Connection facilities for earthing and bonding conductors	Applies	Applies	Applies

**I.S. EN 60079-15:2010**

Clause of IEC 60079-0			IEC 60079-0 clause application to IEC 60079-15		
Ed. 5.0 (2007) (informative)	Ed. 6.0 <sup>1</sup> (future edition) (informative)	Clause / Subclause title (normative)	Protected sparking nC	Non sparking nA	Restricted breathing nR
16	16	Entries into enclosures	Applies	Applies	Applies
17	17	Supplementary requirements for rotating electrical machines	Excluded	Modified	Excluded
18	18	Supplementary requirements for switchgear	Applies	Applies	Applies
19	19	Supplementary requirements for fuses	Modified	Modified	Modified
20	20	Supplementary requirements for plugs and sockets	Modified	Modified	Modified
21	21	Supplementary requirements for luminaires	Modified	Modified	Modified
22	22	Supplementary requirements for caplights and handlights	Applies	Applies	Applies
23	23	Equipment incorporating cells and batteries	Modified	Modified	Modified
24	24	Documentation	Applies	Applies	Applies
25	25	Compliance of prototype or sample with documents	Applies	Applies	Applies
26.1	26.1	General	Applies	Applies	Applies
26.2	26.2	Test configuration	Applies	Applies	Applies
26.3	26.3	Tests in explosive test mixtures	Applies	Applies	Applies
26.4	26.4	Tests of enclosures	Applies	Applies	Applies
26.4.1.1	26.4.1.1	Metallic enclosures, metallic parts of enclosures and glass parts of enclosures	Applies	Applies	Applies
26.4.1.2.1	26.4.1.2.1	Group I electrical equipment	Excluded	Excluded	Excluded
26.4.1.2.2	26.4.1.2.2	Group II and Group III electrical equipment	Applies	Applies	Applies
26.4.2	26.4.2	Resistance to impact	Applies	Applies	Applies
26.4.3	26.4.3	Drop test	Applies	Applies	Applies
26.4.4	26.4.4	Acceptance criteria	Applies	Applies	Applies
26.4.5	26.4.5	Degree of protection by enclosure	Applies	Applies	Applies
26.5	26.5	Thermal tests	Applies	Applies	Applies
26.6	26.6	Torque test for bushings	Applies	Applies	Applies
26.7	26.7	Non-metallic enclosures or non-metallic parts of enclosures	Modified	Modified	Modified
26.8	26.8	Thermal endurance to heat	Modified	Modified	Modified



This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

- 
- Looking for additional Standards? Visit Intertek Inform Infostore
  - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-