



**NSAI**  
Standards

Irish Standard  
I.S. EN 15420:2010

# Gas-fired central heating boilers - Type C boilers of nominal heat input exceeding 70 kW, but not exceeding 1 000 kW

## I.S. EN 15420:2010

*Incorporating amendments/corrigenda/National Annexes issued since publication:*

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation - recommendation based on the consensus of an expert panel and subject to public consultation.

SWIFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

*This document replaces:*

*This document is based on:*  
EN 15420:2010

*Published:*  
20 December, 2010

This document was published under the authority of the NSAI and comes into effect on:  
20 December, 2010

ICS number:  
91.140.10

**NSAI**  
1 Swift Square,  
Northwood, Santry  
Dublin 9

T +353 1 807 3800  
F +353 1 807 3838  
E standards@nsai.ie  
W NSAI.ie

**Sales:**  
T +353 1 857 6730  
F +353 1 857 6729  
W standards.ie

Údarás um Chaighdeáin Náisiúnta na hÉireann

ICS 91.140.10

English Version

## Gas-fired central heating boilers - Type C boilers of nominal heat input exceeding 70 kW, but not exceeding 1 000 kW

Chaudières de chauffage central utilisant les combustibles gazeux - Chaudières de type C dont le débit calorifique nominal est supérieur à 70 kW mais inférieur ou égal à 1 000 kW

Heizkessel für gasförmige Brennstoffe - Heizkessel der Bauart C mit einer Nennwärmebelastung größer als 70 kW aber gleich oder kleiner als 1 000 kW

This European Standard was approved by CEN on 23 October 2010.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**Management Centre: Avenue Marnix 17, B-1000 Brussels**

## Contents

Page

Foreword.....	7
1 Scope.....	8
2 Normative references .....	8
3 Terms and definitions.....	10
3.1 Combustible gases .....	10
3.2 Constituent parts of the boiler.....	12
3.2.1 Gas supply.....	12
3.2.2 Air supply and combustion products evacuation .....	13
3.2.3 Adjusting, control and safety devices .....	15
3.3 Operation of the boiler.....	17
3.3.1 Gas rates .....	17
3.3.2 Outputs.....	18
3.3.3 Efficiency .....	18
3.3.4 Gas combustion .....	19
3.3.5 Times .....	19
3.3.6 spark restoration.....	20
3.3.7 recycling .....	20
3.3.8 controlled shutdown.....	20
3.3.9 safety shutdown.....	20
3.3.10 Locking out.....	20
3.4 Auxiliary energy .....	21
3.4.1 electric auxiliary energy .....	21
3.5 Country of destination.....	21
3.5.1 direct country of destination .....	21
3.5.2 indirect country of destination .....	21
4 Classification of boilers.....	21
4.1 Gases and categories.....	21
4.2 Mode of air supply and evacuation of the combustion products .....	22
4.2.1 Type C Boilers .....	22
4.2.2 Type of installation of the boiler.....	22
4.2.3 Presence and position of a fan.....	23
4.3 Classification according to operating conditions <sup>1)</sup> .....	23
4.3.1 Standard boiler.....	23
4.3.2 Low-temperature boiler .....	23
4.3.3 Gas condensing boiler <sup>1)</sup> .....	24
4.4 Modular boiler .....	24
5 Constructional requirements .....	24
5.1 General.....	24
5.2 Conversion to different gases .....	24
5.3 Materials and method of construction.....	24
5.3.1 General.....	24
5.3.2 Materials and thicknesses of walls or tubes under water pressure .....	25
5.3.3 Thermal insulation .....	33
5.4 Combustion products evacuation duct .....	34
5.4.1 Stability under mechanical loading.....	34
5.4.2 Stability under exposure to heat .....	34
5.4.3 Corrosion resistance .....	34
5.4.4 Resistance to condensate and moisture under normal operating conditions .....	34
5.5 Design .....	34

5.5.1	General .....	34
5.5.2	Modular boilers .....	35
5.6	Use and servicing .....	35
5.7	Connections to the gas and water pipes .....	35
5.7.1	General.....	35
5.7.2	Connections to the gas pipe.....	35
5.7.3	Connections to the central heating circuit.....	36
5.8	Soundness .....	36
5.8.1	Soundness of the gas circuit.....	36
5.8.2	Soundness of the combustion circuit.....	36
5.9	Supply of combustion air and the evacuation of the combustion products .....	37
5.9.1	General.....	37
5.9.2	Air supply and combustion products evacuation duct <sup>1)</sup> .....	37
5.9.3	Terminal .....	37
5.9.4	Terminal guard .....	37
5.9.5	Fitting piece .....	38
5.9.6	Control dampers in the air or combustion products circuit.....	38
5.9.7	Special requirements for certain components of boilers with a fan .....	38
5.9.8	Condensate discharge.....	39
5.10	Checking the state of operation .....	40
5.11	Drainage.....	40
5.12	Electrical equipment.....	40
5.13	Operational safety in the event of failure of the auxiliary energy.....	40
5.14	Adjusting, control and safety devices .....	40
5.14.1	General.....	40
5.14.2	Adjusters and range rating devices .....	41
5.14.3	Gas circuit.....	41
5.14.4	Gas pressure regulator.....	43
5.14.5	Ignition devices .....	43
5.14.6	Flame supervision systems .....	44
5.14.7	Thermostats and water temperature limiting devices.....	45
5.15	Burners .....	46
5.16	Pressure test points.....	46
5.17	Chemical composition of the condensate.....	46
6	Operational requirements .....	46
6.1	General.....	46
6.2	Soundness .....	46
6.2.1	Soundness of the gas circuit.....	46
6.2.2	Soundness of the combustion circuit.....	47
6.2.3	Soundness of the water circuit.....	48
6.3	Nominal, maximum and minimum heat inputs, and nominal output.....	48
6.3.1	Nominal heat input or maximum and minimum heat inputs .....	48
6.3.2	Adjustment of the heat input by the downstream pressure .....	48
6.3.3	Ignition rate.....	48
6.3.4	Nominal output.....	48
6.3.5	Gas pressure regulator.....	48
6.4	Safety of operation.....	49
6.4.1	Limiting temperatures .....	49
6.4.2	Ignition – Cross-lighting – Flame stability.....	50
6.4.3	Pre-purge .....	51
6.4.4	Functioning of a permanent ignition burner when the fan stops during the standby time .....	52
6.5	Adjusting, control and safety devices .....	52
6.5.1	General.....	52
6.5.2	Ignition devices .....	52
6.5.3	Flame supervision devices .....	53
6.5.4	Ignition burner and ignition rates.....	55
6.5.5	Air proving .....	55

6.5.6	Gas pressure switches .....	56
6.5.7	Control thermostat and safety temperature limiter .....	57
6.5.8	Condensate discharge blockage .....	58
6.6	Combustion .....	58
6.6.1	Carbon monoxide .....	58
6.6.2	Limit conditions .....	58
6.6.3	Special conditions .....	58
6.6.4	Sooting .....	58
6.6.5	Other pollutants .....	58
6.7	Useful efficiencies .....	59
6.7.1	Useful efficiency at the nominal heat input .....	59
6.7.2	Useful efficiency at part load .....	59
6.8	Criteria for condensation in the flue .....	60
6.9	Resistance of the materials to pressure .....	60
6.9.1	General .....	60
6.9.2	Boilers of sheet steel or non-ferrous metals .....	60
6.9.3	Boilers of cast iron and cast materials .....	60
6.10	Hydraulic resistance .....	61
6.11	Condensation in the boiler .....	61
6.12	Combustion air and flue dampers .....	61
7	Test methods .....	61
7.1	General .....	61
7.1.1	Characteristics of the reference and limit gases .....	61
7.1.2	General test conditions .....	67
7.2	Soundness .....	70
7.2.1	Soundness of the gas circuit .....	70
7.2.2	Soundness of the combustion circuit .....	71
7.2.3	Soundness of the water circuit .....	72
7.3	Nominal, maximum and minimum heat inputs, and nominal output .....	72
7.3.1	Nominal heat input or maximum and minimum heat inputs .....	72
7.3.2	Adjustment of the heat input by the downstream pressure .....	73
7.3.3	Ignition rate .....	74
7.3.4	Nominal output .....	74
7.3.5	Gas pressure regulator .....	74
7.4	Safety of operation .....	74
7.4.1	Limiting temperatures .....	74
7.4.2	Ignition - Cross-lighting - Flame stability .....	76
7.4.3	Pre-purge .....	79
7.4.4	Functioning of a permanent ignition burner when the fan stops during standby time .....	80
7.5	Adjusting, control and safety devices .....	80
7.5.1	General .....	80
7.5.2	Ignition devices .....	80
7.5.3	Flame supervision devices .....	81
7.5.4	Ignition burner and ignition rates .....	83
7.5.5	Air proving .....	83
7.5.6	Gas pressure switches .....	85
7.5.7	Control thermostat and safety temperature limiter .....	85
7.5.8	Condensate discharge blockage .....	87
7.6	Combustion .....	87
7.6.1	Carbon monoxide .....	87
7.6.2	Limit conditions .....	88
7.6.3	Special conditions .....	89
7.6.4	Other pollutants .....	91
7.7	Useful efficiencies .....	95
7.7.1	Useful efficiency at the nominal heat input .....	95
7.7.2	Useful efficiency at part load .....	96
7.8	Criteria for condensation in the flue .....	101

7.8.1	Determination of flue losses .....	101
7.8.2	Minimum temperature of the combustion products.....	102
7.9	Resistance of materials to pressure .....	102
7.9.1	General.....	102
7.9.2	Boilers of sheet steel or non-ferrous metals .....	102
7.9.3	Boilers of cast iron and cast materials .....	103
7.10	Hydraulic resistance.....	103
7.11	Condensation in the boiler.....	103
7.12	Combustion air and flue dampers.....	103
8	Marking and instructions .....	104
8.1	Marking of the boiler.....	104
8.1.1	General.....	104
8.1.2	Data plate .....	104
8.1.3	Supplementary marking .....	106
8.1.4	Packaging .....	108
8.1.5	Warnings on the boiler and on the packaging.....	108
8.1.6	Other information.....	108
8.2	Instructions.....	108
8.2.1	Technical instructions for the installer.....	108
8.2.2	For installation of the combustion circuit .....	109
8.2.3	Use and maintenance instructions for the user .....	110
8.2.4	Conversion instructions.....	111
8.3	Presentation .....	111
Annex A	(informative) National situations .....	127
A.1	Categories marketed in the various countries.....	127
A.2	Special categories marketed nationally or locally.....	129
A.3	Gas groups distributed locally .....	129
A.4	Boiler supply pressures .....	130
A.5	Gas connections in common use in the various countries.....	132
Annex B	(informative) Special national conditions.....	133
Annex C	(informative) A-deviations.....	134
Annex D	(informative) Classification of type C boilers.....	135
Annex E	(informative) Practical method of calibrating the test rig to enable the heat loss $D_p$ to be determined .....	142
Annex F	(informative) Main symbols and abbreviations used.....	143
Annex G	(informative) Compilation of test conditions .....	144
Annex H	(informative) Valving.....	147
H.1	General.....	147
H.2	Boilers with permanent ignition burner or alternating ignition burner or leakage control device or with pre-purge .....	147
H.2.1	Heat inputs up to 150 kW .....	147
H.2.2	Heat inputs up to 300 kW .....	148
H.3	Boilers without permanent ignition burner or alternating ignition burner, without leakage control device and without pre-purge .....	149
H.3.1	Heat inputs up to 150 kW .....	149
H.3.2	Heat inputs up to 300 kW .....	150
H.4	Heat Inputs exceeding 300 kW but not exceeding 1 000 kW .....	151
H.4.1	Boilers with permanent ignition burner or alternating ignition burner or leakage control device or with pre-purge .....	151
H.4.2	Boilers without permanent ignition burner or alternating ignition burner, without a leakage control device and without pre-purge .....	152
Annex I	(informative) Determination of the heat losses from the test rig of the indirect method and the contributions of the circulating pump of the test rig .....	153

<b>Annex J (informative) Means of determining the ignition time at full rate .....</b>	<b>154</b>
<b>Annex K (informative) Example of the calculation of the <math>NO_x</math> weighting factors for a boiler with several rates .....</b>	<b>155</b>
<b>K.1 Apportioning of <math>Q_{pi} = 20\%</math> .....</b>	<b>155</b>
<b>K.2 Apportioning of <math>Q_{pi} = 40\%</math> .....</b>	<b>155</b>
<b>K.3 Apportioning of <math>Q_{pi} = 60\%</math> .....</b>	<b>155</b>
<b>K.4 Apportioning of <math>Q_{pi} = 70\%</math> .....</b>	<b>156</b>
<b>K.5 Total apportioning .....</b>	<b>156</b>
<b>Annex L (informative) Calculation of conversions of <math>NO_x</math> .....</b>	<b>157</b>
<b>Annex M (normative) Test apparatus for type C2 boilers (see 7.4.2.3.3) .....</b>	<b>158</b>
<b>Annex N (informative) Requirements and test methods for separate air supply and combustion products evacuation ducts of type C6 boilers) .....</b>	<b>159</b>
<b>N.1 Requirements .....</b>	<b>159</b>
<b>N.1.1 Pressure losses .....</b>	<b>159</b>
<b>N.1.2 Pressure loss under the influence of wind .....</b>	<b>159</b>
<b>N.1.3 Suction under the influence of wind .....</b>	<b>159</b>
<b>N.1.4 Recirculation of the combustion products .....</b>	<b>159</b>
<b>N.2 Test methods .....</b>	<b>160</b>
<b>N.2.1 Pressure loss in still air .....</b>	<b>160</b>
<b>N.2.2 Pressure loss under the influence of wind .....</b>	<b>160</b>
<b>N.2.3 Suction under the influence of wind .....</b>	<b>160</b>
<b>N.2.4 Recirculation of the combustion products .....</b>	<b>161</b>
<b>N.2.5 Wind test conditions .....</b>	<b>161</b>
<b>Annex O (informative) Use of test gases .....</b>	<b>164</b>
<b>O.1 Boilers within a range .....</b>	<b>164</b>
<b>O.2 Guidance on the use of test gases .....</b>	<b>164</b>
<b>Annex ZA (informative) Clauses of this European Standard addressing essential requirements or provisions of EU Directives .....</b>	<b>165</b>
<b>Bibliography .....</b>	<b>168</b>

## Foreword

This document (EN 15420:2010) has been prepared by Technical Committee CEN/TC 109 "Central heating boilers using gaseous fuels", the secretariat of which is held by NEN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by June 2011, and conflicting national standards shall be withdrawn at the latest by June 2011.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

It was established to deal with aspects related to:

- safety;
- rational use of energy;
- fitness for purpose.

Other types of boilers are dealt with in separate standards.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directives 90/396/EEC and 92/42/EEC.

For relationship with EU Directives 90/396/EEC "Approximation of the laws of Member States concerning gas appliances" and 92/42/EEC "Efficiency requirements for new hot water boilers fired with liquid or gaseous fuels" see informative Annex ZA, which is an integral part of this standard.

This standard covers only type testing.

Matters related to quality assurance systems, tests during production and to certificates of conformity to auxiliary devices are not dealt with in this standard.

It is impractical to use the full range of test gases to EN 437 for type testing since their availability, for inputs over 300 kW, may present problems for test houses and manufacturers. Informative Annex O gives guidance on the use of gases for tests in order to ensure conformity with EU Directive 90/396/EEC "Approximation of the laws of Member States concerning gas appliances".

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

## 1 Scope

This document specifies the requirements and test methods concerning, in particular, the construction, safety, fitness for purpose, and rational use of energy, as well as the classification and marking of gas-fired central heating boilers that are fitted with atmospheric burners, fan-assisted atmospheric burners or fully premixed burners, and are hereafter referred to as "boilers".

This document applies to boilers of type C, as listed in 4.2:

- that use one or more combustible gases of the three gas families at the pressures stated in Tables 14 and 15;
- that have a nominal heat input (on the basis of net calorific value) exceeding 70 kW, but not exceeding 1 000 kW, including modular boilers;
- where the temperature of the heat transfer fluid does not exceed 105 °C during normal operation;
- where the maximum operating pressure in the water circuit does not exceed 6 bar;
- which can give rise to condensation under certain circumstances.

The document applies to boilers designed for sealed water systems or for open water systems.

The document does not contain all the requirements necessary for boilers:

- intended to be installed in the open or in living rooms;
- permanently fitted with more than one flue outlet;
- of the condensing type;
- intended to be connected to a common flue having mechanical extraction;
- type C21, C41, C51, C61, C7 and C81 boilers;
- fitted with a forced draught burner in accordance with EN 676;
- producing hot water for domestic purposes.

This document only covers type testing.

## 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 88-1, *Pressure regulators and associated safety devices for gas appliances — Part 1: Pressure regulators for inlet pressures up to and including 500 mbar*

EN 125, *Flame supervision devices for gas burning appliances — Thermo-electric flame supervision devices*

EN 126, *Multifunctional controls for gas burning appliances*

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

- 
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
  - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-