



NSAI
Standards

Irish Standard
I.S. EN 50065-1:2011

Signalling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz -- Part 1: General requirements, frequency bands and electromagnetic disturbances

I.S. EN 50065-1:2011

Incorporating amendments/corrigenda issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation - recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

<i>This document replaces:</i> EN 50065-1:2001+A1:2010	<i>This document is based on:</i> EN 50065-1:2011	<i>Published:</i> 22 April, 2011
This document was published under the authority of the NSAI and comes into effect on: 9 May, 2011		ICS number: 33.040.30
NSAI 1 Swift Square, Northwood, Santry Dublin 9	T +353 1 807 3800 F +353 1 807 3838 E standards@nsai.ie W NSAI.ie	Sales: T +353 1 857 6730 F +353 1 857 6729 W standards.ie
Údarás um Chaighdeáin Náisiúnta na hÉireann		

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 50065-1

April 2011

ICS 33.040.30

Supersedes EN 50065-1:2001 + A1:2010

English version

**Signalling on low-voltage electrical installations in the frequency range
3 kHz to 148,5 kHz -
Part 1: General requirements, frequency bands and electromagnetic
disturbances**

Transmission de signaux sur les réseaux
électriques basse tension dans la bande
de fréquences de 3 kHz à 148,5 kHz -
Partie 1: Règles générales, bandes de
fréquences et perturbations
électromagnétiques

Signalübertragung auf elektrischen
Niederspannungsnetzen im
Frequenzbereich 3 kHz bis 148,5 kHz -
Teil 1: Allgemeine Anforderungen,
Frequenzbänder und elektromagnetische
Störungen

This European Standard was approved by CENELEC on 2011-03-21. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

This European Standard was prepared by the CENELEC technical subcommittee SC 205A, Mains communication systems, of Technical Committee CENELEC TC 205, Home and Building Electronic Systems (HBES).

The text of the draft was submitted to the Unique Acceptance Procedure and was approved by CENELEC as EN 50065-1 on 2011-03-21.

This European Standard supersedes EN 50065-1:2001 + A1:2010.

This revision aligns EN 50065-1 with CENELEC Guide 24; this has been done in particular in relation to the responsibilities of parties involved by replacing with references to common application types whilst not making technical changes to the standard. In addition the text on common-mode signalling has been clarified and account taken of use of mains signalling in relation to the charging of electric vehicles. Additional editorial changes have been made to clarify areas on which there have been queries.

The following dates were fixed:

- latest date by which the revision has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2012-03-21
- latest date by which the national standards conflicting with the amendment have to be withdrawn (dow) 2014-03-21

EN 50065 consists of the following parts, under the general title *Signalling on low voltage electrical installations in the frequency range 3 kHz to 148,5 kHz*:

Part 1	General requirements, frequency bands and electromagnetic disturbances
Part 2-1	Immunity requirements for mains communications equipment and systems operating in the range of frequencies 95 kHz to 148,5 kHz and intended for use in residential, commercial and light industrial environments
Part 2-2	Immunity requirements for mains communications equipment and systems operating in the range of frequencies 95 kHz to 148,5 kHz and intended for use in industrial environments
Part 2-3	Immunity requirements for mains communications equipment and systems operating in the range of frequencies 3 kHz to 95 kHz and intended for use by electricity suppliers and distributors
Part 4-1	Low voltage decoupling filters – Generic specification
Part 4-2	Low voltage decoupling filters – Safety requirements
Part 4-3	Low voltage decoupling filters – Incoming filter
Part 4-4	Low voltage decoupling filters – Impedance filter
Part 4-5	Low voltage decoupling filters – Segmentation filter
Part 4-6	Low voltage decoupling filters – Phase coupler
Part 7	Equipment impedance

Contents

		Page
1	Scope	5
2	Normative references	5
3	Terms and definitions	5
4	Frequency bands	7
5	Access protocol.....	8
6	Transmitter output voltage	9
7	Disturbance limits.....	17
8	Test conditions	19
9	Safety considerations.....	21

Annexes

	Annex A (normative) Method of measurement of the frequency range over which a transmitter device detects a signal from another device in the frequency range 125 kHz to 140 kHz ..	22
	Annex B (normative) Method of measurement of the spectral distribution of a transmitting device's signal in the frequency range 125 kHz to 140 kHz.....	23
	Annex C (normative) Methods of measurement (9 kHz to 30 MHz).....	24
	Annex D (normative) Methods of measurement of disturbance power (30 MHz to 1 GHz)	25
	Annex E (normative) Attenuation characteristics of measuring instrument above 150 kHz.....	27
	Annex F (informative) Design for a single artificial network intended to show the performance of a signalling system	28
	Annex ZZ (informative) Coverage of Essential Requirements of EC Directives	30

Figures	Page
Figure 1	Measurement of spectral bandwidth 10
Figure 2	Idealized equivalent circuit model – DUT port impedance 11
Figure 3	Example of artificial mains network 3 kHz to 9 kHz 11
Figure 4	Measurement of output level (single phase) 12
Figure 5	Example of artificial mains network 9 kHz to 95 kHz and 95 kHz to 148,5 kHz 13
Figure 6	Measurement of output level in of 3-phase devices transmitting simultaneously on all phases 14
Figure 7	Voltage limits for spurious outputs in other bands 18
Figure 8	Measuring arrangement for equipment the operation of which is dependent on the transmitter being in circuit (single phase) 20
Figure A.1	Measuring arrangements for testing the frequency range of the signal detector 22
Figure F.1a	The adaptive network for the frequency range 3 kHz to 148,5 kHz 28
Figure F.1b	The adaptive network connection with the EN 55016-1-2 network 28
Figure F.2	The nominal EN 55016-1-2:2004, Figure 1a impedance (doubled) and the calculated impedance between points A and B (Figure F.1b) when the adaptive network is added to the EN 55016-1-2 network 29
Tables	
Table 1	Summary of maximum transmission levels 16
Table 2	Limits of mains terminal disturbance voltage in the frequency range 0,15 MHz to 30 MHz 18
Table 3	Limits of radiated disturbance field strength in the frequency range 30 MHz to 1 000 MHz at a test distance of 10 m 19
Table 4	Limits of disturbance power 19
Table B.1	Values of H_i 23
Table E.1	Attenuation of measuring instrument above 150 kHz 27

1 Scope

This standard applies to electrical equipment using signals in the frequency range 3 kHz to 148,5 kHz to transmit information on low voltage electrical systems, either on the public electricity distribution network or within installations in consumers' premises.

It specifies the frequency bands allocated to the different applications, limits for the terminal output voltage in the operating band and limits for conducted and radiated disturbance. It also gives the methods of measurement.

It does not specify the modulation methods, the coding methods or functional features (except those for the prevention of mutual interference).

Environmental requirements and tests are not included.

NOTE 1 Compliance with this standard does not imply permission to establish communication with locations outside the consumer's installation or with other consumers through the public electricity distribution network where this would not otherwise be allowed.

The object of the standard is to limit mutual influence between transmission equipment in electrical installations and between such equipment and other equipment. In addition this standard is intended to limit interference caused by signal transmission equipment to sensitive electronic equipment. However, complete freedom from such interference cannot be assured.

NOTE 2 Designers should consider signalling systems in conformance with this standard when determining immunity for electrical equipment.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-161		International electrotechnical vocabulary – Chapter 161: Electromagnetic compatibility
EN 55016-1-1	2010	Specification for radio disturbance and immunity measuring apparatus and methods – Part 1-1: Radio disturbance and immunity measuring apparatus – Measuring apparatus (CISPR 16-1-1:2010)
EN 55016-1-2	2004	Specification for radio disturbance and immunity measuring apparatus and methods – Part 1-2: Radio disturbance and immunity measuring apparatus – Ancillary equipment – Conducted disturbances (CISPR 16-1-2:2003 + A1:2004 + A2:2006)
+ A1	2005	
+ A2	2006	
EN 55016-1-4	2010	Specification for radio disturbance and immunity measuring apparatus and methods – Part 1-4: Radio disturbance and immunity measuring apparatus – Antennas and test sites for radiated disturbance measurements (CISPR 16-1-4:2010)
EN 55016-2-2	2004	Specification for radio disturbance and immunity measuring apparatus and methods – Part 2-2: Methods of measurement of disturbances and immunity – Measurement of disturbance power (CISPR 16-2-2:2003 + A1:2004 + A2:2005)
+ A1	2005	
+ A2	2005	

3 Terms and definitions

The definitions in IEC 60050-161 apply.

For the purposes of this document, the following terms and definitions apply.

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-