



**NSAI**  
Standards

Standard Recommendation  
S.R. CLC/TR 60269-5:2011

# Low-voltage fuses -- Part 5: Guidance for the application of low-voltage fuses (IEC/TR 60269-5:2010 (EQV))

## S.R. CLC/TR 60269-5:2011

*Incorporating amendments/corrigenda issued since publication:*

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation - recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

<i>This document replaces:</i>	<i>This document is based on:</i> CLC/TR 60269-5:2011	<i>Published:</i> 29 April, 2011
This document was published under the authority of the NSAI and comes into effect on:  10 May, 2011		ICS number: 29.120.50
<b>NSAI</b> 1 Swift Square, Northwood, Santry Dublin 9	T +353 1 807 3800 F +353 1 807 3838 E standards@nsai.ie  W NSAI.ie	<b>Sales:</b> T +353 1 857 6730 F +353 1 857 6729 W standards.ie
Údarás um Chaighdeáin Náisiúnta na hÉireann		

TECHNICAL REPORT

**CLC/TR 60269-5**

RAPPORT TECHNIQUE

TECHNISCHER BERICHT

April 2011

ICS 29.120.50

English version

**Low-voltage fuses -  
Part 5: Guidance for the application of low-voltage fuses  
(IEC/TR 60269-5:2010)**

Fusibles basse tension -  
Partie 5: Lignes directrices pour  
l'application des fusibles basse tension  
(CEI/TR 60269-5:2010)

Niederspannungssicherungen -  
Teil 5: Leitfaden für die Anwendung von  
Niederspannungssicherungen  
(IEC/TR 60269-5:2010)

This Technical Report was approved by CENELEC on 2011-04-25.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

**CENELEC**

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Management Centre: Avenue Marnix 17, B - 1000 Brussels**

**S.R. CLC/TR 60269-5:2011**

CLC/TR 60269-5:2011

- 2 -

**Foreword**

This Technical Report consists of the text of the International Technical Report IEC/TR 60269-5:2010 prepared by SC 32B, Low-voltage fuses, of IEC TC 32, Fuses.

It was circulated for voting in accordance with the Internal Regulations, Part 2, Subclause 11.4.3.3 (simple majority) and was accepted by CENELEC as CLC/TR 60269-5 on 2011-04-25.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

Annex ZA has been added by CENELEC.

---

**Endorsement notice**

The text of the Technical Report IEC/TR 60269-5:2010 was approved by CENELEC as a Technical Report without any modification.

---

## Annex ZA (normative)

### Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-441	-	International Electrotechnical Vocabulary (IEV) - Chapter 441: Switchgear, controlgear and fuses	-	-
IEC/TR 60146-6	-	Semiconductor convertors - Part 6: Application guide for the protection of semiconductor convertors against overcurrent by fuses	-	-
IEC 60269	Series	Low-voltage fuses	EN 60269	Series
IEC 60269-1	-	Low-voltage fuses - Part 1: General requirements	EN 60269-1	-
IEC 60269-2	-	Low-voltage fuses - Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) - Examples of standardized systems of fuses A to J	HD 60269-2	-
IEC 60269-3 (mod)	-	Low-voltage fuses - Part 3: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household or similar applications) - Examples of standardized systems of fuses A to F	HD 60269-3	-
IEC 60269-4	-	Low-voltage fuses - Part 4: Supplementary requirements for fuse-links for the protection of semiconductor devices	EN 60269-4	-
IEC 60364-4-41 (mod)	-	Low-voltage electrical installations - Part 4-41: Protection for safety - Protection against electric shock	HD 60364-4-41	-
IEC 60364-4-43 (mod)	-	Low voltage electrical installations - Part 4-43: Protection for safety - Protection against overcurrent	HD 60364-4-43	-
IEC 60364-5-52 (mod)	-	Low-voltage electrical installations - Part 5-52: Selection and erection of electrical equipment - Wiring systems	HD 60364-5-52	-
IEC/TR 60787	-	Application guide for the selection of high-voltage current-limiting fuse-links for transformer circuits	-	-
IEC 60947	Series	Low-voltage switchgear and controlgear	EN 60947	Series
IEC 60947-3	-	Low-voltage switchgear and controlgear - Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units	EN 60947-3	-

**S.R. CLC/TR 60269-5:2011**

CLC/TR 60269-5:2011

- 4 -

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60947-4-1	-	Low-voltage switchgear and controlgear - Part 4-1: Contactors and motor-starters - Electromechanical contactors and motor- starters	EN 60947-4-1	-
IEC/TR 61912-1	-	Low-voltage switchgear and controlgear - Overcurrent protective devices - Part 1: Application of short-circuit ratings	-	-

**CONTENTS**

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references .....	8
3 Terms and definitions .....	9
4 Fuse benefits.....	10
5 Fuse construction and operation.....	11
5.1 Components .....	11
5.2 Fuse-construction.....	11
5.2.1 Fuse link.....	11
5.2.2 Fuse-link contacts .....	13
5.2.3 Indicating device and striker .....	13
5.2.4 Fuse-base .....	13
5.2.5 Replacement handles and fuse-holders .....	13
5.3 Fuse operation .....	14
5.3.1 General .....	14
5.3.2 Fuse operation in case of short-circuit .....	14
5.3.3 Fuse operation in case of overload .....	14
6 Fuse-combination units .....	15
7 Fuse selection and markings .....	16
8 Conductor protection .....	18
8.1 General.....	18
8.2 Type gG .....	18
8.3 Types gN and gD .....	19
8.4 Types gR and gS.....	19
8.5 Protection against short-circuit current only.....	19
9 Selectivity of protective devices.....	20
9.1 General.....	20
9.2 Selectivity between fuses .....	21
9.2.1 Verification of selectivity for operating time $\geq 0,1$ s .....	21
9.2.2 Verification of selectivity for operating time $< 0,1$ s .....	22
9.2.3 Verification of total selectivity .....	22
9.3 Selectivity of circuit-breakers upstream of fuses .....	22
9.3.1 General .....	22
9.3.2 Verification of selectivity for operating time $\geq 0,1$ s .....	22
9.3.3 Verification of selectivity for operating time $< 0,1$ s .....	23
9.3.4 Verification of total selectivity .....	23
9.4 Selectivity of fuses upstream of circuit-breakers .....	23
9.4.1 General .....	23
9.4.2 Verification of selectivity for operating time $\geq 0,1$ s .....	23
9.4.3 Verification of selectivity for operating time $< 0,1$ s .....	23
9.4.4 Verification of total selectivity .....	23
10 Short-circuit damage protection .....	25
10.1 General.....	25
10.2 Short-circuit current paths .....	25

10.3	Current limitation .....	26
10.4	Rated conditional short-circuit current, rated breaking capacity .....	26
11	Protection of power factor correction capacitors .....	26
12	Transformer protection .....	27
12.1	Distribution transformers with a high-voltage primary .....	27
12.2	Distribution transformers with a low-voltage primary .....	28
12.3	Control circuit transformers .....	28
13	Motor circuit protection .....	28
13.1	General .....	28
13.2	Fuse and motor-starter coordination .....	29
13.3	Criteria for coordination at the rated conditional short-circuit current $I_q$ .....	29
13.4	Criteria for coordination at the crossover current $I_{co}$ .....	30
13.5	Criteria for coordination at test current “r” .....	31
14	Circuit-breaker protection .....	31
15	Protection of semiconductor devices .....	31
16	Fuses in enclosures .....	32
16.1	Limiting temperature of type gG fuse-links according to IEC 60269-2 – System A .....	32
16.2	Other fuse-links .....	33
17	DC applications .....	33
17.1	Short-circuit protection .....	33
17.2	Overload protection .....	33
17.3	Time-current characteristics .....	34
18	Automatic disconnection for protection against electric shock for installations in buildings .....	35
18.1	General .....	35
18.2	Principle of the protection .....	35
18.3	Examples .....	37
Annex A (informative) Coordination between fuses and contactors/motor-starters .....		38
Bibliography .....		48
Figure 1 – Typical fuse-link according to IEC 60269-2 .....		12
Figure 2 – Typical fuse-link according to IEC 60269-2 .....		13
Figure 3 – Current-limiting fuse operation .....		14
Figure 4 – Fuse operation on overload .....		15
Figure 5 – Selectivity – General network diagram .....		20
Figure 6 – Verification of selectivity between fuses $F_2$ and $F_4$ for operating time $t \geq 0,1$ s ....		21
Figure 7 – Verification of selectivity between circuit-breaker $C_2$ and fuses $F_5$ and $F_6$ .....		22
Figure 8 – Verification of selectivity between fuse $F_2$ and circuit-breaker $C_3$ for operating time $t \geq 0,1$ s .....		24
Figure 9 – Verification of selectivity between fuse $F_2$ and circuit-breaker $C_3$ for operating time $t < 0,1$ s .....		25
Figure 10 – Fuse and motor-starter coordination .....		30
Figure 11 – DC circuit .....		33
Figure 12 – DC breaking operation .....		34
Figure 13 – Fuse operating time at various d.c. circuit time constants .....		35



Figure 14 – Time-current characteristic.....	36
Figure A.1 – Collation of cut-off currents observed in successful coordination at $I_q$ .....	39
Figure A.2 – Pre-arcing and operating $I^2t$ values of fuses used in successful coordination tests as a function of contactor rated current AC3.....	40
Figure A.3 – Pre-arcing and operating $I^2t$ values of fuses used in successful coordination tests as a function of fuse rated current $I_n$ .....	41
Figure A.4 – Illustration of the method of selection of the maximum rated current of a fuse for back-up protection of a contactor of rating $I_e = X$ amperes .....	45
Figure A.5 – Withstand capabilities of a range of contactors and associated overload relays at test current "r" .....	46
Figure A.6 – Illustration of a method of deriving curves of maximum peak current at test current "r" as a function of fuse rated current (these derived curves can be used in the same way as illustrated in Figure A.4).....	47
Table 1 – Definitions and symbols of switches and fuse-combination units.....	16
Table 2 – Fuse application .....	17
Table 3 – Maximum operational voltage of fuse-links .....	18
Table 4 – Fuse selection for power factor correction capacitors (fuses according to IEC 60269-2, system A) .....	27
Table 5 – Time constants of typical d.c. circuits .....	34
Table A.1 – Examples of typical fuse-link ratings used for motor-starter protection illustrating how the category of fuse-link can influence the optimum current rating .....	38
Table A.2 (Table 12 of IEC 60947-4-1) – Value of the prospective test current according to the rated operational current.....	43
Table A.3 – Types of coordination.....	44

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

### **LOW-VOLTAGE FUSES –**

#### **Part 5: Guidance for the application of low-voltage fuses**

#### **FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC 60269-5, which is a technical report, has been prepared by subcommittee 32B: Low-voltage fuses, of IEC technical committee 32: Fuses.

This technical report cancels and replaces IEC/TR 61818, published in 2003, and IEC/TR 61459, published in 1996. It constitutes a minor revision by amending and restructuring the two replaced publications.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
32B/554/DTR	32B/566/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60269 series, under the general title: *Low-voltage fuses*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## INTRODUCTION

Fuses protect many types of equipment and switchgear against the effects of over-current which can be dramatic:

- thermal damage of conductors or bus-bars;
- vaporisation of metal;
- ionisation of gases;
- arcing, fire, explosion,
- insulation damage.

Apart from being hazardous to personnel, significant economic losses can result from downtime and the repairs required to restore damaged equipment.

Modern fuses are common overcurrent protective devices in use today, and as such provide an excellent cost effective solution to eliminate or minimize the effects of overcurrent.

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

- 
- Looking for additional Standards? Visit Intertek Inform Infostore
  - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-