



NSAI
Standards

Irish Standard
I.S. EN 50525-3-41:2011

Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (U_0/U) -- Part 3-41: Cables with special fire performance - Single core non-sheathed cables with halogen-free crosslinked insulation, and low emission of smoke

I.S. EN 50525-3-41:2011

Incorporating amendments/corrigenda issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation - recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

<i>This document replaces:</i> HD 22.9 S3:2007	<i>This document is based on:</i> EN 50525-3-41:2011 HD 22.9 S3:2007	<i>Published:</i> 6 May, 2011 22 February, 2007
This document was published under the authority of the NSAI and comes into effect on: 18 May, 2011		ICS number: 29.060.20
NSAI 1 Swift Square, Northwood, Santry Dublin 9	T +353 1 807 3800 F +353 1 807 3838 E standards@nsai.ie W NSAI.ie	Sales: T +353 1 857 6730 F +353 1 857 6729 W standards.ie
Údarás um Chaighdeáin Náisiúnta na hÉireann		

EUROPEAN STANDARD

EN 50525-3-41

NORME EUROPÉENNE

EUROPÄISCHE NORM

May 2011

ICS 29.060.20

Supersedes HD 22.9 S3:2007

English version

**Electric cables -
Low voltage energy cables of rated voltages up to and including 450/750 V
(U_0/U) -
Part 3-41: Cables with special fire performance -
Single core non-sheathed cables with halogen-free crosslinked insulation,
and low emission of smoke**

Câbles électriques -
Câbles d'énergie basse tension de tension
assignée au plus égale à 450/750 V
(U_0/U) -
Partie 3-41: Câbles à performances
spéciales au feu -
Conducteurs isolés en matériau
élastomère réticulé sans halogène, à
faible dégagement de fumée

Kabel und Leitungen -
Starkstromleitungen mit Nennspannungen
bis 450/750 V (U_0/U) -
Teil 3-41: Starkstromleitungen mit
verbessertem Verhalten im Brandfall -
Halogenfreie, raucharme Ader- und
Verdrahtungsleitungen mit vernetzter
Isolierung

This European Standard was approved by CENELEC on 2011-01-17. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

This European Standard was prepared by the Technical Committee CENELEC TC 20, Electric cables.

The text of the draft was submitted to the formal vote and was approved by CENELEC as EN 50525-3-41 on 2011-01-17.

This document, which is one of a multipart series, supersedes HD 22.9 S3:2007.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2012-01-17
 - latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2014-01-17
-

Contents

	Page
1 Scope	4
2 Normative references	4
3 Terms and definitions	5
4 Heat resistant cables (90 °C)	5
4.1 Cables for fixed wiring – H07Z-U and H07Z-R	5
4.2 Cables for fixed wiring – H07Z-K	5
4.3 Cables for internal wiring – H05Z-U	6
4.4 Cables for internal wiring – H05Z-K	7
Annex A (normative) Tests for cables to EN 50525-3-41	8
Annex B (normative) General data	9
Bibliography	11

Tables

Table A.1	8
Table B.1 – Cables with rigid conductor (450/750 V)	9
Table B.2 – Cables with flexible conductor (450/750 V)	10
Table B.3 – Cables with rigid conductor (300/500 V)	10
Table B.4 – Cables with flexible conductor (300/500 V)	10

1 Scope

EN 50525-3-41 applies to non-sheathed single core cables insulated with halogen-free crosslinked compound and having low emission of smoke and corrosive gases when exposed to fire.

NOTE 1 Low emission of smoke is checked in accordance with EN 61034-2. Low emission of corrosive gases is checked as part of the check for absence of halogens (see Annex B of EN 50525-1).

The cables are of rated voltages U_0/U up to and including 450/750 V.

NOTE 2 Cables rated 450/750 V may be used at 600/1 000 V when this cable is used in fixed installations with mechanical protection, within switchgear and control gear - see HD 516.

The cables are intended for fixed wiring applications.

The maximum conductor operating temperature for each of the cables in this standard is 90 °C.

NOTE 3 HD 516 contains extensive guidance on the safe use of cables in this standard.

This EN 50525-3-41 should be read in conjunction with EN 50525-1, which specifies general requirements.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE One or more references to the standards below are in respect of a specific sub-division of that standard, for instance a clause, a table, a class or a type. Cross-references to these standards are undated and, at all times, the latest version applies.

EN 50363-5	Insulating, sheathing and covering materials for low voltage energy cables - Part 5: Halogen-free, cross-linked insulating compounds
EN 50395	Electrical test methods for low voltage energy cables
EN 50396	Non electrical test methods for low voltage energy cables
EN 50525-1	Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (U_0/U) - Part 1: General requirements
EN 60228	Conductors of insulated cables (IEC 60228)
EN 60332-1-2	Tests on electric and optical fibre cables under fire conditions - Part 1-2: Test for vertical flame propagation for a single insulated wire or cable - Procedure for 1 kW pre-mixed flame (IEC 60332-1-2)
EN 60811-1-4	Insulating and sheathing materials of electric and optical cables - Common test methods - Part 1-4: General application - Tests at low temperature (IEC 60811-1-4)
EN 61034-2	Measurement of smoke density of cables burning under defined conditions - Part 2: Test procedure and requirements (IEC 61034-2)

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-