



NSAI
Standards

Standard Recommendation
S.R. CLC/TS 50544:2010

Low voltage d.c. surge protective device for traction systems - Selection and application rules for surge arresters

S.R. CLC/TS 50544:2010

Incorporating amendments/corrigenda issued since publication:

<i>This document replaces:</i>	<i>This document is based on:</i> CLC/TS 50544:2010	<i>Published:</i> 26 February, 2010
This document was published under the authority of the NSAI and comes into effect on: 10 March, 2010		ICS number: 29.120.50 29.280
NSAI 1 Swift Square, Northwood, Santry Dublin 9	T +353 1 807 3800 F +353 1 807 3838 E standards@nsai.ie W NSAI.ie	Sales: T +353 1 857 6730 F +353 1 857 6729 W standards.ie
Údarás um Chaighdeáin Náisiúnta na hÉireann		

ICS 29.120.50; 29.280

English version

**Low voltage d.c. surge protective device for traction systems -
Selection and application rules for surge arresters**

Parafoudres basse tension courant
continu pour traction -
Principes de choix et d'application
pour les parafoudres

Überspannungsschutzgeräte
für Niederspannungs-Gleichstrom-
Bahnsysteme -
Auswahl und Anwendungsregeln
für Überspannungsableiter

This Technical Specification was approved by CENELEC on 2009-12-25.

CENELEC members are required to announce the existence of this TS in the same way as for an EN and to make the TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: Avenue Marnix 17, B - 1000 Brussels

Foreword

This Technical Specification was prepared by the Technical Committee CENELEC TC 37A, Low voltage surge protective devices.

It also concerns the expertise of SC 9XC, Electric supply and earthing systems for public transport equipment and ancillary apparatus (Fixed installations), of Technical Committee CENELEC TC 9X, Electrical and electronic applications for railways.

The broad subject of overvoltage protection in d.c. traction systems need to address the approaches, requirements and definitions of several disciplines and TC's. Concerned European Standards are referenced for generic definitions.

This Technical Specification reflects the common practise of overvoltage protection in the d.c. traction community, as far as protection of equipment in the primary power supply is concerned (e.g. feeders, overhead contact lines, return circuits, power side of rolling stock).

Therefore, definitions and approaches in this Technical Specification, covering a specific application in line with EN 50526-1, are different for some aspects from the definitions and approaches in the EN 61643 series.

The text of the draft was circulated for voting in accordance with the Internal Regulations, Part 2, Subclause 11.3.3.3. and was approved by CENELEC as CLC/TS 50544 on 2009-12-25.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following date is proposed:

- latest date by which the existence of the CLC/TS
has to be announced at national level (doa) 2010-06-25

This Technical Specification will be withdrawn once the SC 9XC document ¹⁾ on the same subject is published.

¹⁾ Under development at the time of issue.

Contents

1	Scope	5
2	Normative references	5
3	Terms and definitions	5
	3.1 System voltages	5
	3.2 Arrester	7
4	Systems and equipment to be protected	9
	4.1 General	9
	4.2 Substations	9
	4.3 Overhead contact line system	10
	4.4 Return circuit	11
	4.5 Rolling stock	12
5	Supply voltages	13
6	Overvoltages	13
	6.1 Lightning overvoltages	13
	6.2 Switching overvoltages	14
7	Function and characteristics of MO surge arresters	14
	7.1 Basic function	14
	7.2 Characteristics	15
	7.3 Classification	16
8	Insulation co-ordination and application of MO surge arresters	17
	8.1 General	17
	8.2 Principles of insulation co-ordination	17
	8.3 Protective distance	19
	8.4 Protection level	22
	8.5 Surge arresters connected in parallel	22
9	Selection of MO surge arresters	23
	9.1 Continuous operating voltage U_c	23
	9.2 Arrester class	23
	9.3 Mechanical considerations	23
	Annex A (informative) Supply voltages	24
	Bibliography	25

Figures

Figure 1	– Protective circuit in a substation (principle arrangement)	10
Figure 2	– Principle of a protective circuit of a line (outdoor system)	11
Figure 3	– Installation of surge arresters on the overhead contact line and the running rails	12
Figure 4	– Surge arrester arrangement on a vehicle	13
Figure 5	– Current-voltage characteristic of an MO surge arrester	15
Figure 6	– Requirements and design of surge arresters	17
Figure 7	– Assumption for the calculation of the voltage at the open end of a line and for the determination of the protective distance L	20
Figure 8	– Voltage funnel and illustration of protective distance	21

Tables

Table 1 – Arrester classification and related parameters.....	16
Table 2 – Insulation levels	18
Table A.1 – Supply voltages.....	24

1 Scope

This Technical Specification applies to non linear metal-oxide resistor type surge arresters (MO surge arresters) without spark gaps designed to limit voltage surges on d.c. traction systems with nominal voltage up to 1 500 V.

This Technical Specification applies to protection of equipment.

Same principles for selection and application apply for MO surge arresters on d.c. traction systems with nominal voltage 3 000 V.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50122-2	Railway applications – Fixed installations – Part 2: Protective provisions against the effects of stray currents caused by d.c. traction systems
EN 50124-1	Railway applications – Insulation coordination – Part 1: Basic requirements – Clearances and creepage distances for all electrical and electronic equipment
EN 50163	Railway applications – Supply voltages of traction systems
EN 50526-1 ¹⁾	Railway applications – Fixed installations – D.C. surge arresters and voltage limiting devices – Part 1: Surge arresters
EN 60071-1	Insulation co-ordination – Part 1: Definitions, principles and rules (IEC 60071-1)
EN 62305-3	Protection against lightning – Part 3: Physical damage to structures and life hazard (IEC 62305-3, mod.)

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1 System voltages

3.1.1

nominal voltage

U_n

designated value for a system

[EN 50163]

3.1.2

highest permanent voltage

U_{max1}

maximum value of the voltage likely to be present indefinitely

[EN 50163]

¹⁾ At draft stage.

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-