



NSAI
Standards

Irish Standard
I.S. EN 60076-1:2011

Power transformers -- Part 1: General (IEC 60076-1:2011 (EQV))

I.S. EN 60076-1:2011

Incorporating amendments/corrigenda issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation - recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

<i>This document replaces:</i> EN 60076-1:1997/A1:2000 EN 60076-1:1997/A12:2002	<i>This document is based on:</i> EN 60076-1:2011 EN 60076-1:1997/A1:2000	<i>Published:</i> 4 November, 2011 8 November, 2000
This document was published under the authority of the NSAI and comes into effect on: 21 November, 2011		ICS number: 29.180
NSAI 1 Swift Square, Northwood, Santry Dublin 9	T +353 1 807 3800 F +353 1 807 3838 E standards@nsai.ie W NSAI.ie	Sales: T +353 1 857 6730 F +353 1 857 6729 W standards.ie
Údarás um Chaighdeáin Náisiúnta na hÉireann		

I.S. EN 60076-1:2011

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 60076-1

November 2011

ICS 29.180

Supersedes EN 60076-1:1997 + A1:2000 + A12:2002

English version

Power transformers -
Part 1: General
(IEC 60076-1:2011)

Transformateurs de puissance -
Partie 1: Généralités
(CEI 60076-1:2011)

Leistungstransformatoren -
Teil 1: Allgemeines
(IEC 60076-1:2011)

This European Standard was approved by CENELEC on 2011-05-25. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

I.S. EN 60076-1:2011

EN 60076-1:2011

- 2 -

Foreword

The text of document 14/675/FDIS, future edition 2 of IEC 60076-1, prepared by IEC TC 14, Power transformers, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 60076-1 on 2011-05-25.

This European Standard supersedes EN 60076-1:1997 + A1:2000 + A12:2002.

EN 60076-1:2011 includes the following significant technical changes with respect to EN 60076-1:1997:

- addition of a definition of harmonic content;
- addition of a subclause on transport;
- addition of functional method of specification;
- addition of connection symbols for single phase transformers;
- addition of safety and environmental requirements;
- addition of requirements for liquid preservation systems;
- addition of a clause on DC currents;
- addition of vacuum, pressure and leak tests on tanks;
- the requirements formerly in Annex A are now incorporated in the text and Annex A is now an informative checklist;
- informative annexes have been added on facilities for condition monitoring and environmental and safety considerations.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates were fixed:

- | | | |
|--|-------|------------|
| – latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement | (dop) | 2012-05-04 |
| – latest date by which the national standards conflicting with the EN have to be withdrawn | (dow) | 2014-05-25 |

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 60076-1:2011 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60060 series	NOTE	Harmonized in EN 60060 series (not modified).
IEC 60068-3-3	NOTE	Harmonized as EN 60068-3-3.
IEC 60076-4	NOTE	Harmonized as EN 60076-4.
IEC 60076-6	NOTE	Harmonized as EN 60076-6.
IEC 60076-13	NOTE	Harmonized as EN 60076-13.
IEC 60270	NOTE	Harmonized as EN 60270.
IEC 60310	NOTE	Harmonized as EN 60310.
IEC 60529:1989	NOTE	Harmonized as EN 60529:1991 (not modified).
IEC 61378 series	NOTE	Harmonized in EN 61378 series (not modified).
IEC 61378-1	NOTE	Harmonized as EN 61378-1.
IEC 61378-2	NOTE	Harmonized as EN 61378-2.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60076-2	-	Power transformers - Part 2: Temperature rise for liquid-immersed transformers	EN 60076-2	-
IEC 60076-3	2000	Power transformers - Part 3: Insulation levels, dielectric tests and external clearances in air	EN 60076-3	2001
IEC 60076-5	2006	Power transformers - Part 5: Ability to withstand short circuit	EN 60076-5	2006
IEC 60076-10	2001	Power transformers - Part 10: Determination of sound levels	EN 60076-10	2001
IEC 60076-11	2004	Power transformers - Part 11: Dry-type transformers	EN 60076-11	2004
IEC 60137	2008	Insulated bushings for alternating voltages above 1 000 V	EN 60137	2008
IEC 60214-1	2003	Tap-changers - Part 1: Performance requirements and test methods	EN 60214-1	2003
IEC 60296	2003	Fluids for electrotechnical applications - Unused mineral insulating oils for transformers and switchgear	EN 60296 + corr. September	2004 2004
IEC 60721-3-4	1995	Classification of environmental conditions - Part 3: Classification of groups of environmental parameters and their severities - Section 4: Stationary use at non-weatherprotected locations	EN 60721-3-4	1995
ISO 9001	2008	Quality management systems - Requirements	EN ISO 9001	2008

CONTENTS

FOREWORD.....	5
1 Scope.....	7
2 Normative references	8
3 Terms and definitions	8
3.1 General.....	8
3.2 Terminals and neutral point.....	9
3.3 Windings	10
3.4 Rating	11
3.5 Tappings	13
3.6 Losses and no-load current	15
3.7 Short-circuit impedance and voltage drop.....	16
3.8 Temperature rise	17
3.9 Insulation	17
3.10 Connections	17
3.11 Test classification.....	18
3.12 Meteorological data with respect to cooling	19
3.13 Other definitions.....	19
4 Service conditions	20
4.1 General.....	20
4.2 Normal service conditions	20
5 Rating and general requirements.....	22
5.1 Rated power.....	22
5.1.1 General	22
5.1.2 Preferred values of rated power.....	22
5.1.3 Minimum power under alternative cooling modes	22
5.1.4 Loading beyond rated power.....	23
5.2 Cooling mode	23
5.3 Load rejection on transformers directly connected to a generator	23
5.4 Rated voltage and rated frequency	23
5.4.1 Rated voltage	23
5.4.2 Rated frequency	23
5.4.3 Operation at higher than rated voltage and/or at other than rated frequency	24
5.5 Provision for unusual service conditions	24
5.6 Highest voltage for equipment U_m and dielectric tests levels.....	25
5.7 Additional information required for enquiry	25
5.7.1 Transformer classification.....	25
5.7.2 Winding connection and number of phases.....	25
5.7.3 Sound level	26
5.7.4 Transport.....	26
5.8 Components and materials	26
6 Requirements for transformers having a tapped winding.....	27
6.1 General – Notation of tapping range.....	27
6.2 Tapping voltage – tapping current. Standard categories of tapping voltage variation. Maximum voltage tapping.....	27
6.3 Tapping power. Full-power tappings – reduced-power tappings.....	30

6.4	Specification of tappings in enquiry and order	31
6.4.1	General	31
6.4.2	Constructional specification	31
6.4.3	Functional specification	32
6.5	Specification of short-circuit impedance	32
6.6	Load loss and temperature rise	33
7	Connection phase displacement symbols	34
7.1	Connection and phase displacement symbols for three-phase transformers and for single phase transformers connected in a three phase bank	34
7.1.1	Connection symbol	34
7.1.2	Phase displacement in clock number notation	34
7.1.3	Windings not intended to be loaded	35
7.1.4	Reconnectable windings	35
7.1.5	Examples	35
7.2	Connection and phase displacement symbols for single phase transformers not in three phase bank	37
7.2.1	Connection symbol	37
7.2.2	Phase displacement in clock number notation	38
7.2.3	Windings not intended to be loaded	38
7.2.4	Reconnectable windings	38
8	Rating plates	39
8.1	General	39
8.2	Information to be given in all cases	39
8.3	Additional information to be given when applicable	40
9	Safety, environmental and other requirements	41
9.1	Safety and environmental requirements	41
9.1.1	Liquid leaks	41
9.1.2	Safety considerations	41
9.2	Dimensioning of neutral connection	42
9.3	Liquid preservation system	42
9.4	DC currents in neutral circuits	43
9.5	Centre of gravity marking	43
10	Tolerances	43
11	Tests	44
11.1	General requirements for routine, type and special tests	44
11.1.1	General	44
11.1.2	Routine tests	46
11.1.3	Type tests	46
11.1.4	Special tests	47
11.2	Measurement of winding resistance	47
11.2.1	General	47
11.2.2	Dry-type transformers	47
11.2.3	Liquid-immersed type transformers	48
11.3	Measurement of voltage ratio and check of phase displacement	48
11.4	Measurement of short-circuit impedance and load loss	48
11.5	Measurement of no-load loss and current	49
11.6	Measurement of zero-sequence impedance(s) on three-phase transformers	50
11.7	Tests on on-load tap-changers – Operation test	51

11.8 Leak testing with pressure for liquid immersed transformers (tightness test).....	51
11.9 Vacuum deflection test for liquid immersed transformers	51
11.10 Pressure deflection test for liquid immersed transformers.....	52
11.11 Vacuum tightness test on site for liquid immersed transformers.....	53
11.12 Check of core and frame insulation	53
12 Electromagnetic compatibility (EMC)	53
13 High frequency switching transients.....	54
Annex A (informative) Check list of information to be provided with enquiry and order	55
Annex B (informative) Examples of specifications for transformers with tapplings	59
Annex C (informative) Specification of short-circuit impedance by boundaries	63
Annex D (informative) Examples of three-phase transformer connections	64
Annex E (normative) Temperature correction of load loss	67
Annex F (informative) Facilities for future fitting of condition monitoring systems to transformers	68
Annex G (informative) Environmental and safety considerations	69
Bibliography.....	70
 Figure 1 – Different types of voltage variation	 30
Figure 2 – Illustration of 'clock number' notation	35
Figure 3 – Illustration of 'clock number' notation for transformers with open windings	37
Figure 4 – Illustration of 'clock number' notation	39
Figure C.1 – Example of specification of short-circuit impedance by boundaries	63
Figure D.1 – Common connections	64
Figure D.2 – Additional connections.....	65
Figure D.3 – Designation of connections of three-phase auto-transformers by connection symbols (auto-transformer Ya0)	66
Figure D.4 – Example of three single-phase transformers connected to form a three- phase bank (connection symbol Yd5).....	66
 Table 1 – Tolerances	 44
Table B.1 – Example of combined voltage variation	60
Table B.2 – Example of functional specification with HV voltage variation.....	61
Table B.3 – Example of functional specification with LV voltage variation	62
Table F.1 – Facilities for condition monitoring	68

INTERNATIONAL ELECTROTECHNICAL COMMISSION

POWER TRANSFORMERS –

Part 1: General

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60076-1 has been prepared by IEC technical committee 14: Power transformers.

This third edition cancels and replaces the second edition published in 1993, and its Amendment 1(1999). It is a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- addition of a definition of harmonic content;
- addition of a subclause on transport;
- addition of functional method of specification;
- addition of connection symbols for single phase transformers;
- addition of safety and environmental requirements;
- addition of requirements for liquid preservation systems;

- addition of a clause on DC currents;
- addition of vacuum, pressure and leak tests on tanks;
- the requirements formerly in Annex A are now incorporated in the text and Annex A is now an informative checklist;
- informative annexes have been added on facilities for condition monitoring and environmental and safety considerations.

The text of this standard is based on the following documents:

FDIS	Report on voting
14/675/FDIS	14/682/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60076 series can be found, under the general title *Power transformers*, on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

POWER TRANSFORMERS –

Part 1: General

1 Scope

This part of IEC 60076 applies to three-phase and single-phase power transformers (including auto-transformers) with the exception of certain categories of small and special transformers such as:

- single-phase transformers with rated power less than 1 kVA and three-phase transformers less than 5 kVA;
- transformers, which have no windings with rated voltage higher than 1 000 V;
- instrument transformers;
- traction transformers mounted on rolling stock;
- starting transformers;
- testing transformers;
- welding transformers;
- explosion-proof and mining transformers;
- transformers for deep water (submerged) applications.

When IEC standards do not exist for such categories of transformers (in particular transformer having no winding exceeding 1000 V for industrial applications), this part of IEC 60076 may still be applicable either as a whole or in part.

This standard does not address the requirements that would make a transformer suitable for mounting in a position accessible to the general public.

For those categories of power transformers and reactors which have their own IEC standards, this part is applicable only to the extent in which it is specifically called up by cross-reference in the other standard. Such standards exist for:

- reactors in general (IEC 60076-6);
- dry-type transformers (IEC 60076-11);
- self-protected transformers (IEC 60076-13);
- gas-filled power transformers (IEC 60076-15);
- transformers for wind turbine applications (IEC 60076-16);
- traction transformers and traction reactors (IEC 60310);
- converter transformers for industrial applications (IEC 61378-1);
- converter transformers for HVDC applications (IEC 61378-2).

At several places in this part it is specified or recommended that an 'agreement' should be reached concerning alternative or additional technical solutions or procedures. Such agreement is made between the manufacturer and the purchaser. The matters should preferably be raised at an early stage and the agreements included in the contract specification.

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-