



NSAI
Standards

Standard Recommendation
S.R. CLC/TS 61850-80-1:2010

Communication networks and systems
for power utility automation -- Part 80
-1: Guideline to exchanging information
from a CDC-based data model using IEC
60870-5-101 or IEC 60870-5-104
(IEC/TS 61850-80-1:2008 (EQV))

S.R. CLC/TS 61850-80-1:2010

Incorporating amendments/corrigenda issued since publication:

<i>This document replaces:</i>	<i>This document is based on:</i> CLC/TS 61850-80-1:2010	<i>Published:</i> 5 February, 2010
This document was published under the authority of the NSAI and comes into effect on: 10 March, 2010		ICS number: 33.200
NSAI 1 Swift Square, Northwood, Santry Dublin 9	T +353 1 807 3800 F +353 1 807 3838 E standards@nsai.ie W NSAI.ie	Sales: T +353 1 857 6730 F +353 1 857 6729 W standards.ie
Údarás um Chaighdeáin Náisiúnta na hÉireann		

TECHNICAL SPECIFICATION
SPÉCIFICATION TECHNIQUE
TECHNISCHE SPEZIFIKATION

CLC/TS 61850-80-1

February 2010

ICS 33.200

English version

**Communication networks and systems for power utility automation -
Part 80-1: Guideline to exchanging information from a CDC-based data
model using IEC 60870-5-101 or IEC 60870-5-104
(IEC/TS 61850-80-1:2008)**

Kommunikationsnetze und -systeme für
die Automatisierung in der elektrischen
Energieversorgung -
Teil 80-1: Leitfaden
zum Informationsaustausch
mit einer Datenbasis,
die auf gemeinsamen Datenklassen
beruht, mit Hilfe von IEC 60870-5-101
oder IEC 60870-5-104
(IEC/TS 61850-80-1:2008)

This Technical Specification was approved by CENELEC on 2009-12-11.

CENELEC members are required to announce the existence of this TS in the same way as for an EN and to make the TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: Avenue Marnix 17, B - 1000 Brussels

Foreword

This Technical Specification consists of the text of the International Technical Specification IEC 61850-80-1:2008 prepared by IEC TC 57, Power systems management and associated information exchange.

It was circulated for voting in accordance with the Internal Regulations, Part 2, Subclause 11.3.3.3 and was accepted as a CENELEC Technical Specification on 2009-12-11.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following date was fixed:

- latest date by which the existence of the CLC/TS
has to be announced at national level (doa) 2010-06-11

Annex ZA has been added by CENELEC.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE Where an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60870-5-3	-	Telecontrol equipment and systems Part 5-3: Transmission protocols - General structure of application data	EN 60870-5-3	-
IEC 60870-5-4	1993	Telecontrol equipment and systems Part 5-4: Transmission protocols – Definition and coding of application information elements	EN 60870-5-4	1993
IEC 60870-5-5	1995	Telecontrol equipment and systems Part 5-5: Transmission protocols - Basic application functions	EN 60870-5-5	1995
IEC 60870-5-101	2003	Telecontrol equipment and systems Part 5-101: Transmission protocols - Companion standard for basic telecontrol tasks	EN 60870-5-101	2003
IEC 60870-5-104	2006	Telecontrol equipment and systems Part 5-101: Transmission protocols - Network access for IEC 60870-5-101 using standard transport profiles	EN 60870-5-104	2006
IEC 61400-25-2	-	Wind turbines Part 25-2: Communications for monitoring and control of wind power plants - Information models	EN 61400-25-2	-
IEC 61850	Series	Communication networks and systems in substations	EN 61850	Series
IEC 61850-6	-	Communication networks and systems in substations Part 6: Configuration description language for communication in electrical substations related to IEDs	EN 61850-6	-

S.R. CLC/TS 61850-80-1:2010

CLC/TS 61850-80-1:2010

- 4 -

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61850-7-2	2003	Communication networks and systems in substations Part 7-2: Basic communication structure for substation and feeder equipment - Abstract communication service interface (ACSI)	EN 61850-7-2	2003
IEC 61850-7-3	-	Communication networks and systems in substations Part 7-3: Basic communication structure for substation and feeder equipment - Common data classes	EN 61850-7-3	-
IEC 61850-8-1	-	Communication networks and systems in substations Part 8-1: Specific Communication Service Mapping (SCSM) - Mappings to MMS (ISO 9506-1 and ISO 9506-2) and to ISO/IEC 8802-3	EN 61850-8-1	-
57/963/INF	-	IEC 61850 – Technical issues (www.tissue.iec61850.com)	-	-
IEEE 754	2008	Binary floating-point arithmetic	-	-
RFC 2200	June 1997	Internet official protocol standards – Request for comments 2200	-	-

CONTENTS

FOREWORD.....	6
1 Scope and object.....	8
2 Normative references	8
3 Abbreviated terms	9
4 The mapping architecture	10
5 Conceptual architectures and associated use cases	11
5.1 Conceptual architecture of a gateway device.....	11
5.2 Conceptual architecture of an IED directly connected to a WAN (optional)	15
6 Mapping of a device-oriented information model to IEC 60870-5-104 or IEC 60870-5-101	16
6.1 General.....	16
6.2 Mapping of a device-oriented information model reference	16
6.3 Logical device class mapping	17
6.4 Logical node class mapping	17
7 Mapping of the common data classes (CDC)	17
7.1 List of CDC, type Identifications and corresponding mappings for IEC 61850	17
7.2 CDC single point status (SPS).....	20
7.3 CDC double point status (DPS)	20
7.4 CDC integer status (INS).....	21
7.5 CDC protection activated information (ACT)	23
7.6 CDC directional protection activation information (ACD).....	25
7.7 CDC Security violation counting (SEC).....	27
7.8 CDC binary counter reading (BCR).....	28
7.9 CDC measured value (MV).....	29
7.10 CDC complex measured value (CMV).....	30
7.11 CDC Phase to ground related measured values of a three-phase system (WYE)	32
7.12 CDC phase to phase measured values of a three phase system (DEL).....	32
7.13 CDC sequence (SEQ)	33
7.14 CDC harmonic value (HMV).....	34
7.15 CDC harmonic value for WYE (HWYE)	35
7.16 CDC harmonic value for DEL (HDEL)	35
7.17 CDC controllable single point (SPC).....	36
7.18 CDC controllable double point (DPC)	38
7.19 CDC controllable integer status (INC).....	40
7.20 CDC binary controlled step position information (BSC).....	42
7.21 CDC integer-controlled step position information (ISC).....	44
7.22 CDC controllable analogue set point information (APC).....	46
7.23 CDC Single point setting (SPG).....	47
7.24 CDC integer status setting (ING)	48
7.25 CDC analogue settings (ASG)	48
8 Mapping of services.....	48
8.1 List of service models and corresponding mappings	48
8.2 Server class mapping	50
8.3 Association class mapping	50
8.4 Logical node class mapping	51
8.5 Data class mapping.....	52

8.6	Setting group class mapping	53
8.7	Report control block class mapping	54
8.8	Control class mapping	54
9	Protocol stack selections for IEC 60870-5-101 and IEC 60870-5-104	76
9.1	General	76
9.2	Structure of application data	76
9.3	IEC 60870-5 interoperability	77
Annex A (informative) Use of SCL (substation configuration language) to include IEC 60870-5-101 or IEC 60870-5-104 information		104
Figure 1	– Conceptual architecture of a gateway device	11
Figure 2	– Use case a) for a gateway device	12
Figure 3	– Use case b) for a gateway device	13
Figure 4	– Use case c) for a gateway device	14
Figure 5	– Conceptual architecture of an IED	15
Figure 6	– Mapping architecture (conceptual)	17
Figure 7	– Direct control with normal security with status update – positive case applied to gateway device	55
Figure 8	– Direct control with normal security with status update – positive case applied to IED	56
Figure 9	– Direct control with normal security in general – negative case a) applied to gateway device	56
Figure 10	– Direct control with normal security in general – negative case a) applied to IED	57
Figure 11	– Direct control with normal security in general – negative case b) applied to gateway device	57
Figure 12	– Direct control with normal security in general – negative case b) applied to IED	58
Figure 13	– Direct control with normal security with status update – negative case c) applied to gateway device	58
Figure 14	– Direct control with normal security with status update – negative case c) applied to IED	59
Figure 15	– Direct control with normal security without status update – positive case applied to gateway device	59
Figure 16	– Direct control with normal security without status update – positive case applied to IED	60
Figure 17	– Direct control with enhanced security – positive case applied to gateway device	62
Figure 18	– Direct control with enhanced security – positive case applied to IED	63
Figure 19	– Direct control with enhanced security – negative case c) applied to gateway device	64
Figure 20	– Direct control with enhanced security – negative case c) applied to IED	64
Figure 21	– Direct control with enhanced security – negative case d) applied to gateway device	65
Figure 22	– Direct control with enhanced security – negative case d) applied to IED	65
Figure 23	– SBOw control – positive case applied to gateway device	67
Figure 24	– SBOw control – positive case applied to IED	67
Figure 25	– SBOw control – negative case a) applied to gateway device	68
Figure 26	– SBOw control – negative case a) applied to IED	68

Figure 27 – SBOw control – negative case b) applied to gateway device	69
Figure 28 – SBOw control – negative case b) applied to IED	69
Figure 29 – SBOw control – negative case c) applied to gateway device	70
Figure 30 – SBOw control – negative case c) applied to IED	70
Figure 31 – SBO with enhanced security – positive case applied to gateway device	71
Figure 32 – SBO with enhanced security – positive case applied to IED	72
Figure 33 – SBO with enhanced security – negative case a) applied to gateway device	72
Figure 34 – SBO with enhanced security – negative case a) applied to IED	73
Figure 35 – SBO with enhanced security – negative case b) applied to gateway device	73
Figure 36 – SBO with enhanced security – negative case b) applied to IED	74
Table 1 – Mapping structure CDC onto ASDU type	18
Table 2 – CDC: Single point status (SPS)	20
Table 3 – CDC: Single point status (SPS) mapping	20
Table 4 – CDC: Double point status (DPS)	20
Table 5 – CDC: Double point status (DPS) mapping	21
Table 6 – CDC: Integer status (INS)	21
Table 7 – CDC: Integer status (INS) mapping	22
Table 8 – CDC: Protection activated information (ACT)	23
Table 9 – CDC: Protection activated information (ACT) mapping	24
Table 10 – CDC: Protection activated information (ACD)	25
Table 11 – CDC: Directional protection activated information (ACD) mapping	26
Table 12 – CDC: Security violation counting (SEC)	27
Table 13 – CDC: Security violation counting (SEC) mapping	27
Table 14 – CDC: Binary counter reading (BCR)	28
Table 15 – CDC: Binary counter reading (BCR) mapping	28
Table 16 – CDC: Measured value (MV)	29
Table 17 – CDC: Measured value (MV) mapping	29
Table 18 – CDC: Complex measured value (CMV)	30
Table 19 – CDC: Complex measured value (CMV) mapping	31
Table 20 – CDC: Phase to ground related measured values of a three-phase system (WYE)	32
Table 21 – CDC: Phase to phase measured values of a three phase system (DEL)	33
Table 22 – CDC: Sequence (SEQ)	33
Table 23 – CDC: Harmonic value (HMV)	34
Table 24 – CDC: Harmonic value (HMV) mapping	34
Table 25 – CDC: Harmonic value for WYE (HWYE)	35
Table 26 – CDC: Harmonic value for DEL (HDEL)	35
Table 27 – CDC: Controllable single point (SPC)	36
Table 28 – CDC: Controllable single point (SPC) mapping	37
Table 29 – CDC: Controllable double point (DPC)	38
Table 30 – CDC: Controllable double point (DPC) mapping	39
Table 31 – CDC: Controllable integer status (INC)	40

S.R. CLC/TS 61850-80-1:2010

TS 61850-80-1 © IEC:2008(E)

– 5 –

Table 32 – CDC: Controllable integer status (INC) mapping	41
Table 33 – CDC: Binary controlled step position information (BSC).....	42
Table 34 – CDC: Binary controlled step position information (BSC) mapping of data attributes of the functional constraint ST	42
Table 35 – CDC: Binary controlled step position information (BSC) mapping of data attributes of the functional constraint CO	43
Table 36 – CDC: Integer-controlled step position information (ISC).....	44
Table 37 – CDC: Integer-controlled step position information (ISC) mapping	45
Table 38 – CDC: Controllable analogue set point information (APC)	46
Table 39 – CDC: Controllable analogue set point information (APC) mapping of data attributes of the functional constraint MX	46
Table 40 – CDC: Controllable analogue set point information (APC) mapping of data attributes of the functional constraint SP	47
Table 41 – CDC: Single point setting (SPG).....	47
Table 42 – CDC: Integer status setting (ING).....	48
Table 43 – CDC: Analogue settings (ASG).....	48
Table 44 – Services requiring client/server communication profile.....	49
Table 45 – Server services mapping	50
Table 46 – Association services mapping.....	50
Table 47 – Logical nodes services mapping	51
Table 48 – Data services mapping	52
Table 49 – Setting group services mapping.....	53
Table 50 – Report control block services mapping	54
Table 51 – Direct control with normal security services mapping	61
Table 52 – Direct control with enhanced security services mapping	66
Table 53 – SBO control with enhanced security services mapping	74
Table A.1 – Extension of the “P” element types to hold IEC 60870-5-101 information	133
Table A.2 – Extension of the “P” element types to hold IEC 60870-5-104 information	135
Table A.3 – Extension of the “P” element types using redundancy groups.....	136

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 80-1: Guideline to exchanging information from a CDC- based data model using IEC 60870-5-101 or IEC 60870-5-104

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC 61850-80-1, which is a technical specification, has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

The text of this technical specification is based on the following documents:

Enquiry draft	Report on voting
57/916/DTS	57/969/RVC

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The bold characters in some tables are used to highlight the most essential terms or functions inside the figures to improve readability. Shading of parts of the figures is used for the same purpose.

A list of all parts of the IEC 61850 series, published under the general title *Communication networks and systems for power utility automation*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard,
- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual edition of this document may be issued at a later date.

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 80-1: Guideline to exchanging information from a CDC- based data model using IEC 60870-5-101 or IEC 60870-5-104

1 Scope and object

This technical specification gives a guideline on how to exchange information from a CDC-based data model (for example IEC 61850) using IEC 60870-5-101 or IEC 60870-5-104 between substation(s) and control center(s). Mostly guidelines for functions needed in a substation gateway device are given.

The goal of this technical specification is to describe standardized mapping of device-oriented data models (for example IEC 61850) with already defined attributes of CDC's and services (for example IEC 61850-7) onto the already defined ASDU's and services of IEC 60870-5-104 or IEC 60870-5-101. It is not the goal of this technical specification to add any extensions to published standards (for example IEC 61850 or IEC 60870-5-104 or IEC 60870-5-101).

After an introduction giving a basic description of the mapping, the mapping of the information model with associated data classes, and the mapping of services are described. Clause 9 shows how the mapped data and services according to the IEC 60870-5-104 and IEC 60870-5-101 protocol are marked (selected) in the interoperability sheet.

The scope of this technical specification is to achieve real-time exchange of process information required for operational purposes between a substation using a CDC-based data model (for example IEC 61850) and (a) control centre(s) using a communication link over a wide area network (WAN) compliant to the definitions of IEC 60870-5-101 or IEC 60870-5-104. The amount of real-time information provided by the substation-gateway device can vary dependent on the operational needs. Actors could be regional and nationwide control centers that receive real-time information in order to monitor and control geographically widespread processes. The described mapping can be used for several fields of application of power utilities, such as substations, hydro and wind power plants, and decentralized energy resources DER. The mapping is based on the definitions of the standard series IEC 61850 Edition 1.0 and IEC 60870-5-104:2006/IEC 60870-5-101:2003. The scope of the mapped IEC 60870-5-104 and IEC 60870-5-101 subset is given in Clause 9.

This technical specification focuses mainly on defining rules and functions of a gateway device as a part of the substation. However, the rules and functions are also valid when an IED may optionally be connected directly to a WAN compliant with IEC 60870-5-101 or IEC 60870-5-104 and therefore, the mapping has to be done inside the IED.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60870-5-3, *Telecontrol equipment and systems – Part 5: Transmission protocols – Section 3: General structure of application data*

IEC 60870-5-4:1993, *Telecontrol equipment and systems – Part 5: Transmission protocols – Section 4: Definition and coding of application information elements*

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-