



NSAI
Standards

Irish Standard
I.S. EN 60118-15:2012

Electroacoustics - Hearing aids -- Part
15: Methods for characterising signal
processing in hearing aids with a
speech-like signal (IEC 60118-15:2012
(EQV))

I.S. EN 60118-15:2012

Incorporating amendments/corrigenda issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation - recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

<i>This document replaces:</i>	<i>This document is based on:</i> EN 60118-15:2012	<i>Published:</i> 13 April, 2012
This document was published under the authority of the NSAI and comes into effect on: 20 April, 2012		ICS number: 17.140.50
NSAI 1 Swift Square, Northwood, Santry Dublin 9	T +353 1 807 3800 F +353 1 807 3838 E standards@nsai.ie W NSAI.ie	Sales: T +353 1 857 6730 F +353 1 857 6729 W standards.ie
Údarás um Chaighdeáin Náisiúnta na hÉireann		

English version

**Electroacoustics -
Hearing aids -
Part 15: Methods for characterising signal processing in hearing aids with
a speech-like signal
(IEC 60118-15:2012)**

Electroacoustique -
Appareils de correction auditive -
Partie 15: Méthodes de caractérisation du
traitement des signaux dans les appareils
de correction auditive avec un signal de
type parole
(CEI 60118-15:2012)

Akustik -
Hörgeräte -
Teil 15: Methoden zur Charakterisierung
der Hörgeräte-Signalverarbeitung
(IEC 60118-15:2012)

This European Standard was approved by CENELEC on 2012-03-27. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

I.S. EN 60118-15:2012

EN 60118-15:2012

- 2 -

Foreword

The text of document 29/719/CDV, future edition 1 of IEC 60118-15, prepared by IEC/TC 29 "Electroacoustics" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60118-15:2012.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2012-12-27
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2015-03-27

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 60118-15:2012 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

- | | | |
|-------------------------------|------|---|
| IEC 61669 | NOTE | Harmonized as EN 61669. |
| IEC 60118-0:1983
+ A1:1994 | NOTE | Harmonized as EN 60118-0:1993 + A1:1994 (not modified). |

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60118-7	-	Electroacoustics - Hearing aids - Part 7: Measurement of the performance characteristics of hearing aids for production, supply and delivery quality assurance purposes	EN 60118-7	-
IEC 60118-8	2005	Electroacoustics - Hearing aids - Part 8: Methods of measurement of performance characteristics of hearing aids under simulated in situ working conditions	EN 60118-8	2005
IEC 60318-4	-	Electroacoustics - Simulators of human head and ear - Part 4: Occluded-ear simulator for the measurement of earphones coupled to the ear by means of ear inserts	EN 60318-4	-
IEC 60318-5	-	Electroacoustics - Simulators of human head and ear - Part 5: 2 cm ³ coupler for the measurement of hearing aids and earphones coupled to the ear by means of ear inserts	EN 60318-5	-
IEC 61260	-	Electroacoustics - Octave-band and fractional-octave-band filters	EN 61260	-

This page is intentionally left BLANK.

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references.....	7
3 Terms and definitions.....	8
4 Limitations.....	9
5 Setup.....	9
5.1 System overview.....	9
5.2 Estimated insertion gain.....	11
5.3 Coupler gain.....	12
6 Test equipment.....	12
6.1 Acoustical requirements.....	12
6.2 Test signal.....	13
6.2.1 Specification of ISTS.....	13
6.2.2 Shaping of the test signal for determining the EIG.....	14
6.3 Earphone coupler and attachments.....	15
6.3.1 Estimated insertion gain.....	15
6.3.2 Coupler gain.....	15
7 Test conditions.....	15
7.1 Programming of hearing aid.....	15
7.2 End user settings for programming.....	16
7.2.1 Hearing aid features.....	16
7.2.2 Vent selection for programming.....	16
7.2.3 Directionality.....	16
7.3 Audiograms for a typical end-user.....	16
8 Measurements and analysis.....	18
8.1 Measurements.....	18
8.1.1 General.....	18
8.1.2 Estimated insertion gain (EIG).....	19
8.1.3 Coupler gain (optional for 2 cm ³ coupler).....	19
8.2 Analysis.....	19
8.2.1 General.....	19
8.2.2 Compensating for hearing aid processing delay.....	21
8.2.3 Correction for use of 2 cm ³ coupler for EIG determination.....	21
8.2.4 Calculation of the estimated insertion gain for the LTASS of the ISTS (LTASS EIG).....	21
8.2.5 Calculation of the coupler gain for the LTASS of the ISTS (LTASS coupler gain) (optional).....	22
8.2.6 Sectioning of recorded signals for percentile calculations.....	22
8.2.7 Calculation of the EIG for the 30 th , 65 th and 99 th percentiles of the ISTS (percentile EIG).....	23
8.2.8 Calculation of the coupler gain for the 30 th , 65 th and 99 th percentiles of the ISTS (Percentile coupler gain) (optional).....	23
9 Data presentation.....	24
9.1 LTASS gain (LTASS EIG or LTASS coupler gain).....	24
9.2 Percentile gain (percentile EIG or percentile coupler gain).....	25

9.3 Interpretation of gain views	26
9.3.1 LTASS gain view	26
9.3.2 Percentile gain view	26
9.4 Mandatory data	27
Annex A (informative) International speech test signal (ISTS)	28
Bibliography.....	32
Figure 1 – Measurement setup for the estimated insertion gain.....	11
Figure 2 – Measurement setup for the coupler gain.....	12
Figure 3 – ISTS 30 th , 65 th , 99 th percentiles and LTASS in dB versus one-third-octave bands	14
Figure 4 – Standard audiograms for the flat and moderately sloping group	17
Figure 5 – Standard audiograms for the steep sloping group.....	18
Figure 6 – Overview of analysis	20
Figure 7 – Time alignment of output signal (y) relative to the input signal (x)	21
Figure 8 – Sectioning of recorded signals	22
Figure 9 – Illustration of the method for obtaining "time aligned gain" for the 65 th percentile.....	24
Figure 10 – LTASS gain at 3 input sound pressure levels	24
Figure 11 – LTASS gain at 3 input levels relative the LTASS gain at 65 dB input sound pressure level	25
Figure 12 – Percentile gain for 3 percentiles and corresponding LTASS gain	25
Figure A.1 – ISTS level distributions for five third-octave bands as measured from 50 % overlapping 125 ms sections of the ISTS	31
Table 1 – ISTS 30 th , 65 th , 99 th percentiles and LTASS in dB at one-third-octave bands	14
Table 2 – Standard audiograms for the flat and moderately sloping group.....	17
Table 3 – Standard audiograms for the steep sloping group.....	18
Table 4 – Recommended coupler correction values when using the 2 cm ³ coupler	21

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTROACOUSTICS –
HEARING AIDS –**
**Part 15: Methods for characterising signal processing
in hearing aids with a speech-like signal**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60118-15 has been prepared by IEC technical committee 29: Electroacoustics.

The text of this standard is based on the following documents:

CDV	Report on voting
29/719/CDV	29/730A/RVC

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of IEC 60118 series, published under the general title *Electroacoustics – Hearing aids*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The characterisation of hearing aids in actual use can differ significantly from those determined in accordance with standards such as IEC 60118-0 and IEC 60118-7. These standards use non speech-like test signals with the hearing aid set to specific settings which are, in general, not comparable with typical user settings.

This standard describes a recommended speech-like test signal, the International Speech Test Signal (ISTS), and a method for the characterisation of hearing aids using this signal with the hearing aid set to actual user settings or to the manufacturers' recommended settings for one of a range of audiograms. For the purposes of this standard the hearing aid is considered to be a combination of the physical hearing aid and the fitting software which accompanies it.

ELECTROACOUSTICS – HEARING AIDS –

Part 15: Methods for characterising signal processing in hearing aids with a speech-like signal

1 Scope

This part of IEC 60118 specifies a test signal designed to represent normal speech, the International Speech Test Signal (ISTS), together with the procedures and the requirements for measuring the characteristics of signal processing in air-conduction hearing aids. The measurements are used to derive the estimated insertion gain (EIG). For the purposes of characterizing a hearing aid for production, supply and delivery, the procedures and requirements to derive the coupler gain on a 2 cm³ coupler as defined in IEC 60318-5 are also specified.

The procedure uses a speech-like test signal and the hearing aid settings are set to those programmed for an individual end-user or those recommended by the manufacturer for a typical end-user for a range of flat, moderately sloping or steep sloping audiograms, so that the measured characteristics are comparable to those which may be obtained by a wearer at typical user settings.

The purpose of this standard is to ensure that the same measurements made on a hearing aid following the procedures described, and using equipment complying with these requirements, give substantially the same results.

Measurements of the characteristics of signal processing in hearing aids which apply non-linear processing techniques are valid only for the test signal used. Measurements which require a different test signal or test conditions are outside the scope of this standard.

Conformance to the specifications in this standard is demonstrated only when the result of a measurement, extended by the actual expanded uncertainty of measurement of the testing laboratory, lies fully within the tolerances specified in this standard as given by the values given in 6.1.

Measurement methods that take into account the acoustic coupling of a hearing aid to the individual ear and the acoustic influence of the individual anatomical variations of an end-user on the acoustical performance of the hearing aid, known as real-ear measurements, are outside the scope of this particular standard.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60118-7, *Electroacoustics – Hearing aids – Part 7: Measurement of the performance characteristics of hearing aids for production, supply and delivery quality assurance purposes*

IEC 60118-8:2005, *Electroacoustics – Hearing aids – Part 8: Methods of measurement of performance characteristics of hearing aids under simulated in situ working conditions*

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-