



NSAI
Standards

Code of Practice
I.C.P. 2:1982

Slating and Tiling

© NSAI 1982 No copying without NSAI permission except as permitted by copyright law.

Superseded

I.C.P. 2:1982

Incorporating amendments/corrigenda/National Annexes issued since publication:

I.C.P. 2:1982/A1:1986

I.C.P. 2:1982/A2:1994

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation - recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

<i>This document replaces:</i>	<i>This document is based on:</i> I.C.P. 2:1982	<i>Published:</i> 22 October, 1982
This document was published under the authority of the NSAI and comes into effect on: 22 October, 1982		ICS number: 91.060.20
NSAI 1 Swift Square, Northwood, Santry Dublin 9	T +353 1 807 3800 F +353 1 807 3838 E standards@nsai.ie W NSAI.ie	Sales: T +353 1 857 6730 F +353 1 857 6729 W standards.ie
Údarás um Chaighdeáin Náisiúnta na hÉireann		

NATIONAL STANDARDS AUTHORITY OF IRELAND
GAS TECHNICAL STANDARDS COMMITTEE

AMENDMENT

NO. 2 : 1994

OF

IRISH CODE OF PRACTICE (SLATING AND TILING)

I.C.P. 2:1982

1. (i) Where the words "asbestos-cement" appear in the code alter them to read "fibre-cement".

(ii) (a) Alter all references to "Irish Standard 3, Concrete Roofing Tiles" to read "I.S./EN 490 : 1994, Concrete Roofing Tiles and Fittings – Product Specifications".

(b) Alter all references to "I.S. 3" to read "I.S./EN 490".

(iii) (a) Alter all references to "I.S.7: Part 1, Asbestos-Cement Slates" to read "I.S./EN 492: 1994: Fibre-Cement Slates and their Fittings for Roofing – Product Specification and Test Methods".

(b) Alter all references to " I.S. 7 and I.S. 7: Part 1 " to read "I.S./EN 492".

2. Sub-Clause 4.5.3; Delete the existing title and substitute "Handling and cutting fibre – cement slates which contain asbestos fibres".

NOTES TO USERS

For Information Only

This amendment is necessary because of the publication of I.S./EN 490 and I.S./EN 492 and the consequent revocation of I.S. 3 and I.S. 7:Part 1.

AMENDMENT

No. 1 : 1986

OF

I.C.P. 2 : 1982

SLATING AND TILING

Clause 14: Delete table No. 1 and substitute the following table:

Table 1: Minimum Batten Sizes

Roofing Material	Span					
	400 and 450 mm			600 mm		
	Width	x	Depth	Width	x	Depth
Single Lap Concrete Tiles	44	x	35	44	x	35
Asbestos-Cement Slates	44	x	35	44	x	35

Note 1: (to table 1). Delete the existing text and substitute the following:

' As these sizes are minima, to ensure compliance with the table it may be necessary to use battens having a nominal size greater than these minima'.

IRISH CODE OF PRACTICE

SLATING AND TILING

I.C.P. 2 : 1982

*Published by the Institute for Industrial Research and Standards
with the consent of the Minister for Industry and Energy*

Price Code K

INSTITUTE FOR INDUSTRIAL RESEARCH AND STANDARDS

Ballymun Road, Dublin 9

Telegrams: Research, Dublin Telex: 25449 Telephone: (01) 370101

CONTENTS

Foreword	4
-------------	---------	---

SECTION ONE: GENERAL

1. Scope	5
2. Definitions	5

SECTION TWO: MATERIALS AND COMPONENTS

3. Concrete tiles and fittings	10
4. Special tiles	10
5. Asbestos-cement slates and fittings	10
6. Colour and texture	10
7. Nails and clips	10
8. Boarding and battens	11
9. Hip irons	12
10. Underlays	12
11. Mortar	12
12. Sheet materials	13

SECTION THREE: DESIGN

13. Weather resistance	14
14. Structural stability	14
15. Lap and pitch	15
16. Durability	16
17. Thermal insulation	17
18. Condensation	17
19. Choice of nails for fixing slates and tiles	18
20. Boarding, underlay and battening	18
21. Battens and counter battens	19
22. Method of nailing battens, counter battens and underlay	19
23. Roof drainage	19
24. Translucent slates and tiles	19
25. Vertical slating and tiling	19

SECTION FOUR: APPLICATION OF SLATES AND TILES

26. Gauge	20
27. Mechanical fixing including nailing and clipping	20
28. Eaves	22
29. Sprocketed eaves	23
30. Verges	23
31. Ridge and hip coverings	23
32. Valleys	24
33. Abutments and top edges	26
34. Saddle soakers	26
35. Translucent slates or tiles	26
36. Dormers	27
37. Chimney stacks, skylights and other projections	27
38. Vertical slating and tiling	27
39. Underlay	27
40. Battens	28

CONTENTS—(Continued)

SECTION FIVE: REPAIRS AND RECOVERING

41. Repairs	28
42. Recovering	28

SECTION SIX: SAFETY AND GENERAL PRECAUTIONS

43. General	29
44. Storage and handling	29
45. Safety	29
46. Precautions	30
47. Bibliography	30

Appendices

A — Climatic Considerations and Fixings	31
B — Thermal Insulation	31

Tables

1 — Minimum batten sizes	15
B.1—Approximate U values for some roof construction	32

Figures

1 — Map showing the country divided into two zones on the basis of wind speeds	21
2 — An example of eaves support	22
3 — Section through valley with lead lining	25
A.1—Map of Ireland showing wind speed in a gust (m/s) likely to be exceeded only once in 50 years at 10 m above the ground in open level country.	33

FOREWORD

This code has been prepared with the object of securing improvements in on-site roofing practice. The code covers design, construction and maintenance. It deals only with single lap interlocking concrete tiles and asbestos-cement slates, as the usage of other types of tiles and slates is very low. The code does not cover detailed structural design.

The code was prepared by a committee on which were representatives of the Department of the Environment, Office of Public Works, National Building Agency, Local Authorities, Tile and Slating manufacturers, Roofing contractors, the National House Building Guarantee Scheme and this Institute.

The first working paper placed before the committee was British Standard 5534, Part 1 : 1978 " Code of practice for slating and tiling ". While the code is based on this document, it differs from it in many aspects. These changes were made mainly to suit Irish conditions.

Irish Code of Practice for Slating and Tiling

SECTION ONE: GENERAL

1. SCOPE

This code deals with the design and application of asbestos-cement slating and concrete tiling, underlay, boarding, counter battens, battens and their fixings. Weathertightness and thermal resistance are considered.

2. DEFINITIONS

2.1 General

- 2.1.1 *Abutment.* The intersection of a roof surface with the part of the structure which rises above it.
- 2.1.2 *Barge board.* A component fixed along the edges of a gable and covering the ends of the horizontal roof members.
- 2.1.3 *Chimney gutter.* A gutter formed at the back of a chimney stack penetrating through a pitched roof.
- 2.1.4 *Back gutter.* A gutter formed at the back of a chimney or other penetration through a pitched roof.
- 2.1.5 *Dormer.* A vertical window or opening framed in a sloping roof.
- 2.1.6 *Dormer cheek.* A vertical side of a dormer.
- 2.1.7 *Eaves.* The lower or draining edge of a roof.
- 2.1.8 *Fascia.* The external vertical member, of various impervious materials, of a cornice or eaves construction.
- 2.1.9 *Fascia board.* A member, usually of timber, fixed to the rafter ends, wall plate or wall face immediately below the eaves.
- 2.1.10 *Flashing.* A strip of impervious material, usually metal, used to exclude water from the junction between a roof covering and another part of the structure.
- 2.1.10.1 *Apron flashing.* A flashing the lower edge of which is lapped over the roof covering.
- 2.1.10.2 *Cover flashing.* A flashing used in conjunction with other components such as soakers, the vertical parts of which it overlaps.
- 2.1.10.3 *Raking flashing.* A flashing used to cover an inclined intersection when the top edge is secured into a chase cut parallel to the top surface of the roof covering.
- 2.1.10.4 *Stepped flashing.* A flashing used to cover an inclined intersection, its upper edge being shaped to step up from course to course of brickwork or masonry and secured into the horizontal joints.
- 2.1.11 *Gable.* That part of a wall above the general eaves level at the end of a ridge or partially hipped roof.

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-