



NSAI
Standards

Irish Standard
I.S. EN 50160:2010

Voltage characteristics of electricity supplied by public electricity networks

I.S. EN 50160:2010

Incorporating amendments/corrigenda issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation - recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

<i>This document replaces:</i> EN 50160:2007	<i>This document is based on:</i> EN 50160:2010 EN 50160:2007	<i>Published:</i> 30 July, 2010 21 September, 2007
This document was published under the authority of the NSAI and comes into effect on: 16 August, 2010		ICS number: 29.020
NSAI 1 Swift Square, Northwood, Santry Dublin 9	T +353 1 807 3800 F +353 1 807 3838 E standards@nsai.ie W NSAI.ie	Sales: T +353 1 857 6730 F +353 1 857 6729 W standards.ie
Údarás um Chaighdeáin Náisiúnta na hÉireann		

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 50160

July 2010

ICS 29.020

Supersedes EN 50160:2007

English version

Voltage characteristics of electricity supplied by public electricity networks

Caractéristiques de la tension fournie
par les réseaux publics de distribution

Merkmale der Spannung in öffentlichen
Elektrizitätsversorgungsnetzen

This European Standard was approved by CENELEC on 2010-03-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

This European Standard was prepared by Working Group 1, Physical characteristics of electrical energy, of the Technical Committee CENELEC TC 8X, System aspects of electrical energy supply. It was submitted to the formal vote and was approved by CENELEC as EN 50160 on 2010-03-01.

This document is the result of an intensive cooperation between CENELEC and CEER, with involvement of CEER experts in TC 8X WG1 as well as in related Task Forces.

This document supersedes EN 50160:2007.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates were fixed:

- | | | |
|--|-------|------------|
| – latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement | (dop) | 2011-03-01 |
| – latest date by which the national standards conflicting with the EN have to be withdrawn | (dow) | 2015-03-01 |

The main differences from EN 50160:2007 are:

- new organization of the document by grouping clauses related to events and continuous phenomena;
- modification of some definitions and completion by some new definitions;
- new Clause 6 relevant to voltage characteristics in high voltage networks.

This work has been deemed so important, that before submission for vote, a CENELEC enquiry has been made, where NCs had the opportunity to respond to the most essential questions resulting from the WG discussions. This enquiry resulted in an extensive number of valuable comments, which have been carefully examined for possible consideration either for the voting draft in particular or for further work within WG1 on some main issues. Following that, the draft has been revised in depth, considering in particular the comments received on:

- the subclauses relevant to supply voltage changes, where a new formulation (capable of encompassing the needs expressed by the vast majority of the NCs) has been introduced,
- the new Clause 6, relevant to voltage characteristics in high voltage networks, where limits for harmonics and unbalance have been changed into indicative values, as new measurement surveys are taking place in several European countries, and it has been recognized as appropriate to wait for the relevant results before considering the setting of limits.

Contents

1	Scope and object	4
1.1	Scope	4
1.2	Object	4
2	Normative references	5
3	Terms and definitions	5
4	Low-voltage supply characteristics	10
4.1	General	10
4.2	Continuous phenomena	11
4.3	Voltage events	14
5	Medium-voltage supply characteristics	16
5.1	General	16
5.2	Continuous phenomena	17
5.3	Voltage events	20
6	High-voltage supply characteristics	22
6.1	General	22
6.2	Continuous phenomena	23
6.3	Voltage events	25
Annex A	(informative) Special nature of electricity	28
Annex B	(informative) Indicative values for voltage events and single rapid voltage changes	30
B.1	Long interruptions of the supply voltage	30
B.2	Short interruptions of the supply voltage	30
B.3	Voltage dips and swells	30
B.4	Swells (temporary power frequency overvoltages) between live conductors and earth	32
B.5	Magnitude of rapid voltage changes	32
Bibliography	33
Figures		
Figure 1	— Voltage levels of signal frequencies in percent of U_n used in public LV networks	13
Figure 2	— Voltage levels of signal frequencies in percent of U_c used in public MV networks	20
Tables		
Table 1	— Values of individual harmonic voltages at the supply terminals for orders up to 25 given in percent of the fundamental voltage U_1	13
Table 2	— Classification of dips according to residual voltage and duration	15
Table 3	— Classification of swells according to maximum voltage and duration	16
Table 4	— Values of individual harmonic voltages at the supply terminals for orders up to 25 given in percent of the fundamental voltage U_1	19
Table 5	— Classification of dips according to residual voltage and duration	21
Table 6	— Classification of swells according to maximum voltage and duration	22
Table 7	— Indicative values of individual harmonic voltages at the supply terminals for orders up to 25 given in percent of the fundamental voltage U_1	24
Table 8	— Classification of dips according to residual voltage and duration	26
Table 9	— Classification of swells according to maximum voltage and duration	26

1 Scope and object

1.1 Scope

This European Standard defines, describes and specifies the main characteristics of the voltage at a network user's supply terminals in public low voltage, medium and high voltage AC electricity networks under normal operating conditions. This standard describes the limits or values within which the voltage characteristics can be expected to remain at any supply terminal in public European electricity networks and does not describe the average situation usually experienced by an individual network user.

NOTE 1 For the definitions of low, medium and high voltage see 3 (Definitions).

This European Standard does not apply under abnormal operating conditions, including the following:

- a) a temporary supply arrangement to keep network users supplied during conditions arising as a result of a fault, maintenance and construction work, or to minimize the extent and duration of a loss of supply;
- b) in the case of non-compliance of a network user's installation or equipment with the relevant standards or with the technical requirements for connection, established either by the public authorities or the network operator, including the limits for the emission of conducted disturbances;

NOTE 2 A network user's installation may include load and generation.

- c) in exceptional situations, in particular,
 - 1) exceptional weather conditions and other natural disasters;
 - 2) third party interference;
 - 3) acts by public authorities;
 - 4) industrial actions (subject to legal requirements);
 - 5) force majeure;
 - 6) power shortages resulting from external events.

The voltage characteristics given in this standard are not intended to be used as electromagnetic compatibility (EMC) levels or user emission limits for conducted disturbances in public electricity networks.

The voltage characteristics given in this standard are not intended to be used to specify requirements in equipment product standards and in installation standards.

NOTE 3 The performance of equipment might be impaired if it is subjected to supply conditions which are not specified in the equipment product standard.

This standard may be superseded in total or in part by the terms of a contract between the individual network user and the network operator.

NOTE 4 The sharing of complaint management and problem mitigation costs between the involved parties is outside the scope of EN 50160.

Measurement methods to be applied in this standard are described in EN 61000-4-30.

1.2 Object

The object of this European Standard is to define, describe and specify the characteristics of the supply voltage concerning:

- a) frequency;
- b) magnitude;
- c) waveform;
- d) symmetry of the line voltages.

These characteristics are subject to variations during the normal operation of a supply system due to changes of load, disturbances generated by certain equipment and the occurrence of faults which are mainly caused by external events.

The characteristics vary in a manner which is random in time, with reference to any specific supply terminal, and random in location, with reference to any given instant of time. Because of these variations, the values given in this standard for the characteristics can be expected to be exceeded on a small number of occasions.

Some of the phenomena affecting the voltage are particularly unpredictable, which make it very difficult to give useful definite values for the corresponding characteristics. The values given in this standard for the voltage characteristics associated with such phenomena, e.g. voltage dips and voltage interruptions, shall be interpreted accordingly.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 60664-1	2007	Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests (IEC 60664-1:2007)
EN 61000-3-3	2008	Electromagnetic compatibility (EMC) – Part 3-3: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection (IEC 61000-3-3:2008)
EN 61000-4-30	2009	Electromagnetic compatibility (EMC) – Part 4-30: Testing and measurement techniques – Power quality measurement methods (IEC 61000-4-30:2008)
IEC 60364-5-53 + A1	2001 2002	Electrical installations of buildings – Part 5-53: Selection and erection of electrical equipment – Isolation, switching and control
IEC/TR 61000-2-8	2002	Electromagnetic compatibility (EMC) – Part 2-8: Environment – Voltage dips and short interruptions on public electric power supply systems with statistical measurement results
IEC/TR 61000-3-7	2008	Electromagnetic compatibility (EMC) – Part 3-7: Assessment of emission limits for fluctuating loads in MV and HV power systems

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

conducted disturbance

electromagnetic phenomenon propagated along the line conductors of a supply network

NOTE In some cases an electromagnetic phenomenon is propagated across transformer windings and hence between networks of different voltage levels. These disturbances may degrade the performance of a device, equipment or system or they may cause damage.

3.2

declared supply voltage

U_c

supply voltage U_c agreed by the network operator and the network user

NOTE Generally declared supply voltage U_c is the nominal voltage U_n but it may be different according to the agreement between the network operator and the network user.

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-